



"Gateway to the Santa Monica Mountains National Recreation Area"

AFFIDAVIT – SELF CERTIFICATION OF INSTALLATION SMOKE/CARBON MONOXIDE ALARM(S)

FOR COMPLIANCE WITH SECTION R314.3 AND R315.2 OF THE CALIFORNIA RESIDENTIAL CODE WHERE NO INTERIOR ACCESS FOR INSPECTION IS REQUIRED.

Property Owner's Name: _____ Permit No: _____
Property Address: _____

Number of Alarms Installed: Smoke: _____ Carbon: _____

Existing single family dwellings shall be provided with Carbon Monoxide alarms no later than July 1, 2011.

When the valuation of additions, alterations or repairs to existing dwelling units exceeds \$1,000.00, Section(s) R314 and R315 of the California Residential Code require that Smoke Alarms and/or Carbon Monoxide Alarms be installed in the following locations:

1. Outside of each separate dwelling unit sleeping area in the immediate vicinity of the bedroom(s)
 - Smoke Alarm and Carbon Monoxide Alarm
2. On every level of a dwelling unit including basements
 - Smoke Alarm and Carbon Monoxide Alarm
3. Within each sleeping room.
 - Smoke Alarm

Carbon Monoxide Alarms are not required in dwellings which do not contain fuel-burning appliances and that do not have an attached garage.

Multi-purpose alarms: Carbon monoxide alarms combined with smoke alarms shall comply with Section R315.1 and shall be approved by the Office of the State Fire Marshal.

Power Supply: In dwelling units with no commercial power supply, alarm(s) may be solely battery operated. In existing dwelling units, alarms are permitted to be solely battery operated where repairs or alterations do not result in the removal of wall and ceiling finishes or there is no access by means of attic, basement or crawl space. See Sections R314.4 and R315.1. An electrical permit is required for alarms which must be hardwired.

As owner of the above-referenced property, I hereby certify that the alarm(s) referenced above have been installed in accordance with the manufacturer's instructions and in compliance with the California Residential Code. The alarms have been tested and are operational.

Print Name: _____ Date: _____

Signature: _____

This certification must be returned to the Building and Safety Department prior to the final sign off of all building permits requiring compliance with Section 420.4.1 of the California Building Code. This form may be mailed to the address provided below.