

CITY OF AGOURA HILLS


BUILDING & SAFETY DIVISION 30001 LADYFACE COURT AGOURA HILLS, CA 91301 PHONE: (818) 597-7334 FAX: (818) 597-7352 www.AgouraHillsCity.org

FURNACE IN ATTIC LOCATION

IH-07

3-1-23

Furnace in Attic Location



Appliances in Attics

The following regulations apply to a furnace appliance when located in an attic in accordance with the 2022 CMC 304.4, CMC 904.9, and 2022 CRC R807.1.

- Access. At least as large as the largest component of the appliance and not less than 22-in. x 30-in.
- **Passageway Length**. When the height of the passageway is less than 6-ft. distance from the passageway access to the furnace shall not exceed 20-ft.
- Passageway Width. A passageway shall have solid flooring not less than 24-in wide.
- Work Platform. A level working platform 30-in deep x 30-in wide in front of the service side of the unit.
- **Lighting and Outlet**. A permanent 120-volt receptacle and light are located near the unit with the switch controlling the lighting fixture located at the access opening.
- Furnace.
 - O Upright furnaces may be installed in an attic, furred space, or under-floor spaces more than 5-ft in height, provided the required listings and furnace and duct clearances are observed.
 - o Horizontal furnaces may be installed in an attic, furred space, or under-floor spaces, provided the



CITY OF AGOURA HILLS

BUILDING & SAFETY DIVISION 30001 LADYFACE COURT AGOURA HILLS, CA 91301 PHONE: (818) 597-7334 FAX: (818) 597-7352 www.AgouraHillsCity.org

FURNACE IN ATTIC LOCATION

IH-07

3-1-23

required listings and furnace and duct clearances are observed.

• Clearances. Minimum clearances from combustibles shall comply with the listing of the appliance.