

 <p>CITY OF AGOURA HILLS</p>	<p align="center">CITY OF AGOURA HILLS</p> <p align="center">BUILDING & SAFETY DIVISION</p> <p align="center">30001 LADYFACE COURT AGOURA HILLS, CA 91301</p>	<p align="right">Email: Permits@AgouraHillsCity.org PHONE: (818) 597-7334 www.AgouraHillsCity.org</p>	
<p align="center">ISLAND VENT REQUIREMENTS</p>		<p align="center">IH-18</p>	<p align="center">9-15-23</p>

The 2022 California Plumbing Code requires the following for a compliant island vent:

Requirement

CPC Reference

- | | |
|--|-----------------|
| | *Click for link |
| • Vent piping to be sized per CPC Table 703.2 | 904.1 |
| • Drainage fittings to be used on the vent line below floor level | 909.1 |
| • Minimum ¼ inch per foot slope | 909.1 |
| • Island return vent to be as high as possible, but not less than drain board height | 909.1 |
| • Return vent bend to be a one-piece fitting or an assembly of a 45 degree, a 90 degree, and a 45-degree elbow in that order | 909.1 |
| • Return vent to connect to horizontal drain w/ Wye branch fitting | 909.1 |
| • Foot vent required to connect with Wye branch fitting | 909.1 |
| • Horizontal Portion of foot vent less than 20 feet for 1 1/2-inch pipe | T 703.2 Note 6 |
| • Clean out required in vertical portion of foot vent, and upper terminal of horizontal drain line. To be accessible. | 909.1 |
| • Approved vertical to horizontal drainage fitting required (Long Sweep) | 706.4 |
| • No additional fixtures allowed on island sink drain | 909.1 |

