

CHUMASH PARK RESTROOM REHABILITATION PROJECT (the “Project”) NIB NO. 24-04

BID SUBMITTAL QUESTIONS (Second set – August 9, 2024)

1. The sewer profile has the new sewer starting at 8-9’ deep and running at 10% slope, connecting at 17’ deep. You see this on the sewer profile drawings. Why are we running the sewer so low the entire way?

Answer: The sewer line runs at 10% slope to avoid impacting the tree roots prior to the mainline connection.