

**FINAL FOUNDATION REPORT  
PROPOSED REYES ADOBE ROAD BRIDGE  
WIDENING OVER U.S. HIGHWAY 101  
BRIDGE NO. 53-1726  
AGOURA HILLS, CALIFORNIA**

**Kleinfelder Project No. 75010**

**April 2, 2008**



**KLEINFELDER**

An employee owned company

April 2, 2008  
Project No. 75010

**STV Incorporated**  
100 Pacifica, Suite 140  
Irvine, CA 92618

Attention: Mr. Tim J. McGrady, P.E.  
Project Manager

**Subject: Final Foundation Report  
Proposed Reyes Adobe Road Bridge Widening  
Over U.S. Highway 101  
Bridge No. 53-1726  
Agoura Hills, California**

Dear Mr. McGrady:

Kleinfelder West, Inc. (Kleinfelder) is pleased to submit this Final Foundation Report for the proposed Reyes Adobe Road Bridge Widening over U.S. Highway 101, Bridge Number 53-1726, Agoura Hills, California. This report supersedes our Final Foundation Report dated September 26, 2007 and includes an updated Pile Data Table (Table 6), supplemental recommendations regarding uplift capacity of the foundations, additional discussion/recommendations regarding pile drivability, and our response to additional Caltrans review comments. Our services have been performed in accordance with our agreed-upon scope of work. The authorized scope of work included field exploration, laboratory testing, geotechnical engineering analyses, and report preparation. This report provides geotechnical evaluation and recommendations for the proposed bridge. A limited Aerially Deposited Lead (ADL) study is also included in our scope and a stand-alone technical memo for this study is provided in Appendix D of this report. Review comments by Caltrans dated July 3, October 12, and 29, 2007 have been incorporated into this updated Final Foundation Report.

We appreciate the opportunity to provide geotechnical and environmental services to you on this project and trust the information in this report meets the current project needs. If there are any questions, please contact the undersigned.

Respectfully submitted,

**KLEINFELDER WEST, INC.**

Justin J. Kempton, PE, GE  
Area Manager



Endi Zhai, PhD, PE, GE  
Principal Engineer



Distribution: (15) addressee

---

**TABLE OF CONTENTS**


---

| <u>Section</u>   | <u>Page</u> |
|--|-------------|
| <b>1.0 INTRODUCTION .....</b>                          | <b>1</b>    |
| 1.1 General.....                                       | 1           |
| 1.2 Project Description.....                           | 1           |
| 1.3 Purpose and Scope of Work.....                     | 2           |
| 1.4 Limitations.....                                   | 2           |
| <b>2.0 SITE DESCRIPTION .....</b>                      | <b>4</b>    |
| <b>3.0 PREVIOUS STUDIES .....</b>                      | <b>5</b>    |
| <b>4.0 GEOTECHNICAL INVESTIGATION PROGRAM.....</b>     | <b>6</b>    |
| 4.1 Field Exploration.....                             | 6           |
| 4.2 Laboratory Testing.....                            | 6           |
| <b>5.0 SITE GEOLOGY AND SUBSURFACE CONDITIONS.....</b> | <b>8</b>    |
| 5.1 Geologic Conditions.....                           | 8           |
| 5.2 Subsurface Conditions.....                         | 8           |
| 5.2.1 Earth Materials.....                             | 9           |
| 5.2.2 Groundwater Conditions .....                     | 9           |
| 5.3 Subsurface Profile and Engineering Parameters..... | 10          |
| <b>6.0 SEISMIC DESIGN CONSIDERATION .....</b>          | <b>12</b>   |
| 6.1 Ground Surface Rupture.....                        | 12          |
| 6.2 Seismic Shaking and Design ARS Curves .....        | 12          |
| 6.3 Liquefaction Potential .....                       | 13          |
| 6.4 Seismic Compaction .....                           | 14          |
| <b>7.0 DISCUSSION AND RECOMMENDATIONS .....</b>        | <b>15</b>   |
| 7.1 Scour .....  | 15          |
| 7.2 Corrosion .....                                    | 15          |
| 7.3 Slope Stability .....                              | 16          |
| 7.4 Bridge Foundation Recommendations .....            | 17          |
| 7.4.1 Foundation Type.....                             | 17          |
| 7.4.2 Axial Pile Capacity .....                        | 17          |
| 7.4.3 Lateral Pile Capacity .....                      | 19          |

|            |  |           |
|------------|--|-----------|
| 7.5        | Bridge Approach Embankments .....        | 22        |
| 7.5.1      | Approach Fill Requirements .....         | 22        |
| 7.5.2      | Settlement and Waiting Period .....      | 22        |
| 7.6        | Lateral Earth Pressures .....            | 23        |
| 7.7        | Wingwalls.....                           | 24        |
| 7.8        | Wall Drainage .....                      | 24        |
| <b>8.0</b> | <b>CONSTRUCTION CONSIDERATIONS .....</b> | <b>25</b> |
| 8.1        | Site Preparation .....                   | 25        |
| 8.2        | Earthwork and Backfill .....             | 25        |
| 8.3        | Settlement Monitoring .....              | 26        |
| 8.4        | Temporary Excavations and Shoring.....   | 26        |
| 8.5        | Pile Installation.....                   | 27        |
| 8.5.1      | General .....                            | 27        |
| 8.5.2      | Pile Driving .....                       | 27        |
| 8.6        | Surface Water Control .....              | 29        |
| 8.7        | Geotechnical Observation .....           | 29        |
| <b>9.0</b> | <b>REFERENCES .....</b>                  | <b>30</b> |

### **List of Tables, Figures, and Appendices**

|          |   |
|----------|---|
| Table 1  | Summary of Design Parameters for Slope Stability Analyses |
| Table 2  | Summary of Design Parameters for Foundation Design        |
| Table 3  | Summary of Seismic Design Parameters                      |
| Table 4  | Summary of Corrosion Laboratory Tests                     |
| Table 5  | Summary of Slope Stability Analyses                       |
| Table 6  | Pile Data Table   |
| Table 7A | Summary of Lateral Pile Capacity Analysis – Pinned-Head   |
| Table 7B | Summary of Lateral Pile Capacity Analysis – Fixed-Head    |

- Figure 1 Site Location Map
- Figure 2 General Plan
- Figure 3 Plot Plan
- Figure 4 Log of Test Borings
- Figure 5 Geological Cross Section
- Figure 6 ARS Curve
- Figure 7 Foundation Plan
- Figure 8 Expansive Soil Exclusion Zone

- Appendix A Field Exploration
- Appendix B Laboratory Testing
- Appendix C Engineering Analyses
- Appendix D Technical Memorandum for Limited ADL Study
- Appendix E Response to Caltrans Review Comments
- Appendix F Technical Memorandum for Pile Foundation Stiffness Matrices

---

## 1.0 INTRODUCTION

---

### 1.1 General

The City of Agoura Hills, proposes to widen the existing two-lane Reyes Adobe Road Bridge over the U.S. Highway 101 (Bridge No. 53-1726) located in the City of Agoura Hills, California. The location of the site is shown in Figure 1, Site Location Map and the proposed layout is shown in Figure 2, General Plan. The proposed widening will be designed generally in accordance with current Caltrans standards.

Our services have been performed in accordance with our agreed-upon scope of work. The authorized scope of work included field exploration, laboratory testing, geotechnical engineering analyses, and report preparation. This report provides geotechnical evaluation and recommendations for the proposed bridge structure. A limited Aerially Deposited Lead (ADL) study is also included in our scope and a stand-alone technical memo for this study is provided in Appendix D of this report.

Caltrans review comments dated July 3, 2007 on the Draft Foundation Report and comments dated October 12 and 27, 2007 regarding our September 26, 2007 Final Foundation Report have been incorporated in this updated Final Foundation Report. Our Response Letters to Caltrans Comments are included in Appendix E.

### 1.2 Project Description

The existing Reyes Adobe Road Bridge over the U.S Highway 101 (Bridge No. 53-1726) was constructed in 1950 between Canwood Drive and Agoura Road in Agoura Hills, California. The existing Reyes Adobe Road Overcrossing (OC) supports one northbound lane and one southbound lane across US 101 Freeway. Currently, the Reyes Adobe Road OC is a four-span, with precast prestressed girders in spans 2 and 3, and cast-in-place / precast girders in spans 1 and 4. The length and width are 221 feet and 37.8 feet, respectively. The proposed widening will be on the west side and will consist of four-span, precast prestressed girder with intermediate and end diaphragms. The width for the widening portion will be 58.8 feet.

Based on the general plan and topographic information, the approach embankments beneath the widening near abutments 1 and 5 will require up to approximately 12 feet of fill from the existing grade, with embankment slope gradients that will match the existing gradients of approximately 1.5H:1V slope in the longitudinal direction (beneath the structure). Earthwork at the bent locations is anticipated to be nominal and limited to excavation and backfill associated with pile cap construction.

### **1.3 Purpose and Scope of Work**

The purpose of our investigation was to evaluate subsurface conditions and engineering properties of the subsurface soils encountered, and provide geotechnical recommendations to aid in the design and preparation of the proposed bridge widening plans and specifications. The scope of work included the following tasks:

- Review of existing geotechnical and geologic data within and adjacent to the project site.
- Drilling, sampling and logging of three (3) hollow stem auger borings. Two of the borings (B-1 and B-2) were drilled at the location of the proposed bridge widening and one boring (B-3) was drilled at the locations of the Northbound on-ramp and planned fill for the widening.
- Laboratory testing of selected samples to characterize the subsurface conditions.
- Geotechnical engineering analyses.
- Preparation of this foundation report.

A limited Aerially Deposited Lead (ADL) study is also included in our scope and a stand-alone technical memo for this study is provided in Appendix D of this report.

### **1.4 Limitations**

This report has been prepared for STV and The City of Agoura Hills. It is intended solely for their use in the design and construction of the project as described herein. It may not contain sufficient information for other uses or purposes of other parties.

The findings, conclusions and recommendations presented in this report were prepared in accordance with generally accepted geotechnical engineering practice. No other warranty, direct or implied, is made. Field exploration program was based on the project plans

provided to us by STV at the time of our investigation.

The scope of our geotechnical services did not include any environmental site assessment for the presence or absence of hazardous/toxic materials in the soil, surface water, ground water or atmosphere, or the presence of wetlands. A limited ADL study was conducted and the results are provided in Appendix D.

Our evaluation of subsurface conditions at the site has considered subgrade soil and groundwater conditions present at the time of our investigation. The influence(s) of post-construction changes to these conditions such as introduction of water into the subsurface will likely influence future performance of the proposed project.

The client has the responsibility to see that all parties to the project, including the designer, contractor, subcontractors, etc., are made aware of this report in its entirety. This report contains information, which may be useful in the preparation of contract specifications. However, the report is not designed as a specification document and may not contain sufficient information for this use without proper modification.

This report may be used only by the client and only for the purposes stated within a reasonable time from its issuance, but in no event later than three years from the date of the report. Land or facility use, on and off-site conditions, regulations, or other factors may change over time, and additional work may be required with the passage of time. Any party other than the client who wishes to use this report shall notify Kleinfelder of such intended use. Based on the intended use of the report, Kleinfelder may require that additional work be performed and that an updated report be issued. Non-compliance with any of these requirements by the client or anyone else will release Kleinfelder from any liability resulting from the use of this report by any unauthorized party and client agrees to defend, indemnify, and hold Kleinfelder harmless from any claim or liability associated with such unauthorized use or non-compliance.



---

## 2.0 SITE DESCRIPTION

---

Existing Reyes Adobe Road within the project limits is a north-south four lane arterial street that narrows to two lanes at the bridge structure. Existing topographic relief generally descends from North to South. The existing grade elevations at Abutment 1 and Abutment 5 are 940 feet and 930 feet respectively. Bents 2, 3 and 4 are within the depressed portion of U.S. Highway 101 and the ground surface elevations at these locations are approximately 918 feet, 916 feet, and 916 feet (above mean sea level), respectively. The existing embankment fill slopes beneath the existing bridge are moderately steep with average inclinations of approximately 1.5H:1V. The existing slopes have a flatter gradient further away from the existing bridge.

---

### 3.0 PREVIOUS STUDIES

---

The following previous data were reviewed:

- Preliminary Foundation Report, Proposed West Side Widening, Reyes Adobe Overcrossing (Bridge No. 53-1726), Agoura Hills, California, by Kleinfelder, Inc., Kleinfelder Project No. 75010, dated August 8, 2006.
- Preliminary Foundation Report (PRF), Reyes Adobe Overcrossing at US 101, Bridge No. 53-1726, Agoura Hills, California, by Group Delta Consultants (GDC), GDC Project No. I-430, dated April 2, 2004.
- As-built drawings (Including Log of Test Borings), by Caltrans, Approved April 13, 1964.

Other available maps and reports reviewed include United States Geological Survey (USGS) Quad maps and geologic data from in-house files.

---

## 4.0 GEOTECHNICAL INVESTIGATION PROGRAM

---

The geotechnical investigation program consisted of field exploration and laboratory testing as discussed below.

### 4.1 Field Exploration

The subsurface conditions at the location of the proposed widening were investigated by Kleinfelder on January 3, 2007 by drilling three hollow stem auger borings (B-1, B-2, and B-3). Borings B-1 and B-2 were drilled near the locations of Bents 2 and 4, respectively. One boring (B-3) was also drilled on the northbound ramp paving area. Borings B-1 through B-3 were drilled using a 8-inch diameter hollow- stem auger drilling system by Jet Drilling to depths ranging from approximately 31 to 46.5 feet. The boring logs are presented in Appendix A. The approximate boring locations are shown in Figure 3, Plot Plan. Borings B-1 and B-2 which were used for bridge foundation design are included on the logs of test borings (LOTB) plan, Figure 4.

In the borings, soil samples were taken at approximately 5-foot intervals, to the maximum depth explored, with either a Standard Penetration Test (SPT) sampler or a California Modified split spoon sampler. All samples were stored and transported to our laboratory for testing. The soils from the test borings were visually classified in the field by a Kleinfelder staff engineer in general accordance with the Unified Soil Classification System per ASTM D-2488. Field classifications and boring logs were revised as necessary based on laboratory test results and the review of a registered Geotechnical Engineer. At the conclusion of drilling, the borings were abandoned by backfilling with cement-bentonite grout.

Three shallow hand auger borings (Borings HB-1 through HB-3) were also excavated to obtain samples for analytical testing which is included in Appendix D of this report.

### 4.2 Laboratory Testing

Laboratory tests were performed on selected samples to characterize the soils and to develop index and engineering properties of the soils. The tests performed are indicated on

the Logs of Borings, which are presented in Appendix A. A detailed description of the laboratory testing program and test results are presented in Appendix B. Laboratory tests performed consisted of:

- In situ moisture content and dry density, ASTM D-2937
- Atterberg limits (liquid limit and plastic limit), ASTM D-4318
- Grain size distribution test, ASTM D-422-63/CT-202/203
- Wash analysis (fines content or % passing #200 sieve), ASTM D-1140
- Direct shear test, ASTM D-3080
- Consolidation test, ASTM D-2435/CT-219
- Corrosivity tests (pH, sulfates, chlorides and electrical resistivity),  
CT-532/643/417/422

---

## 5.0 SITE GEOLOGY AND SUBSURFACE CONDITIONS

---

### 5.1 Geologic Conditions

The project site is located in the city of Agoura Hills in the western portion of Los Angeles County, and within the southwestern portion of the Transverse Ranges Geomorphic province of California. The Transverse Ranges consist of generally east-west trending mountains and valleys, which contrast with the overall north-northwest structural trend elsewhere in the state. The anomalous structure of the Transverse Ranges is attributed to the effects of compressive deformation (crustal shortening), generated by north-south convergence along the big bend of the San Andreas fault (Yerkes, 1987) north of the San Gabriel Mountains and the motion of the Pacific Plate. The valleys and mountains of the Transverse Ranges are typically bounded by a series of east-west trending, generally north dipping reverse faults with left-lateral, oblique movement.

The Reyes Adobe Road OC over US Highway 101 is located in a pass within Lindero Canyon. The site is located in the Santa Monica Mountains of the Transverse Range Geomorphic Province of California. At the interchange of the Reyes Adobe Road with US 101 Freeway, the surficial materials consist of younger alluvium (silts and clays). An outcrop of basalt that correlates to the Conejo Volcanics of the Santa Monica Mountains is observed on the southern side of the Reyes Adobe Road OC. Outcrops of shaley claystones and siltstones, of the Topanga Formation, are exposed on the north side of the bridge. At depth, basalt and/or sedimentary units of the Conejo Volcanics or the Topanga Formation may be encountered.

### 5.2 Subsurface Conditions

The subsurface conditions were evaluated based on the field investigation and laboratory testing data obtained for this project and review of the as-built LOTBs for the existing bridge. Generally, the subsurface materials encountered consisted of compacted fill underlain by alluvium and bedrock. Bedrock was encountered at depths of approximately 19 feet and 22 feet in Borings B-1 and B-2 (drilled Near Bents 2 and 4) corresponding to elevations 897 feet and 894 feet, respectively. The top of bedrock appears to descend from Abutment 1 location towards the Abutment 5 location. Past grading at this location

appeared to involve excavations, fills and cut slopes to achieve existing grades.

### **5.2.1 Earth Materials**

The earth materials encountered in the current borings are comparable to the materials reported on the as-built LOTBs for the existing bridge. The materials encountered are summarized below.

The materials encountered across the site generally consist of previously placed compacted fill material (Qf), underlain by alluvium, and by bedrock. The compacted fill consists generally of silty sand and silty clay. The Alluvium (Qa) generally consists of stiff to very stiff sandy clay and dense silty sand with some gravel. The bedrock consists of claystone and siltstone of the Upper Topanga Formation Bedrock. The bedrock is thinly bedded. The alluvium/bedrock contact appears to deepen abruptly between Abutment 1 and Bent 2. Near and between Bents 2 through 4 and Abutment 5, alluvium/bedrock contact deepens gently.

At Abutment 1, the bedrock contact is anticipated to be at approximate elevation 910 feet (approximately 26 feet below ground surface). At Bents 2 through 4 and at Abutment 5, the bedrock contact appears to deepen gently from approximate elevation 897 at Bent 2 to approximate elevation 894 near Abutment 5. The bedrock is anticipated to be approximately 26 feet below ground surface at Bents 2 through 4 and approximately 35 feet below ground surface at Abutment 5. A generalized cross section is presented in Figure 5.

### **5.2.2 Groundwater Conditions**

Groundwater was encountered in Boring B-2 at a depth of approximately 19 feet below grade (or approximate elevation 897 feet). Groundwater was not encountered within borings B-1 and B-3 to a maximum depth of approximately 36.5 and 46.5 below the ground surface, respectively. The groundwater was encountered approximately 3 feet above bedrock within the silty sand alluvium material. The as-built LOTBs with borings from June 1962 reported groundwater approximately at elevations 891 feet to 894 feet. For our design, we used a groundwater level at an elevation of 897 feet at each support location.

Groundwater may fluctuate due to seasonal variation, nearby construction, irrigation, and numerous other man-made and natural influences.

### **5.3 Subsurface Profile and Engineering Parameters**

Design parameters summarized in Tables 1 and 2 for new embankment fill, existing compacted fill, alluvium, weathered and competent formational materials were developed based on the results of our field investigations, laboratory testing, previous investigations, and our experience with similar materials.

The new compacted fill and existing compacted fill strength parameters were selected based on review of the test results for materials encountered as well as similar materials in the general vicinity of the site. Sufficient tests should be performed for the proposed fill materials to achieve the minimum shear strength parameters for abutment slope stability. Our recommendations for the fill materials provided in Section 7.5.1 Approach Fill Requirements of this report shall be followed.

The foundation design soil profiles used at each support location are illustrated in Figure 5. Strength parameters assigned for alluvium and bedrock are based on direct shear testing results as shown in Appendix B. The laboratory direct shear testing results for similar soils were combined and the upper and lower bound values were reviewed. The recommended values for design tend to be conservative in our opinion.

**Table 1 Summary of Design Parameters for Slope Stability Analysis**

| Layer No. | Material Type                     | Angle of Internal Friction (deg) |               | Cohesion (psf) |               |
|-----------|-----------------------------------|----------------------------------|---------------|----------------|---------------|
|           |                                   | Static                           | Pseudo-static | Static         | Pseudo-static |
| 1         | New Fill                          | 30                               | 30            | 200            | 200           |
| 2         | Old Fill                          | 30                               | 30            | 200            | 200           |
| 3         | Alluvium (Silty and Sandy Clays)  | 24                               | 24            | 600            | 900           |
| 4         | Alluvium (Silty Sand with gravel) | 35                               | 35            | 100            | 100           |
| 5         | Bedrock<br>(Highly Weathered)     | 21                               | 25            | 450            | 800           |
| 6         | Bedrock                           | 32                               | 32            | 500            | 500           |

Note: see soil profile in Figure 5.

**Table 2 Summary of Design Parameters for Foundation Design**

| Layer No. | Material Type                     | Angle of Internal Friction (deg) | Cohesion (psf) |
|-----------|-----------------------------------|----------------------------------|----------------|
| 1         | New Fill                          | 30                               | -              |
| 2         | Old Fill                          | 30                               | -              |
| 3         | Alluvium (Silty and Sandy Clays)  | -                                | 900            |
| 4         | Alluvium (Silty Sand with gravel) | 30                               | -              |
| 5         | Bedrock (Highly Weathered)        | 25                               | 800            |
| 6         | Bedrock                           | 32                               | 500            |

Note: see soil profile in Figure 5.



## 6.0 SEISMIC DESIGN CONSIDERATION

---

### 6.1 Ground Surface Rupture

The project site is not located within one of the Fault-Rupture Hazard Zones in California designated by the California Geological Survey. No faults are mapped as crossing the site or projecting towards the site in the geologic literature reviewed. Therefore, the potential for ground surface fault rupture at the site is considered low.

### 6.2 Seismic Shaking and Design ARS Curves

Based on the Caltrans latest Seismic Hazard Map (1996), the controlling fault for the Reyes Adobe Road OC is the Malibu Coast-Santa Monica-Hollywood-Raymond (MMR) fault, with a closest distance of approximately 11 km. The MMR is a reverse/oblique (RO) fault and could generate a moment magnitude of 7.5 for the maximum credible earthquake (MCE). The Chatworth/S (CWS) and Chatworth/N (CWN) Faults, with a MCE magnitude of 6.25 and 6.5, are located with a closest distance of about 8 and 10 km, respectively; their type of faulting is unknown as defined in the technical report to accompany the Caltrans 1996 Seismic Hazard Map. According to the latest Caltrans Seismic Hazard Map (1996), the peak bedrock acceleration (PBA) at the site is within the contour zone of 0.4g and 0.5g. According to Caltrans Practice, a PBA value of 0.5g should be used. Based on the Caltrans Guidelines for Structures Foundations (2006), the PBA value ascertained from the Seismic Hazard Map shall be verified with Sadigh et al. (1997) attenuation relationship. Calculations using the Sadigh et al. (1997) attenuation relationship for the controlling fault MMR indicated a PBA of 0.49g.

The recommended seismic design parameters are provided in Table 3 below:

**Table 3 Summary of Seismic Design Parameters**

| <b>Seismic Parameters</b>     | <b>Design Recommendation and Reference</b>                        |
|-------------------------------|---|
| Controlling Fault             | MMR (Mualchin, 1996a)   |
| Type of Fault                 | Reverse/Oblique(Mualchin, 1996b)                                  |
| Site Distance from the Fault  | 11 km (Mualchin, 1996a)   |
| Earthquake Magnitude (MCE)    | 7.5 (Mualchin, 1996a,b)   |
| Peak Acceleration             | 0.5g  |
| Soil Profile Type             | S <sub>D</sub> (Table B.1, 2004 Caltrans Seismic Design Criteria) |
| Standard ARS Curve (Modified) | Figure B.8 (2004 Caltrans SDC) modified for directivity           |

The standard ARS Curve presented in Figure B.8 of Caltrans Seismic Design Criteria (SDC) for 0.5g was modified to account for near source fault rupture directivity effect as follows:

- 20% increase in spectral values for periods equal to or greater than 1.0 second;
- No change for periods less than 0.5 seconds; and
- Spectral ordinates for periods between 0.5 and 1 second shall be determined by linear interpolation.

The standard ARS curve, modified standard ARS curve and their ordinate values are presented in Figure 6.

### **6.3 Liquefaction Potential**

When a loose, saturated granular deposit is subjected to seismic loading without substantial dissipation of excess pore water pressure, the deposit may liquefy and lose its shear strength.

Based upon groundwater condition encountered and the presence of stiff to very stiff, and dense very dense alluvial soils, and formational subsurface materials, the potential for

liquefaction at the site is considered low. Liquefaction induced ground settlements are expected to be negligible.

#### **6.4 Seismic Compaction**

Seismic compaction is a phenomenon in which loose, dry or partly saturated sands tend to settle or densify during strong earthquake shaking. A procedure for estimating the probable settlement of dry sands during earthquakes was developed by Tokimatsu and Seed (1987). Based on these procedures, site-specific data, we estimate that the seismic compaction during the design earthquake will be negligible.

## 7.0 DISCUSSION AND RECOMMENDATIONS

### 7.1 Scour

Scour is not applicable at this site because the bridge does not traverse a water crossing.

### 7.2 Corrosion

Caltrans Corrosion Guidelines Section 5.5 states that the Department considers a site to be corrosive to foundation elements, at bridge structures, if one or more of the following conditions exist for the soil and/or water samples taken at the site (Caltrans, 2003):

- Chloride concentration is greater than or equal to 500 ppm
- Sulfate concentration is greater than or equal to 2000 ppm
- pH is 5.5 or less

A representative sample of the site soils was tested for pH, sulfate content, chloride content, and minimum resistivity. The results of these tests are presented in Table 4.

Based on the results of the corrosion analyses, the tested material is considered non-corrosive based on the above criteria. However, due to low resistivity, on-site soil may have corrosion potential for buried metal. This should be considered in the design of buried metal structures.

**Table 4 Summary of Corrosion Laboratory Tests**

| Boring  | Sample Depth (ft, bgs) | USCS Soil Type  | Minimum Resistivity (ohm-cm) | pH  | Sulfate Content (ppm) | Chloride Content (ppm) |
|---|------------------------|-----------------|------------------------------|-----|-----------------------|------------------------|
| B-3   | 2.5-5                  | Silty Clay (CL) | 1100                         | 7.8 | 14                    | 63                     |
| Notes:<br>ohm-cm = ohm-centimeter; ppm = parts per million; USCS = Unified Soil Classification System |                        |                 |                              |     |                       |                        |

### 7.3 Slope Stability

Based on the general plan and topographic information, the approach embankments beneath the widening between Abutment 1 and Bent 2 and between Bent 4 and Abutment 5 will require up to approximately 12 feet of fill from the existing grade. The embankment slope gradients are planned to match the existing gradients of approximately 1.5H:1V slope in the longitudinal direction (beneath the structure). Our recommendations for the new embankment fill are provided in Section 7.5.1 Approach Fill Requirements of this report.

Overall (global) slope stability of the two slopes discussed was analyzed using the strength parameters as summarized in Table 1. Both Modified Bishop's Method for circular slip surfaces and the Modified Janbu Method for slip surfaces of noncircular shape were applied using the computer program SLIDE V5.0 (Rocscience, 2005). The design criteria utilized are as follows: permanent abutment slopes are required to have a minimum factor of safety of 1.5 for the static condition; and a minimum factor of safety of 1.1 for the pseudostatic condition using the Caltrans recommended horizontal earthquake loading coefficient equal to 1/3 of the horizontal peak acceleration. A horizontal earthquake loading coefficient of 0.17 g was used.

Results of the slope stability analyses of the proposed bridge abutment slopes indicate that the required minimum static and pseudostatic factors of safety are satisfied provided the abutment slopes are paved. A summary of the slope stability analysis results are presented in Table 5 below. The slope stability analysis results are included in Appendix C.

**Table 5 Summary of Slope Stability Analysis**

| Slope Location                      | Factor of Safety             |               |                                |               |
|-------------------------------------|------------------------------|---------------|--------------------------------|---------------|
|                                     | Circular (Bishop Simplified) |               | Non-Circular (Janbu Corrected) |               |
|                                     | Static                       | Pseudo-Static | Static                         | Pseudo-Static |
| Slope Between Abutment 1 and Bent 2 | 1.60                         | 1.24          | 1.58                           | 1.22          |
| Slope Between Bent 4 and Abutment 5 | 1.72                         | 1.35          | 2.85                           | 1.41          |

Although the approach abutment slopes are expected to be grossly stable, erosion and

surficial instability may be a concern during periods of heavy or intense rainfall. Any existing erosion should be properly repaired. Any deep erosion gullies will require removal by adequate benching into the slope and replacing the eroded material with compacted fill. Slope paving is required for the 1.5H:1V or steeper abutment slopes.

Erosion control and highway planting should be performed in accordance with Section 20 of Caltrans Standard Specifications. Excessive irrigation of slopes should be avoided. Appropriate drainage devices should be placed at the top of all slopes such that water does not flow over slope faces in an uncontrolled manner.

## **7.4 Bridge Foundation Recommendations**

### **7.4.1 Foundation Type**

Foundation types that are similar to those supporting the existing overcrossing were desired for support of the proposed widening to maintain the compatibility. Based on the as-built plans, Abutments 1 and 5 are each supported on 5 vertical Class I (now Class 90) driven concrete piles with a design loading of 90 kips. Bents 2 through 4 are each supported on 16 vertical Class II (now Class 90) concrete piles with a design loading of 90 kips.

Factors considered included compatibility, constructability, subsurface materials, differential settlement between supports, structure demands, soil capacity and corrosion and economy.

Based on our analyses, we recommend using Caltrans Standard 15-inch driven concrete piles to support the proposed structure at all supports.

### **7.4.2 Axial Pile Capacity**

The axial capacity of the proposed piles was estimated using the computer program APILE Version 4.0 (Ensoft, 2004). Axial capacity for the 15-inch concrete piles includes skin friction and tip resistance. Skin friction in the new fill is ignored. To calculate the allowable geotechnical capacity in compression, a factor of safety of 2.0 was applied. The axial pile capacity calculations are provided in Appendix C. The recommended tip elevations are summarized in Table 6. Table 6 has been updated to include tension demands.

Table 6 Pile Data Table

| Location | Pile Type           | Bottom of Pile Cap Ele. (ft, MSL) | Design Loading (service) (kips) | Nominal Resistance (kips) |         | Design Tip Ele. (ft, MSL) <sup>1</sup> | Specified Tip Elevation (ft, MSL) |
|----------|---------------------|-----------------------------------|---------------------------------|---------------------------|---------|--|-----------------------------------|
|          |                     |                                   |                                 | Compression               | Tension |  |                                   |
| Abut 1   | 15" Concrete Driven | 929.64                            | 90                              | 180                       | -       | 904.0(1)<br>912.6(3)                   | 904.0                             |
| Bent 2   | 15" Concrete Driven | 907.75                            | 90                              | 180                       | 15      | 879.0(1)<br>897.75(2)<br>892.2(3)      | 879.0                             |
| Bent 3   | 15" Concrete Driven | 907.75                            | 90                              | 180                       | 15      | 879.0(1)<br>897.75(2)<br>892.2(3)      | 879.0                             |
| Bent 4   | 15" Concrete Driven | 907.75                            | 90                              | 180                       | 15      | 879.0(1)<br>898.75(2)<br>892.1(3)      | 879.0                             |
| Abut 5   | 15" Concrete Driven | 924.82                            | 90                              | 180                       | -       | 889.0(1)<br>908.8(3)                   | 889.0                             |

**Notes:**

<sup>1</sup> Design tip elevation is controlled by the following demands: (1) Compression, (2) Tension, and (3) Lateral.

<sup>2</sup> The proposed piles should be spaced at a minimum of 3 pile diameters (center-to-center).

Pile settlements were evaluated using the load transfer method implemented in the APILE program. The estimated settlement of proposed 15-inch piles under the nominal compression loads is less than ½ inch. The calculations are included in Appendix C.

Hard Driving Conditions may be encountered in the deeper (lower) bedrock unit. Construction considerations regarding pile installation are presented in Section 8.5 of this report.

Kleinfelder conducted analyses to calculate the single pile head stiffness and pile group stiffness matrices for bent piles of the proposed bridge. The results of our analyses were presented in our Technical Memorandum dated January 4, 2008 which is included with this report as Appendix F.

### 7.4.3 Lateral Pile Capacity

Lateral loads may be resisted by the piles and the passive resistance of the soils. The capacities presented below are based on the strength of the soils. The pile sections should be checked to verify the structural capacity of the piles. For service condition, we assumed a ¼-inch deflection at pile head with gross moment of inertia ( $I_g$ ). For seismic condition, we used cracked moment of inertia ( $I_c$ ) (assumed  $I_c=0.5 \times I_g$ ) and assumed 1-inch deflection at pile head. The lateral pile capacity was evaluated using the computer program LPILE Plus Version 5.0 for Windows (Ensoft, 1985-2006). The lateral pile capacity calculations are included in Appendix C. The results are summarized in Tables 7A (pinned-head condition) and 7B (fixed-head condition). Note that for the fixed-head condition, the transfer moment capacity of the pile head will control the maximum lateral capacity.

The lateral pile capacities shown in Tables 7A and 7B are for single piles. Piles in groups may be considered to act individually when the center-to-center spacing is greater than 3 pile diameters in the direction normal to loading and 8 pile diameters in the direction parallel to loading. Based on pile layout (see Figure 7), the abutment piles may be considered to act individually. To account for bent piles group action in the direction parallel to loading, the lateral capacities listed in Tables 7A and 7B should be multiplied by an appropriate lateral group reduction factor as follows:

- For spacing of 8 pile diameters or greater, no reduction in lateral capacity is necessary.
- For spacing of 5 pile diameters, a lateral group reduction factor of 0.9 should be applied.
- For spacing of 3 pile diameters, a lateral group reduction factor of 0.7 should be applied.
- For spacing in between those provided below, a linear interpolation may be utilized to calculate the reduction factor.



**Table 7A Summary of Lateral Pile Capacity Analysis (Pinned Head Condition)**

| Location | Pile Type              | Bottom of Pile Cap Ele. (ft, MSL) | Pile Deflection (in) | Maximum Lateral Shear Force (kips) | Maximum Moment (kips-ft) | Depth to Max. Moment from Pile Cap (ft) |
|----------|------------------------|-----------------------------------|----------------------|------------------------------------|--------------------------|---|
| Abut 1   | 15"<br>Concrete Driven | 929.64                            | 0.25                 | 19                                 | 41                       | 4.4                                     |
|          |                        |                                   | 1.0                  | 42                                 | 96                       | 4.2                                     |
| Bent 2   | 15"<br>Concrete Driven | 907.75                            | 0.25                 | 17                                 | 41                       | 4.7                                     |
|          |                        |                                   | 1.0                  | 26                                 | 70                       | 5.2                                     |
| Bent 3   | 15"<br>Concrete Driven | 907.75                            | 0.25                 | 17                                 | 41                       | 4.7                                     |
|          |                        |                                   | 1.0                  | 26                                 | 70                       | 5.2                                     |
| Bent 4   | 15"<br>Concrete Driven | 907.75                            | 0.25                 | 23                                 | 42                       | 4.1                                     |
|          |                        |                                   | 1.0                  | 66                                 | 113                      | 3.4                                     |
| Abut 5   | 15"<br>Concrete Driven | 924.82                            | 0.25                 | 16                                 | 38                       | 4.5                                     |
|          |                        |                                   | 1.0                  | 36                                 | 88                       | 4.4                                     |

**Table 7B Summary of Lateral Pile Capacity Analysis (Fixed Head Condition)**

| Location | Pile Type           | Bottom of Pile Cap Ele. (ft, MSL) | Pile Deflection (in) | Maximum Lateral Shear Force (kips) | Maximum Moment (kips-ft) | Depth to Max. Moment from Pile Cap (ft) |
|----------|---------------------|-----------------------------------|----------------------|------------------------------------|--------------------------|---|
| Abut 1   | 15" Concrete Driven | 929.64                            | 0.25                 | 42                                 | 123                      | 0                                       |
|          |                     |                                   | 1.0                  | 89                                 | 268                      | 0                                       |
| Bent 2   | 15" Concrete Driven | 907.75                            | 0.25                 | 32                                 | 104                      | 0                                       |
|          |                     |                                   | 1.0                  | 49                                 | 176                      | 0                                       |
| Bent 3   | 15" Concrete Driven | 907.75                            | 0.25                 | 32                                 | 104                      | 0                                       |
|          |                     |                                   | 1.0                  | 49                                 | 176                      | 0                                       |
| Bent 4   | 15" Concrete Driven | 907.75                            | 0.25                 | 48                                 | 130                      | 0                                       |
|          |                     |                                   | 1.0                  | 137                                | 337                      | 0                                       |
| Abut 5   | 15" Concrete Driven | 924.82                            | 0.25                 | 36                                 | 113                      | 0                                       |
|          |                     |                                   | 1.0                  | 78                                 | 250                      | 0                                       |

## **7.5 Bridge Approach Embankments**

Based on the general plan and topographic information, the approach embankments beneath the widening between Abutment 1 and Bent 2 and between Bent 4 and Abutment 5 will require up to approximately 12 feet of fill from the existing grade. The embankment slope gradients are planned to match the existing gradients of approximately 1.5H:1V slope in the longitudinal direction (beneath the structure).

### **7.5.1 Approach Fill Requirements**

Areas to receive fill should be cleared of all existing vegetation, debris, and other deleterious materials in accordance with Section 16 of Caltrans Standard Specifications.

Fills placed within bridge approach zone should be compacted to 95 percent relative compaction per latest ASTM D-1557. The limits of bridge approach zone are considered to extend longitudinally 150 feet measured horizontally from the bridge abutment and either parallel or concentric with the roadway centerline, and transversely the full width of embankment except the outer 5 feet measured horizontally from the embankment side slopes.

Earthwork should be performed in accordance with Section 19 of Caltrans Standard Specifications. Abutment backfill will be structural backfill according to Caltrans standard specifications. Expansive soils, defined as soils with Expansion Index (EI) greater than 50 and/or soils with Sand Equivalent (SE) less than 20, should be excluded from the bridge abutments as required by Caltrans guidelines and shown in Figure 8.

### **7.5.2 Settlement and Waiting Period**

Fill-induced settlement is expected and a waiting period is required. The settlement magnitude and the required waiting period are dependent on the new fill type and amount of new fill material placed. Caltrans requires that the remaining total settlement of the bridge approach embankments should not exceed 0.5 inches.

Piles should not be constructed prior to completion of embankment settlement. We estimated that total settlement up to 2 inches may occur within approximately 3 months at the maximum new fill area. Due to presence of existing pile foundation at the site, we

recommend a settlement monitoring program should be performed. Protection or retrofit measures should be taken if excessive settlement occurs at the existing pile foundation locations. Actual settlement and waiting period of embankment fill will be based on monitoring as discussed in Section 8.3 of this report.

## 7.6 Lateral Earth Pressures

For walls backfilled with structure backfill in accordance with Caltrans Standard Specifications, the following lateral earth pressures may be used for design:

| Slope Above<br>the Wall | Active Equivalent<br>Fluid Pressure (pcf) | At-Rest Equivalent<br>Fluid Pressure (pcf) |
|-------------------------|---|--|
| Level                   | 36  | 55   |
| 2H:1V                   | 50  | 70   |

For 2H:1V sloping backfill, the resultant of the fluid pressure may be inclined at 26 degrees to the horizontal. Active pressures may be used for walls able to displace at the top 0.2 percent of the wall height, or ¼ inch for each 10-feet of wall height. Walls unable to displace this amount must be designed for at-rest pressures.

The above values assume that backfill materials are free-draining and, therefore, do not include hydrostatic pressures. Surcharge loading on walls with level backfill may be taken as a uniform lateral pressure equal to 30 percent of the vertical surcharge. For normal roadway traffic, the vertical surcharge can be taken as equivalent to 2-feet of soil, or 240 psf.

Walls designed for static pressures only have generally performed well in past earthquakes. If desired by the designers, the wall design may also consider dynamic earth pressures. If seismic pressures are desired for design, we recommend that the additional lateral pressure during seismic shaking be taken as an equivalent fluid pressure of 20 pcf. If used, the resultant of this force should be applied at 60% of the wall height, and added to the static earth pressures.

According to Caltrans SDC (Caltrans, 2006), when abutments tend to push into the backfill under seismic loading conditions, the abutment structural backfill will provide an ultimate passive resistance of 5.0 ksf multiplied by a height proportionality factor of  $H/5.5$ , where H

is the abutment wall height in feet. The structure designer should follow Caltrans SDC Section 7.8 for seismic response of abutments.

### **7.7 Wingwalls**

No wingwalls are planned at this time.

### **7.8 Wall Drainage**

Our recommendations for the lateral earth pressures assumes that walls have adequate drainage provisions to prevent the buildup of hydrostatic pressures in the soil backfill. The drainage system may be designed in accordance with Caltrans Standard Plan BO-3, Detail 3-1. Pervious backfill material shall consist of gravel, crushed gravel, crushed rock, natural sands, manufactured sand, or combinations thereof. Pervious backfill (other than sacked material at wall drain outlets) shall conform to the grading requirements in Section 19-3.065 of the Caltrans Standard Specifications. Sacked pervious backfill at wall drain outlets shall conform to the grading for 1½" x ¾" primary aggregate size specified in Section 90-3.02 of Caltrans Standard Specifications. As an alternate, geocomposite drain in Bridge Design Details, page 6-22, may be used in lieu of the pervious backfill.

---

## 8.0 CONSTRUCTION CONSIDERATIONS

---

Based on the subsurface soil investigation and laboratory test results, the subsurface conditions are expected to satisfactorily support the proposed structure, provided the geotechnical recommendations presented in this report are implemented.

### 8.1 Site Preparation

Site preparation should be performed in accordance with Section 16 and 19 of Caltrans Standard Specifications.

### 8.2 Earthwork and Backfill

After clearing and stripping, the surface should be excavated to a minimum depth of 2 feet before placement of new fill. Compressible soils shall be removed and replaced with compacted structural backfill in accordance with Caltrans Standard Specifications Section 19-3.06. The exposed surface should be proof-rolled with loaded heavy equipment. Any areas of loose or yielding soils should be overexcavated and recompacted. Any soils that cannot be compacted, or are otherwise unsuitable for the planned use, should be excavated and disposed of from the project site. The exposed surface should then be scarified and compacted to the specified density before placement of new fill. New fill placed on or adjacent to the existing slopes should be properly benched into the existing fill in accordance with Caltrans Standard Specifications Section 19-6.01.

All earthwork should be performed in accordance with Caltrans Standard Specification Section 19 (2006). All materials to be placed as fill should be free of vegetation, organics, debris, and other deleterious materials. All fill placed around foundations and behind walls should be placed in thin loose lifts, moisture-conditioned, and compacted to Caltrans Standard Specification.

Abutment backfill shall be structural backfill according to Caltrans standard specifications. Expansive soils, defined as soils with Expansion Index (EI) greater than 50 and/or soils with Sand Equivalent (SE) less than 20, should be excluded from the bridge abutments as required by Caltrans guidelines and shown in Figure 8. Expansion Index should be

determined in accordance with ASTM D4829. Sand Equivalent should be determined in accordance with California Test Method 217. Fills placed within 150 feet of abutments should be compacted to 95 percent relative compaction per ASTM D-1557.

The specimens selected for consolidation testing (see Appendix B) showed up to about 2% swelling after inundation. Some of the subsurface soils may be expansive. Sufficient tests should be performed to assure that the new fill materials, either derived from the on-site soils or borrowed from off-site, meet the requirements stated in this report.

### **8.3 Settlement Monitoring**

A settlement monitoring program is recommended to evaluate the rate and magnitude of actual settlement in the field for the proposed embankment areas. Surface monuments, constructed in accordance with Caltrans Standard Plan A74 or equivalent, should be installed in a timely manner upon completion of fill placement. Surface monuments should be placed at both abutment locations. The actual location of surface monuments will be determined during grading under the direction of the Geotechnical Engineer.

Settlements should be monitored at the time of installation, every other day for the first week, and every week thereafter till the settlement criteria is satisfied. Pile construction may begin when an extrapolation of the settlement plot shows that the residual (remaining) total settlement of the foundation soil projected over a period of 20 years is less than or equal to ½ inch. All settlement monitoring devices should be protected from damage throughout the construction and monitoring periods.

### **8.4 Temporary Excavations and Shoring**

Any temporary sheeting or shoring should be in accordance with CALOSHA standards and should be made the contractor's responsibility. Appropriate measures should be taken to prevent damage to adjacent utilities and improvements, if any. A shoring design and safety plan should be required from the contractor and submitted to the Engineer for review and approval. Likewise, measures to control impact of both ground and surface water on the stability of temporary excavations should be employed and should remain the sole responsibility of the contractor.

## 8.5 Pile Installation

### 8.5.1 General

Construction of pile foundations should be performed in accordance with Section 49 of the Caltrans Standard Specifications (Caltrans, 2006).

Proper installation of the piles at this site requires careful consideration of several issues and qualified contractors with prior experience in constructing piles of similar size and type, and in similar subsurface conditions.

Installation of the precast concrete driven piles shall be observed by a qualified representative of the Geotechnical Engineer. Hard driving condition should be anticipated in the lower portion of bedrock as discussed in Section 8.5.2.

### 8.5.2 Pile Driving

The specified pile tip elevations for the structure are all controlled by the compression demands on the piles. The specified pile tip elevations are 904 feet for Abutment 1, 879 feet for Bents 2 through 4, and 889 feet for Abutment 5. The pile tip elevations required for the tension demands of the bents are approximately 19 feet higher at elevations of about 897.8 to 898.8 feet. The pile tip elevations required for the lateral loading requirements are approximately 8.5 to 19.8 feet above the specified tip elevations.

*The upper approximately 5 to 12 feet of bedrock materials consists generally of highly weathered siltstone and sandstone. Slightly to moderately weathered formational materials were encountered below the highly weathered materials. Field blow counts (N-values) in the highly weathered materials were comparable to the alluvial soils above the bedrock. Significantly higher blow counts were not encountered until the slightly to moderately weathered formational materials were encountered.*

*The approximate elevation of the highly weathered bedrock encountered in our current explorations ranged from 897 feet at Boring 1 (near Bent 2) to 894 feet at Boring 2 (near Bent 4 and Abut 5). The highly weathered bedrock was up to 12 feet in thickness as encountered in our borings. Slightly to moderately weathered formational materials were encountered at approximate elevation 885 to 887 feet. We anticipate the elevation of the*



*highly weathered bedrock near Abut 1 to be approximately 910 feet.*

*At Abuts 1 and 5, the piles the specified pile tip elevations result in an embedment into bedrock of less than about 5 feet. At Bents 2 through 4 the specified tips (based on the compression demands) are anticipated to be 5 to 8 feet into the slightly to moderately weathered bedrock. To satisfy the tension and lateral demands, the piles at Bents 2 through 4 are anticipated to extend approximately 2 to 5 feet below top of the highly weathered bedrock and not penetrate the slightly to moderately weathered bedrock.*

*In Section 8.5 under Construction Considerations, we stated that 'Hard driving conditions are anticipated in the lower portion of the bedrock'. The lower portion of the bedrock was referring to the slightly to moderately weathered portion of the bedrock below the upper highly weathered bedrock.*

*There is a reasonable potential that the piles could reach nominal compression demands prior to reaching the specified tip elevation because, based on the as built data of the existing bridge, there were substantial variation of pile lengths between Abut. 1 and Abut. 5 and within the same supports. The as-built drawing showed final tip elevations that varied as much as 16 feet difference within the same support (existing bent 2). Existing Bents 3 and 4 had final tip elevations within each support that varied as 13 feet and 10 feet, respectfully. Abut 1 and Abut 5 had final tip elevations within each same support that varied 9.3 feet and 2.5 feet, respectfully. We do not anticipate that nominal compression capacity will be achieved prior to achieving the design tip elevation for lateral or tension demands. If the design tip elevations for lateral or tension demands are achieved and the nominal compression capacity is achieved prior to achieving the specified tip elevation, the concrete pile shall be cut off at the designated elevation in accordance with Section 49 of the standard specifications.*

*A pile driving criteria for the nominal compression demands should be prepared by the contractor and approved by the engineer based on the actual hammer and driving system proposed to be used by the contractor. The pile driving criteria for compression demands along with the design tip elevations for tension and lateral loads should be used by the resident engineer when approving the pile installation.*

## **8.6 Surface Water Control**

Ponding of water adjacent to the structure should be avoided. During and after construction, positive drainage should be provided to direct surface water away from structures and all excavations toward suitable, nonerosive drainage devices.

## **8.7 Geotechnical Observation**

It is recommended that observation and testing be performed by the geotechnical engineer's representative during the following stages of construction:

- Grading operations, including excavations, remedial removals and fill placement
- Monitoring device installation
- Pile installation
- When any unusual conditions are encountered

---


## 9.0 REFERENCES

---

- American Society for Testing Materials (ASTM). Annual Book of Standards. Soil and Rock. Vol. 04.08. 1997.
- California Department of Transportation (Caltrans). Standard Plans, 2006.
- Caltrans California Seismic Hazard Map. 1996.
- Caltrans A Technical Report to Accompany the Caltrans Seismic Hazard Map," Prepared by L. Mualchin. 1996.
- Caltrans Corrosion Guidelines, Version 1.0. September 2003.
- Caltrans Standard Specifications. 2006.
- Caltrans Memo to Designers. Various date depending on sections.
- Caltrans Guidelines for Structures Foundation Reports, March 2006.
- Caltrans Seismic Design Criteria, Version 1.4. June 2006.
- Caltrans Bridge Design Details, 1994.
- Ensoft, Inc., APILE v4.0 User's Manual, 2004.
- Ensoft, Inc., LPILE Plus v5.0 for Windows, Technical Manual, 1985-2006.
- SLIDE Version 5.0. Rocscience, 2005.
- Caltrans, As-built drawings (Including Log of Test Borings), by Caltrans, Approved April 13, 1964.
- Preliminary Foundation Report, Proposed West Side Widening, Reyes Adobe Overcrossing (Bridge No. 53-1726), Agoura Hills, California, by Kleinfelder, Inc., Kleinfelder Project No. 75010, dated August 8, 2006.
- Preliminary Foundation Report, (PRF), Reyes Adobe Overcrossing at US 101, Bridge No. 53-1726, Agoura Hills, California, by Group Delta Consultants (GDC), GDC Project No. 1-430, dated April 2, 2004.
- Sadigh, et al. Attenuation relationships for Shallow Crustal Earthquakes Based on California Strong Motion Data, Seismological Research Letters, Vol. 68, No. 1, pp. 180-189. 1997.
- Seed, H.B. and Whitman, R., Design of Earth Retaining Structures for Dynamic Loads, ASCE Specialty Conference on Lateral Stresses in the Ground and Design of Earth Retaining Structures. 1970.
- State of California Department of Conservation Division of Mines and Geology (CDMG). Fault Rupture Hazard Zones, Special Publication 42. 1997b.
- Tokimatsu, K. and H.B. Seed, Evaluation of Settlements in Sands Due to Earthquake Shaking, Journal of Geotechnical Engineering, Vol. 113, No. 8, pp. 861-878. 1987.



**FIGURES**






SOURCE: U.S.G.S. 7.5' topographic series, Agoura Hills, California  
 quadrangle dated 1950, photorevised 1981.




ATTACHED IMAGES: Images: 75010p1.jpg  
 ATTACHED XREFS:  
 DB-L:\2007\CADD

CAD FILE: L:\2007\CADD\7501010 LAYOUT: Layout2

|   |   |                   |   |
|---|---|-------------------|---|
| <b>KLEINFELDER</b><br><br>6430 Variel Avenue, Suite 103<br>Woodland Hills, CA. 91367<br>PH. (818) 226-6900 FAX. (818) 226-6910<br>www.kleinfelder.com | <b>SITE LOCATION MAP</b>  |                   | DRAWN BY: D. FAHRNEY  |
|   | REYES ADOBE ROAD<br>101 FREEWAY AND REYES ADOBE INTERCHANGE<br>AGOURA HILLS, CALIFORNIA |                   | REVISED BY: D. FAHRNEY  |
| DRAWN: 05/29/07   | APPROVED BY: _____  | PROJECT NO. 70510 | CHECKED BY: J. KEMPTON  |
|   |   |                   | FIGURE<br><br><div style="font-size: 2em; font-weight: bold; text-align: center;">1</div> |
|   |   |                   | FILE NAME: 75010p1.dwg  |



- LEGEND:
- INDICATES LIMITS OF CONCRETE & RAILING REMOVAL
  - INDICATES CLOSURE POUR
  - INDICATES EXISTING STRUCTURE
  - INDICATES NEW STRUCTURE



- NOTES
- ① PAINT "REYES ADOBE RD. OC (Widen)"
  - ② PAINT "BRIDGE NO. 53-1726"
  - ③ PC/PS GIRDER WITH INTERMEDIATE AND END DIAPHRAGMS. TYPICAL FOR SPANS 2 AND 3. SEE "TYPICAL SECTION No. 2" FOR DETAILS
  - ④ CONCRETE BARRIER TYPE 26 MOD
  - ⑤ TEMPORARY RAILING TYPE K. FOR LOCATIONS, SEE "STAGE CONSTRUCTION DETAILS" SHEET AND "ROAD PLANS"
  - ⑥ EXISTING TYPE 1 BARRIER RAILING TO BE REMOVED
  - ⑦ CLOSURE POUR (3'-11")
  - ⑧ CHAIN LINK RAILING TYPE 7 MOD
  - ⑨ STRUCTURE APPROACH SLAB TYPE N (30D)
  - ⑩ STRUCTURE APPROACH SLAB TYPE R (30D)
  - ⑪ FUTURE UTILITY OPENING
  - ⑫ CAST-IN-PLACE CONCRETE RECTANGULAR T-BEAM. TYPICAL FOR SPAN 1 AND 4. SEE "TYPICAL SECTION No. 1" SHEET FOR DETAILS.
  - ⑬ EXISTING RECLAIMED WATERLINE
  - ⑭ EXISTING PACIFIC TELEPHONE AND TELEGRAPH CO. UTILITY
  - ⑮ REMOVE EXISTING BRIDGE MOUNTED SIGN
  - ⑯ BRIDGE MOUNTED SIGN
  - ⑰ SLOPE PAVING (FULL SLOPE)
  - ⑱ METAL BEAM GUARD RAIL, SEE "ROAD PLANS"
  - ⊕ INDICATES POINT OF MINIMUM VERTICAL CLEARANCE
  - \* MATCH EXISTING GRADE

|      |        |       |                          |          |              |
|------|--------|-------|--------------------------|----------|--------------|
| DIST | COUNTY | ROUTE | POST MILES TOTAL PROJECT | SHEET No | TOTAL SHEETS |
| 07   | LA     | 101   | 36.1/36.3                |          |              |

REGISTERED CIVIL ENGINEER DATE \_\_\_\_\_

PLANS APPROVAL DATE \_\_\_\_\_

The State of California or its officers or agents shall not be responsible for the accuracy or completeness of electronic copies of this plan sheet.

CITY OF AGOURA HILLS  
30001 LADYFACE COURT  
AGOURA HILLS, CALIFORNIA 91301

STV INCORPORATED  
1055 WEST 7TH STREET, SUITE 3150  
LOS ANGELES, CALIFORNIA 90017

95% SUBMITTAL

Figure 2

|  |            |                    |                         |                    |  |   |                                       |                        |  |
|--|------------|--------------------|-------------------------|--------------------|--|---|---------------------------------------|------------------------|--|
| Lily Sun<br>DESIGN OVERSIGHT<br>X<br>SIGN OFF DATE | DESIGN     | BY Susan Michalski | CHECKED Wellington Chu  | LOAD FACTOR DESIGN | LIVE LOADING: HS20-44 AND ALTERNATIVE AND PERMIT DESIGN LOAD | PREPARED FOR THE<br>STATE OF CALIFORNIA<br>DEPARTMENT OF TRANSPORTATION | Wellington H. Chu<br>PROJECT ENGINEER | BRIDGE NO.<br>53-1726  | REYES ADOBE ROAD OC (WIDENING)<br>GENERAL PLAN |
|  | DETAILS    | BY Wellington Chu  | CHECKED Susan Michalski | LAYOUT             | BY Susan Michalski   |   |                                       | CHECKED Wellington Chu |  |
|  | QUANTITIES | BY Susan Michalski | CHECKED Wellington Chu  | SPECIFICATIONS     | BY Susan Michalski   | CHECKED Wellington Chu  |                                       |                        |  |

DESIGN GENERAL PLAN SHEET (ENGLISH) (REV. 2/25/05)

ORIGINAL SCALE IN INCHES FOR REDUCED PLANS

CU 07-274  
EA 240201

DISREGARD PRINTS BEARING EARLIER REVISION DATES


REVISION DATES (PRELIMINARY STAGE ONLY)

|          |          |  |  |  |  |
|----------|----------|--|--|--|--|
| 05/01/07 | 09/05/07 |  |  |  |  |
|----------|----------|--|--|--|--|

SHEET 1 OF 25

ATTACHED IMAGES:  
ATTACHED XREFS:  
DB-L:\2007\CADD

CAD FILE: L:\2007\CADD\75010\Reyes\_Adobe\_Civil\_Sheets\_LAYOUT: Layout1



**EXPLANATION**

- HB-3 APPROXIMATE SOIL BORING LOCATION
- B-3 APPROXIMATE HAND AUGER BORING LOCATION
- CROSS-SECTION LOCATION

|              |            |
|--------------|------------|
| DRAWN BY:    | D. FAHRNEY |
| REVISD BY:   | D. FAHRNEY |
| CHECKED BY:  | J. KEMPTON |
| DATE:        | 05/10/07   |
| APPROVED BY: |            |

REYES ADOBE ROAD  
101 FREEWAY AND REYES ADOBE INTERCHANGE  
AGOURA HILLS, CALIFORNIA

PROJECT NO. 75010 FILE NAME: 75010p3.dwg

**PLOT PLAN**


**KLEINFELDER**

6430 Variel Avenue, Suite 103  
Woodland Hills, CA 91367  
PH. (818) 226-6900 FAX. (818) 226-6910  
www.kleinfelder.com

FIGURE  
**3**

PLOTTED: 29 May 2007, 1:34pm, dfahrney

|   |        |       |                          |          |              |
|---|--------|-------|--------------------------|----------|--------------|
| DIST  | COUNTY | ROUTE | POST MILES TOTAL PROJECT | SHEET NO | TOTAL SHEETS |
| 07  | LA     | 101   | 36.1                     |          |              |
| 5/24/07<br>REGISTERED CIVIL ENGINEER DATE   |        |       |                          |          |              |
| PLANS APPROVAL DATE   |        |       |                          |          |              |
| CITY OF AGOURA HILLS<br>30001 LADYFACE COURT<br>AGOURA HILLS, CALIFORNIA 91301  |        |       |                          |          |              |
| KLEINFELDER INC.<br>1370 VALLEY VISTA DRIVE, SUITE 150<br>DIAMOND BAR, CALIFORNIA 91765   |        |       |                          |          |              |
| The State of California or its officers or agents shall not be responsible for the accuracy or completeness of electronic copies of this plan sheet.<br>To get to the Caltrans web site, go to: <a href="http://www.dot.ca.gov">http://www.dot.ca.gov</a> |        |       |                          |          |              |






**NOTES:**

- 1.4 INCH DIAMETER SAMPLES WERE TAKEN USING A STANDARD PENETRATION TEST (SPT) SPLIT BARREL SAMPLER WITH AN INSIDE DIAMETER (ID) OF 1.4 INCH AND AN OUTSIDE DIAMETER (OD) OF 2 INCH.
- 2.4 INCH DIAMETER RING SAMPLES WERE TAKEN USING A CALIFORNIA (MODIFIED) SPLIT BARREL SAMPLER WITH AN ID OF 2.4 INCH AND AN OD OF 3.27 INCH.
- AN ABOVE-HOLE AUTOMATIC HAMMER SYSTEM WAS USED TO ADVANCE THE DRIVE SAMPLERS. (140 LB HAMMER, 30-INCH DROP)

**BENCHMARK:**

LA County BM ID#11278 Col-Trans Disc in SE Corner Bridge over 101 Freeway 24 inches E/O CF 23 feet E/O Reyes Adobe MKD (101-005 1994) Elev. 939.056



**NOTES:**

**SOIL TEST DESIGNATIONS**

- ① WATER CONTENT
- ② LIQUID LIMIT
- ③ PLASTICITY INDEX
- ④ SHrinkage
- ⑤ UNIFORMITY COEFFICIENT
- ⑥ COEFFICIENT OF CURVATURE
- ⑦ SAND EQUIVALENT
- ⑧ UNCONF. COMPRESS. INDEX
- ⑨ UNCONF. EXPANSION INDEX
- ⑩ TRIAXIAL
- ⑪ DIRECT SHEAR
- ⑫ EXPANSION INDEX

**LEGEND OF EARTH MATERIALS**

- GRAVEL
- SAND
- SILT
- CLAYEY CLAY
- CLAYEY SAND
- SILTY SAND
- SILTY CLAY
- CLAYEY SILT
- CLAYEY SILT
- SHALE

**CONSISTENCY CLASSIFICATION FOR SOILS**

| SPT (Blows/foot) | Consistency  |
|------------------|--------------|
| 0-4              | Very Loose   |
| 5-10             | Loose        |
| 11-20            | Medium Dense |
| 21-30            | Dense        |
| 31-50            | Very Dense   |
| 50               | Hard         |


PRELIMINARY - NOT FOR CONSTRUCTION, SUBJECT TO INDEPENDENT VERIFICATION PRIOR TO FINAL DESIGN

|                  |              |            |                               |  |                     |           |                                |
|------------------|--------------|------------|-------------------------------|--|---------------------|-----------|--------------------------------|
| DESIGN OVERSIGHT | DRAWN BY     | D. FAHRNEY | M. JANOUSEK<br>STAFF ENGINEER | PREPARED FOR THE<br><b>STATE OF CALIFORNIA</b><br>DEPARTMENT OF TRANSPORTATION | BRIDGE NO.          | 53-X726   | REYES ADOBE ROAD OC (WIDENING) |
|                  | DESIGN CHECK | CHECKED BY | J. KEMPTON                    |  | PROJECT ENGINEER    | POST MILE |                                |
| DATE             | DATE         | 01/03/07   | DATE                          | 01/03/07   | LOG OF TEST BORINGS |           |                                |



ATTACHED IMAGES:  
 ATTACHED XREFS:  
 DB-L:2007\CADD

CAD FILE: L:\2007\CADD\75010\Reyes\_Adobe\_Civil\_Sheets\ LAYOUT: SECTION



| LAYER NO. | MATERIAL NAME              |
|-----------|----------------------------|
| 1         | NEW FILL                   |
| 2         | OLD FILL                   |
| 3         | ALLUVIUM (CL)              |
| 4         | ALLUVIUM (SM/SC)           |
| 5         | BEDROCK (HIGHLY WEATHERED) |
| 6         | BEDROCK                    |

DRAWN BY: D. FAHRNEY  
 REVISED BY: D. FAHRNEY  
 CHECKED BY: J. KEMPTON  
 DATE: 05/10/07

**CROSS-SECTION A-A'**  
 REYES ADOBE ROAD  
 101 FREEWAY AND REYES ADOBE INTERCHANGE  
 AGOURA HILLS, CALIFORNIA  
 PROJECT NO. 75010 FILE NAME: 75010p3.dwg

**KLEINFELDER**  
 6430 Variel Avenue, Suite 103  
 Woodland Hills, CA 91367  
 PH. (818) 226-6900 FAX. (818) 226-6910  
 www.kleinfelder.com

FIGURE **5**

PLOTTED: 29 May 2007, 3:31pm, dfahrney

# CALTRANS BRIDGE DESIGN ARS CURVE

ARS v3.0, 2001-2006, Spreadsheet revised by: EZ)

| PROJECT INFORMATION  |   |
|--|---|
| Project Name   | Reyes Adobe Rd OC                           |
| Project No.  |   |
| Location   | Los Angeles County, California              |
| INPUT PARAMETERS   |   |
| Controlling Fault Name   | Malibu Coast-Santa Monica-Hollywood-Raymond |
| Fault Type   | Reverse/Thrust                              |
| MCE Moment Magnitude   | 7.50  |
| Distance to Fault  | 11.00 km                                    |
| Peak Bedrock Acceleration Based on 1996 Seismic Hazard Map           | 0.5 g                                       |
| Soil Profile Type  | D   |
| COMPUTED RESULTS   |   |
| Peak Bedrock Acceleration Based on Sadigh et al. (1997) <sup>1</sup> | 0.49 g                                      |
| Design Peak Bedrock Acceleration (g)                                 | 0.5 g                                       |

| COMPUTED ARS CURVES |  |   |
|---------------------|--|---|
| Period T (sec)      | Standard SDC ARS Curve <sup>2</sup> Sa (g) | Recommended ARS Curve <sup>3</sup> Sa (g) |
| 0.02                | 0.500                                      | 0.500                                     |
| 0.04                | 0.500                                      | 0.500                                     |
| 0.06                | 0.587                                      | 0.587                                     |
| 0.08                | 0.759                                      | 0.759                                     |
| 0.10                | 0.917                                      | 0.917                                     |
| 0.15                | 1.154                                      | 1.154                                     |
| 0.20                | 1.259                                      | 1.259                                     |
| 0.25                | 1.265                                      | 1.265                                     |
| 0.30                | 1.247                                      | 1.247                                     |
| 0.35                | 1.219                                      | 1.219                                     |
| 0.40                | 1.191                                      | 1.191                                     |
| 0.45                | 1.158                                      | 1.158                                     |
| 0.50                | 1.126                                      | 1.126                                     |
| 0.60                | 1.058                                      | 1.100                                     |
| 0.70                | 0.986                                      | 1.065                                     |
| 0.80                | 0.907                                      | 1.016                                     |
| 0.90                | 0.840                                      | 0.974                                     |
| 1.00                | 0.776                                      | 0.931                                     |
| 1.10                | 0.711                                      | 0.853                                     |
| 1.20                | 0.642                                      | 0.770                                     |
| 1.30                | 0.585                                      | 0.702                                     |
| 1.40                | 0.533                                      | 0.640                                     |
| 1.50                | 0.485                                      | 0.582                                     |
| 1.60                | 0.446                                      | 0.535                                     |
| 1.70                | 0.408                                      | 0.490                                     |
| 1.80                | 0.378                                      | 0.454                                     |
| 1.90                | 0.347                                      | 0.416                                     |
| 2.00                | 0.322                                      | 0.386                                     |
| 2.10                | 0.300                                      | 0.360                                     |
| 2.20                | 0.282                                      | 0.338                                     |
| 2.30                | 0.264                                      | 0.317                                     |
| 2.40                | 0.247                                      | 0.296                                     |
| 2.50                | 0.229                                      | 0.275                                     |
| 2.60                | 0.216                                      | 0.259                                     |
| 2.70                | 0.205                                      | 0.246                                     |
| 2.80                | 0.193                                      | 0.232                                     |
| 2.90                | 0.182                                      | 0.218                                     |
| 3.00                | 0.171                                      | 0.205                                     |
| 3.10                | 0.162                                      | 0.194                                     |
| 3.20                | 0.155                                      | 0.186                                     |
| 3.30                | 0.147                                      | 0.176                                     |
| 3.40                | 0.140                                      | 0.168                                     |
| 3.50                | 0.133                                      | 0.160                                     |
| 3.60                | 0.128                                      | 0.154                                     |
| 3.70                | 0.122                                      | 0.146                                     |
| 3.80                | 0.117                                      | 0.140                                     |
| 3.90                | 0.112                                      | 0.134                                     |
| 4.00                | 0.106                                      | 0.127                                     |

**NOTES:**

- <sup>1</sup>Peak Bedrock Acceleration (PBA):  
Determined using attenuation relationship by Sadigh et al. (1997) for rock site. Sadigh recommended no increase for Strike-Slip Fault, 10% increase for Oblique Fault; and 20% increase for Reverse/Thrust Fault.
- <sup>2</sup>Standard SDC ARS Curve:  
Based on Caltrans Standard SDC (2004) ARS Curve for the given Magnitude, Peak Bedrock Acceleration, and Soil Profile Type.
- <sup>3</sup>recommended ARS Curve:  
When the bridge is located within 15 km of the controlling fault, the standard SDC ARS Curve was modified as follows to account for fault rupture directivity effect:  
  - For Periods < 0.5 sec, no increase in Standard SDC spectral acceleration values.
  - For Periods > 1.0 sec, Standard SDC spectral acceleration values were increased by 20%.
  - For Periods between 0.5 sec and 1.0 sec, spectral acceleration values were linearly interpolated.




Figure 6

**PILE DATA TABLE**

| Location | Pile Type           | Design Loading (kips) | Nominal Resistance |                | Design Tip Elevation (ft) | Specified Tip Elevation (ft) |
|----------|---------------------|-----------------------|--------------------|----------------|---------------------------|------------------------------|
|          |                     |                       | Compression (kips) | Tension (kips) |                           |                              |
| Abut 1   | 15" Concrete Driven | 90                    | 180                | -              | 904.1(1)<br>912.6(3)      | 904.0                        |
| Bent 2   | 15" Concrete Driven | 90                    | 180                | -              | 879.0(1)<br>892.2(3)      | 879.0                        |
| Bent 3   | 15" Concrete Driven | 90                    | 180                | -              | 879.0(1)<br>892.2(3)      | 879.0                        |
| Bent 4   | 15" Concrete Driven | 90                    | 180                | -              | 879.0(1)<br>892.2(3)      | 879.0                        |
| Abut 5   | 15" Concrete Driven | 90                    | 180                | -              | 889.0(1)<br>908.8(3)      | 889.0                        |

Note: Design tip elevation is controlled by the following demands:  
(1) Compression, (2) Tension, (3) Lateral Loads.

**BENCHMARK**

LA County BM ID#11278 Cal-Trans Disc in SE Corner Bridge over 101 Freeway 24 inches E/O CF 23 feet E/O Reyes Adobe MKD (101-005 1994) Elev. 939.056

**LEGEND**

- XXX.XXX Indicates bottom of footing elevation
- XXX.XXX Indicates existing bottom of footing elevation
- Indicates existing structure
- Indicates new construction
- Indicates existing piling
- Indicates new piling

|      |        |       |                          |          |       |
|------|--------|-------|--------------------------|----------|-------|
| DIST | COUNTY | ROUTE | POST MILES TOTAL PROJECT | SHEET No | TOTAL |
| 07   | LA     | 101   | 36.1/36.3                |          |       |


REGISTERED CIVIL ENGINEER DATE \_\_\_\_\_

PLANS APPROVAL DATE \_\_\_\_\_

The State of California or its officers or agents shall not be responsible for the accuracy or completeness of electronic copies of this plan sheet.

CITY OF AGOURA HILLS  
30001 LADYFACE COURT  
AGOURA HILLS, CALIFORNIA 91301

STV INCORPORATED  
1055 WEST 7TH STREET, SUITE 3150  
LOS ANGELES, CALIFORNIA 90017



GEOTECHNICAL PROFESSIONAL APPROVAL DATE

TIME PLOTTED => \$TIME  
DATE PLOTTED => \$DATE  
USERNAME => \$USER

|                              |                               |                           |                               |                           |                                       |                     |   |
|------------------------------|-------------------------------|---------------------------|-------------------------------|---------------------------|---------------------------------------|---------------------|---|
| Lily Sun<br>DESIGN OVERSIGHT | SCALE: 1" = 10'               | VERT. DATUM NAVD 88       | HORZ. DATUM NAD 83            | DESIGN BY Susan Michalski | CHECKED Wellington Chu                | BRIDGE NO. 53-1726  | REYES ADOBE ROAD OC (WIDENING)<br>FOUNDATION PLAN |
| X<br>SIGN OFF DATE           | PHOTOGRAMMETRY AS OF: 8-11-06 | ALIGNMENT TIES            | DETAILS BY Wellington Chu     | CHECKED Susan Michalski   | Wellington H. Chu<br>PROJECT ENGINEER | POST MILE 36.1/36.3 |   |
|                              | SURVEYED BY Clinton Anderson  | DRAFTED BY Diano Knezevic | QUANTITIES BY Susan Michalski | CHECKED Wellington Chu    | DEPARTMENT OF TRANSPORTATION          |                     |   |

FOUNDATION PLAN SHEET (ENGLISH) (REV. 2-25-05)

ORIGINAL SCALE IN INCHES FOR REDUCED PLANS

CU 07-274  
EA 240201


DISREGARD PRINTS BEARING EARLIER REVISION DATES

| REVISION DATES (PRELIMINARY STAGE ONLY) | SHEET | OF |
|---|-------|----|
| 05/07/01 09/05/07                       | 4     | 25 |

FILE => \$REQUEST

ATTACHED IMAGES: Images: gdc20.bmp  
 ATTACHED XREFS:  
 DB-L:2007\CADD

CAD FILE: L:\2007\CADD\75010\ LAYOUT: Layout1



| H      | d    |
|--------|------|
| <16 ft | 4 ft |
| >16 ft | 0    |

\*EXPANSION INDEX TO BE DETERMINED BY ASTM 4829

FIGURE

**8**

**KLEINFELDER**

6430 Variel Avenue, Suite 103  
 Woodland Hills, CA 91367  
 PH. (818) 226-6900 FAX. (818) 226-6910  
 www.kleinfelder.com

**EXPANSIVE SOIL EXCLUSION ZONE**

REYES ADOBE ROAD  
 101 FREEWAY AND REYES ADOBE INTERCHANGE  
 AGOURA HILLS, CALIFORNIA

PROJECT NO. 75010 FILE NAME: 75010p8.dwg

DRAWN BY: D. FAHRNEY  
 REVISED BY: D. FAHRNEY  
 CHECKED BY: J. KEMPTON  
 DATE: 05/10/07  
 APPROVED BY:



**APPENDIX A**  
**FIELD EXPLORATION**

---

## APPENDIX A FIELD EXPLORATION

---

The subsurface exploration program for the proposed bridge consisted of drilling and logging a total of 3 hollow-stem auger borings and 3 hand-auger borings. The hollow-stem borings were drilled with a CME-75, truck-mounted drill rig furnished by Jet Drilling of Signal Hill, California. Borings B-1 to B-3 were advanced to depths ranging from approximately 31 feet to 46.5 feet below existing grade on January 3, 2007. The borings were drilled through asphalt; rapid-set concrete was used to patch the holes. Borings HB-1 to HB-3 were advanced to depths ranging from approximately 1.5 to 3 feet below existing grade on January 4, 2007. All borings were backfilled with the soil cuttings when the drilling and excavating was completed. The approximate locations of the borings are shown on Plate 2.

The Logs of Borings are presented as Figures A-2 through A-7. An explanation to the logs is presented as Figure A-1. The Logs of Borings describe the earth materials encountered, samples obtained, and show field and laboratory tests performed. The logs also show the boring number, drilling date and the name of the logger and drilling subcontractor. The borings were logged by a Kleinfelder staff engineer using the Unified Soil Classification System. The boundaries between soil types shown on the logs are approximate because the transition between different soil layers may be gradual. Bulk and intact samples of representative earth materials were obtained from the borings.

A Modified California Sampler was used to obtain relatively undisturbed samples of the soil encountered. This sampler consists of a 3-inch O.D., 2.4-inch I.D. split barrel shaft that is driven a total of 18-inches into the soil at the bottom of the boring. The soil was retained in one inch brass rings for laboratory testing. An additional two inches of soil from each drive remained in the cutting shoe and was usually discarded after visually classifying the soil. The number of blows required to drive the sampler the final 12 inches is presented on the boring logs. The California sampler was driven by a 140-pound hammer with a drop height of 30 inches.

Disturbed samples were obtained using a Standard Penetration Sampler (SPT). This sampler consists of a 2-inch O.D., 1.4-inch I.D. split barrel shaft that is advanced into the soils at the bottom of the drill hole a total of 18-inches. The number of blows required to drive the sampler for final 12 inches is presented on the Logs of Borings. The SPT sampler was driven by a 140-pound hammer with a drop height of 30 inches. Soil samples obtained by the SPT were stored in plastic ziplock bags. Bulk samples of the sub-surface soils were retrieved directly from the soil cuttings.

Date Drilled:  
 Drilled By:  
 Drilling Method:  
 Logged By:

Water Depth:  
 Date Measured:  
 Reference Elevation:  
 Datum:

| Elevation (feet) Depth | Sample | Sample No. | Blow Count (Blows/ft.) | Graphic Log | GEOTECHNICAL DESCRIPTION AND CLASSIFICATION | Dry Density (pcf) | Moisture Content (%) | Additional Tests |
|------------------------|--------|------------|------------------------|-------------|---|-------------------|----------------------|------------------|
| 0                      |        | 1          | 6                      |             |   | 108               | 10                   | DS, SE           |
| 5                      |        | 2          | 12                     |             |   |                   |                      | GS               |
|                        | (1)    | (2)        | (3)                    | (4)         | (5)   | (6)               | (6)                  | (7)              |

NOTES ON FIELD INVESTIGATION

- SAMPLE** - Graphical representation of sample type as shown below.

  - Split Spoon - Standard Penetration Test Sample (SPT)
  - Drive Sample - California Sample (Col)
  - Bulk Sample - Obtained by collecting cuttings in a plastic bag
  - Tube Sample - Shelby/Pitcher Tube Sample
- SAMPLE NO.** - Sample Number
- BLOWS/FT** - Number of blows required to advance sampler 1 foot (unless a lesser distance is specified). Samplers in general were driven into the soil at the bottom of the hole with a standard (140 lb) hammer dropping a standard 30 inches. Drive samples collected in bucket auger borings may be obtained by dropping non-standard weight from variable heights. When a SPT sampler is used the blow count conforms to ASTM D-1586.

SCR/ROD - Sample Core Recovery (SCR) in percent (%) and Rock Quality Designation (ROD) in percent (%). ROD is defined as the percentage of core in each run which the spacing between natural fractures is greater than 4 inches. Mechanical breaks of the core are not considered.
- GRAPHIC LOG** - Standard symbols for soil and rock types, as shown on plate B-1b.
- GEOTECHNICAL DESCRIPTION**

Soil - Soil classifications are based on the Unified Soil Classification System per ASTM D-2487, and designations include consistency, moisture, color and other modifiers. Field descriptions have been modified to reflect results of laboratory analyses where deemed appropriate.

Rock - Rock classifications generally include a rock type, color, moisture, mineral constituents, degree of weathering, alteration, and the mechanical properties of the rock. Fabric, lineations, bedding spacing, foliations, and degree of cementation are also presented where appropriate.

Description of soil origin or rock formation is placed in brackets at the beginning of the description where applicable, for example, Residual Soil.
- DRY DENSITY, MOISTURE CONTENT:** As estimated by laboratory or field testing.
- ADDITIONAL TESTS** - (Indicates sample tested for properties other than the above):

|  |                                       |                             |
|--|---------------------------------------|-----------------------------|
| MAX - Maximum Dry Density                            | SG - Specific Gravity                 | PP - Pocket Penetrometer    |
| GS - Grain Size Distribution                         | HA - Hydrometer Analysis              | WA - Wash Analysis          |
| SE - Sand Equivalent                                 | AL - Atterberg Limits                 | DS - Direct Shear           |
| EI - Expansion Index                                 | RV - R-Value                          | CP - Collapse Potential     |
| CHEM - Sulfate and Chloride Content, pH, Resistivity | CN - Consolidation                    | UC - Unconfined Compression |
| PM - Permeability                                    | CU - Consolidation Undrained Triaxial | T - Torvane                 |
| UU - Unconsolidated Undrained Triaxial               | CD - Consolidated Drained Triaxial    |                             |
- ATTITUDES** - Orientation of rock discontinuity observed in bucket auger boring or rock core, expressed in strike/dip and dip angle, respectively, preceded by a one-letter symbol denoting nature of discontinuity as shown below.

B: Bedding Plane      J: Jointing      C: Contact      F: Fault      S: Shear























EXPLANATION OF LOGS

PLATE  
 A-1a



## UNIFIED SOIL CLASSIFICATION SYSTEM (ASTM D-2487)

| PRIMARY DIVISIONS  |   |  | GROUP SYMBOLS   |   | SECONDARY DIVISIONS   |   |
|--|---|--|---|---|---|---|
| COARSE-GRAINED SOILS<br>MORE THAN HALF OF MATERIALS IS LARGER THAN #200 SIEVE SIZE | GRAVELS MORE THAN HALF OF COARSE FRACTION IS LARGER THAN #4 SIEVE | CLEAN GRAVELS (LESS THAN 5% FINES)                               | GW  |                  | WELL GRADED GRAVELS, GRAVEL-SAND MIXTURES, LITTLE OR NO FINES                     |   |
|  |   | GRAVEL WITH FINES  | GP  |                  | POORLY GRADED GRAVELS OR GRAVEL-SAND MIXTURES, LITTLE OR NO FINES                 |   |
|  |   | SANDS MORE THAN HALF OF COARSE FRACTION IS SMALLER THAN #4 SIEVE | CLEAN SANDS (LESS THAN 5% FINES)  | GM  |  | SILTY GRAVELS, GRAVEL-SAND-SILT MIXTURES  |
|  |   |  | SANDS WITH FINES  | GC  |  | CLAYEY GRAVELS, GRAVEL-SAND-CLAY MIXTURES |
|  | SANDS AND SILTS AND CLAYS<br>LIQUID LIMIT IS LESS THAN 50         | CLEAN SANDS (LESS THAN 5% FINES)                                 | SW  |                  | WELL GRADED SANDS, GRAVELLY SANDS, LITTLE OR NO FINES                             |   |
|  |   |  | SP  |                  | POORLY GRADED SANDS OR GRAVELLY SANDS, LITTLE OR NO FINES                         |   |
|  |   | SANDS WITH FINES   | SM  |                  | SILTY SANDS, SAND-SILT MIXTURES   |   |
|  |   |  | SC  |                  | CLAYEY SANDS, SAND-CLAY MIXTURES  |   |
| FINE-GRAINED SOILS<br>MORE THAN HALF OF MATERIALS IS SMALLER THAN #200 SIEVE SIZE  | SILTS AND CLAYS<br>LIQUID LIMIT IS LESS THAN 50                   | ML   |  | INORGANIC SILTS, VERY FINE SANDS, ROCK FLOUR, SILTY OR CLAYEY FINE SANDS                          |   |   |
|  |   | CL   |  | INORGANIC CLAYS OF LOW TO MEDIUM PLASTICITY, GRAVELLY CLAYS, SANDY CLAYS, SILTY CLAYS, LEAN CLAYS |   |   |
|  |   | OL   |  | ORGANIC SILTS AND ORGANIC SILT-CLAYS OF LOW PLASTICITY  |   |   |
|  | SILTS AND CLAYS<br>LIQUID LIMIT IS GREATER THAN 50                | MH   |  | INORGANIC SILTS, MICACEOUS OR DIATOMACEOUS FINE SANDS OR SILTS, ELASTIC SILTS                     |   |   |
|  |   | CH   |  | INORGANIC CLAYS OF HIGH PLASTICITY, FAT CLAYS   |   |   |
|  |   | OH   |  | ORGANIC CLAYS OF MEDIUM TO HIGH PLASTICITY, ORGANIC SILTS   |   |   |
|  | HIGHLY ORGANIC SOILS  |  | PT  |                  | PEAT, MUÇ AND OTHER HIGHLY ORGANIC SOILS  |   |
| TYPICAL FORMATIONAL MATERIALS  | SANDSTONES  |  | SS  |                 |   |   |
|  | SILTSTONES  |  | SH  |                |   |   |
|  | CLAYSTONES  |  | CS  |                |   |   |
|  | LIMESTONES  |  | LS  |                |   |   |
|  | SHALE   |  | SL  |                |   |   |

### CONSISTENCY CRITERIA BASED ON FIELD TESTS

| RELATIVE DENSITY: COARSE-GRAINED SOIL |                    |                      | CONSISTENCY: FINE-GRAINED SOIL |                  | TORVANE                        | POCKET ** PENETROMETER                |
|---------------------------------------|--------------------|----------------------|--------------------------------|------------------|--------------------------------|---------------------------------------|
| RELATIVE DENSITY                      | SPT * (# blows/ft) | RELATIVE DENSITY (%) | CONSISTENCY                    | SPT (# blows/ft) | UNDRAINED SHEAR STRENGTH (tsf) | UNCONFINED COMPRESSIVE STRENGTH (tsf) |
| Very Loose                            | <4                 | 0 - 15               | Very Soft                      | <2               | <0.13                          | <0.25                                 |
| Loose                                 | 4 - 10             | 15 - 35              | Soft                           | 2 - 4            | 0.13 - 0.25                    | 0.25 - 0.5                            |
| Medium Dense                          | 10 - 30            | 35 - 65              | Medium Stiff                   | 4 - 8            | 0.25 - 0.5                     | 0.5 - 1.0                             |
| Dense                                 | 30 - 50            | 65 - 85              | Stiff                          | 8 - 15           | 0.5 - 1.0                      | 1.0 - 2.0                             |
| Very Dense                            | >50                | 85 - 100             | Very Stiff                     | 15 - 30          | 1.0 - 2.0                      | 2.0 - 4.0                             |
|                                       |                    |                      | Hard                           | >30              | >2.0                           | >4.0                                  |

\* NUMBER OF BLOWS OF 140 POUND HAMMER FALLING 30 INCHES TO DRIVE A 2 INCH O.D. (1 3/8 INCH I.D.) SPLIT BARREL SAMPLER (ASTM-1586 STANDARD PENETRATION TEST)

\*\* UNCONFINED COMPRESSIVE STRENGTH IN TONS/SQ.FT. READ FROM POCKET PENETROMETER

#### MOISTURE CONTENT

| DESCRIPTION | FIELD TEST  |
|-------------|---|
| Dry         | Absence of moisture, dusty, dry to the touch          |
| Moist       | Damp but no visible water                             |
| Wet         | Visible free water, usually soil is below water table |

#### CEMENTATION

| DESCRIPTION | FIELD TEST   |
|-------------|--|
| Weakly      | Crumbles or breaks with handling or slight finger pressure |
| Moderately  | Crumbles or breaks with considerable finger pressure       |
| Strongly    | Will not crumble or break with finger pressure             |



**KLEINFELDER**

**EXPLANATION OF LOGS**

PLATE  
**A-1b**

Date Drilled: 1/3/07 Water Depth: >36.5 feet  
 Drilled By: Jet Drilling Date Measured: 1/3/2007  
 Drilling Method: 8" Hollow Stem Auger Elevation: 916 feet (approx.)  
 Logged By: M. Janousek Datum: MSL

| Elevation (feet) | Depth | Sample Type | Sample Number | Blows per Foot | Graphic Log | SOIL DESCRIPTION AND CLASSIFICATION   | Dry Density (pcf) | Moisture Content (%) | Additional Tests |
|------------------|-------|-------------|---------------|----------------|-------------|---|-------------------|----------------------|------------------|
| 915              |       |             | 1             |                |             | <b>Asphalt Concrete:</b> approximately 8 inches thick.  |                   |                      |                  |
|                  |       |             | 2             |                |             | <b>Aggregate Base:</b> approximately 10 inches thick.   |                   |                      | Analytical       |
|                  |       |             | 3             |                |             | <b>Artificial Fill (Af):</b>  |                   |                      | Analytical       |
|                  |       |             | 4             |                |             | <b>Silty Sand (SM):</b> yellow, moist, fine to coarse grained, trace clay.  |                   |                      | Analytical       |
|                  |       |             |               |                |             | <b>Silty Clay (CL):</b> brown, moist, with fine to medium sand.   |                   |                      |                  |
|                  |       |             | 5             |                |             | -- some fine to coarse sand.  |                   |                      |                  |
| 910              |       |             | 6             | 17             |             | <b>Alluvium (Oa):</b>   | 116               | 13.7                 | Analytical<br>AL |
|                  |       |             |               |                |             | <b>Sandy Clay (CL):</b> brown, moist, stiff, fine to coarse sand.   |                   |                      |                  |
|                  |       |             |               |                |             | -- very stiff, increase fine to coarse sand.  |                   |                      |                  |
| 905              |       |             | 7             | 32             |             |   | 109               | 18.2                 | GS, CN           |
|                  |       |             |               |                |             | <b>Silty Sand (SM):</b> olive brown, moist, dense, fine to coarse grained, with fine gravel, some silt, trace clay.   |                   |                      |                  |
|                  |       |             |               |                |             | -- (18% passing No. 200 Sieve)  |                   |                      |                  |
|                  |       |             |               |                |             | -- decrease gravel.   |                   |                      |                  |
| 900              |       |             | 8             | 30             |             |   |                   |                      | WA               |
|                  |       |             |               |                |             | <b>Bedrock:</b>   |                   |                      |                  |
|                  |       |             |               |                |             | <b>Upper Topanga Formation (Ttuc):</b> claystone and siltstone, mottled orange and gray, very stiff, thin-bedded, includes few thin sandstone strata, highly weathered. |                   |                      |                  |
|                  |       |             |               |                |             | -- increase siltstone.  |                   |                      |                  |
| 895              |       |             | 9             | 32             |             |   |                   |                      |                  |
|                  |       |             |               |                |             | -- gray, hard, moderately weathered.  |                   |                      |                  |
| 890              |       |             | 10            | 17             |             |   |                   |                      |                  |
|                  |       |             |               |                |             |   |                   |                      |                  |
| 885              |       |             | 11            | 39             |             |   | 97                | 25.9                 | DS               |

GEOTECH DB 75010-2 REYES ADOBE INTERCHANGE UPDATED 5-07.GPJ KA\_RDLND.GDT\_5/29/07



Proposed West Side Widening  
 Reyes Adobe Road OC  
 Agoura Hills, CA

PLATE

A-2a



PROJECT NO. 75010-2

LOG OF BORING B-1

Drafted By: Reviewed By:

Note: The boundaries between soil types shown on the logs are approximate as the transition between different soil layers may be gradual.

GEOTECH DB 75010-2 REYES ADOBE INTERCHANGE UPDATED 5-07-GPJ, KA, RD.LND.GDT, 5/29/07

| Elevation<br>(feet)<br>Depth   | Sample Type<br>Sample Number | Blows per Foot | Graphic Log   | SOIL DESCRIPTION<br>AND<br>CLASSIFICATION<br><i>(Continued From Previous Page)</i>  | Dry Density<br>(pcf) | Moisture<br>Content (%) | Additional<br>Tests |
|--|------------------------------|----------------|---|---|----------------------|-------------------------|---------------------|
| 880  | 12                           | 39             |  | <p>Total Depth: 36.5 feet.<br/>           Groundwater not encountered.<br/>           Boring backfilled with soil cuttings and capped with Quickset Cement.</p> |                      |                         |                     |
|  <b>KLEINFELDER</b> |                              |                |   | <b>Proposed West Side Widening</b><br><b>Reyes Adobe Road OC</b><br><b>Agoura Hills, CA</b>   |                      |                         | <b>PLATE</b>        |
| <b>PROJECT NO. 75010-2</b>   |                              |                |   | <b>LOG OF BORING B-1</b>  |                      |                         | <b>A-2b</b>         |

Note: The boundaries between soil types shown on the logs are approximate as the transition between different soil layers may be gradual.

Date Drilled: 1/3/07      Water Depth: 19 feet  
 Drilled By: Jet Drilling      Date Measured: 1/3/2007  
 Drilling Method: 8" Hollow Stem Auger      Elevation: 916 feet (approx.)  
 Logged By: M. Janousek      Datum: MSL

| Elevation (feet) | Depth | Sample Type | Sample Number | Blows per Foot | Graphic Log   | SOIL DESCRIPTION AND CLASSIFICATION   | Dry Density (pcf) | Moisture Content (%) | Additional Tests                                     |   |     |      |    |    |
|------------------|-------|-------------|---------------|----------------|---|---|-------------------|----------------------|--|---|-----|------|----|----|
|                  |       |             |               |                |   |   |                   |                      |  |   |     |      |    |    |
| 915              |       |             | 1             |                |   | <b>Artificial Fill (Af):</b><br>Sandy Clay (CL): yellow brown, moist, with fine to medium sand.<br>-- some fine to coarse gravel. | 97                | 20.1                 | Analytical<br>Analytical<br>Analytical<br>Analytical |   |     |      |    |    |
|                  |       |             | 2             |                |   |   |                   |                      |  |   |     |      |    |    |
|                  |       |             | 3             |                |   |   |                   |                      |  |   |     |      |    |    |
|                  |       |             | 4             |                |   |   |                   |                      |  |   |     |      |    |    |
|                  |       |             | 5             |                |   |   |                   |                      |  |   |     |      |    |    |
| 910              |       |             | 6             | 20             |   |   |                   |                      |  |   |     |      |    |    |
|                  |       |             | 7             | 10             |   |   |                   |                      |  |   |     |      |    |    |
| 905              |       |             | 8             | 32             |   |   |                   |                      |  | <b>Alluvium (Oa):</b><br>Sandy Clay (CL): brown, moist, stiff, with fine to medium sand, trace fine gravel.<br><br>-- very stiff, fine to coarse sand, increase fine gravel.  | 104 | 16.9 | DS |    |
|                  |       |             | 9             | 69             |   |   |                   |                      |  | <b>Silty Sand (SM):</b> brown, wet, very dense, fine to coarse grained, with fine gravel, trace clay, some cobbles up to 5 inches diameter.<br><br>-- (13% passing No. 200 Sieve)   |     |      |    |    |
|                  |       |             | 10            | N/A            |   |   |                   |                      |  | <b>Bedrock:</b><br>Upper Topanga Formation (Ttuc): claystone and siltstone, mottled orange and gray, very stiff, thin-bedded, includes few thin sandstone strata, highly weathered.<br>(Cobble from silty sand layer lodged in auger tip @ 22 feet. Therefore, no samples obtained from 25 and 30 feet depths. Classification performed by visual observation of cuttings obtained directly from augers.) |     |      |    | AL |
| 895              |       |             | 11            | N/A            |   |   |                   |                      |  |   |     |      |    |    |
|                  |       |             |               |                | Practical refusal @ 31 feet.<br>Groundwater encountered @ 19 feet.<br>Boring backfilled with soil cuttings and capped with Quickset Cement. |   |                   |                      |  |   |     |      |    |    |

GEOTECH DB 75010-2 REYES ADOBE INTERCHANGE UPDATED 5-07.GPJ KA RDLND.GDT 5/29/07



Proposed West Side Widening  
 Reyes Adobe Road OC  
 Agoura Hills, CA

PLATE

A-3

PROJECT NO. 75010-2

LOG OF BORING B-2

Drafted By:      Reviewed By:

Note: The boundaries between soil types shown on the logs are approximate as the transition between different soil layers may be gradual.

Date Drilled: 1/3/07      Water Depth: >46.5 feet  
 Drilled By: Jet Drilling      Date Measured: 1/3/2007  
 Drilling Method: 8" Hollow Stem Auger      Elevation: 924 feet (approx.)  
 Logged By: M. Janousek      Datum: MSL

| Elevation (feet) / Depth | Sample Type / Sample Number | Blows per Foot | Graphic Log | SOIL DESCRIPTION AND CLASSIFICATION  | Dry Density (pcf) | Moisture Content (%) | Additional Tests  |
|--------------------------|-----------------------------|----------------|-------------|--|-------------------|----------------------|---|
| 920                      | 1, 2, 3, 4, 4B              |                |             | <b>Asphalt Concrete:</b> approximately 8 inches thick.<br><b>Aggregate Base:</b> approximately 20 inches thick.  |                   |                      | Analytical<br>Analytical<br>Analytical, RV,<br>SE, CHEM |
| 915                      | 5                           | 27             |             | <b>Artificial Fill (Af):</b><br><b>Silty Clay (CL):</b> yellow, moist, with fine to medium sand, trace fine gravel.<br><b>Silty Sand (SM):</b> brown, moist, medium dense, fine to coarse grained, some coarse gravel, with clay.<br>-- yellow brown, increase gravel. | 107               | 11.3                 | GS  |
| 910                      | 6                           | 27             |             | -- trace gravel, decrease clay.  | 105               | 17.8                 |   |
| 905                      | 7, 8                        | 7, 15          |             | <b>Silty Clay (CH):</b> mottled yellow and gray, moist, medium stiff, with fine to coarse sand.<br>-- stiff, decrease sand.  |                   |                      | AL  |
| 900                      | 9                           | 14             |             | -- trace coarse gravel.  |                   |                      | AL  |
| 895                      | 10                          | 18             |             | <b>Alluvium (Qa):</b><br><b>Clayey Sand (SC):</b> brown, moist, medium dense, fine to coarse grained, with fine gravel.  |                   |                      |   |
| 890                      | 11                          | 28             |             | <b>Bedrock:</b><br><b>Upper Topanga Formation (Ttuc):</b> claystone and siltstone, mottled orange and gray, very stiff, thin-bedded, includes few thin sandstone strata, highly weathered.   | 95                | 24.8                 | DS  |

GEO TECH DB 75010-2 REYES ADOBE INTERCHANGE UPDATED 5-07.GPJ KA\_RDLND.GDT 5/29/07



Proposed West Side Widening  
 Reyes Adobe Road OC  
 Agoura Hills, CA

PLATE

A-4a




PROJECT NO. 75010-2

LOG OF BORING B-3

Drafted By:      Reviewed By:

Note: The boundaries between soil types shown on the logs are approximate as the transition between different soil layers may be gradual.

GEOTECH.DB 75010-2 REYES ADOBE INTERCHANGE UPDATED 5-07.GPJ KA RDLND.GDT 5/29/07

| Elevation<br>(feet)<br>Depth | Sample Type | Sample Number | Blows per Foot | Graphic Log   | SOIL DESCRIPTION<br>AND<br>CLASSIFICATION<br><i>(Continued From Previous Page)</i>   | Dry Density<br>(pcf) | Moisture<br>Content (%) | Additional<br>Tests |
|------------------------------|-------------|---------------|----------------|---|--|----------------------|-------------------------|---------------------|
| 885                          |             | 12            | 37             |  | <b>Bedrock:</b><br>Upper Topanga Formation (Ttuc): claystone and siltstone, mottled orange and gray, very stiff, thin-bedded, includes few thin sandstone strata, highly weathered. <i>(continued)</i><br>-- hard. |                      |                         |                     |
| 40                           |             | 13            | 61             |  | -- gray, slightly weathered, unoxidized.   | 112                  | 14.1                    | DS                  |
| 880                          |             | 14            | 62             |  |  |                      |                         |                     |
| 45                           |             |               |                |   | Total Depth: 46.5 feet.<br>Groundwater not encountered.<br>Boring backfilled with soil cuttings and capped with Quickset Cement.   |                      |                         |                     |



Proposed West Side Widening  
 Reyes Adobe Road OC  
 Agoura Hills, CA

PLATE

PROJECT NO. 75010-2

LOG OF BORING B-3

A-4b

Note: The boundaries between soil types shown on the logs are approximate as the transition between different soil layers may be gradual.

Date Drilled: 1/4/07      Water Depth: > 1.5 feet  
 Drilled By:      Date Measured: 1/4/2007  
 Drilling Method: Hand-Auger Boring      Elevation: 938 feet (approx.)  
 Logged By: M. Janousek      Datum: MSL

| Elevation (feet) Depth | Sample Type                         | Sample Number | Graphic Log | SOIL DESCRIPTION AND CLASSIFICATION  | Dry Density (pcf) | Moisture Content (%) | Additional Tests |
|------------------------|-------------------------------------|---------------|-------------|--|-------------------|----------------------|------------------|
| -935                   | <input checked="" type="checkbox"/> | 1             |             | <b>Artificial Fill (Af):</b><br><b>Silty Sand (SM):</b> brown, moist, fine to coarse grained, trace clay, with roots and leaves. |                   |                      | Analytical       |
|                        | <input checked="" type="checkbox"/> | 2             |             | -- increase clay, with cobbles up to 8 inches diameter.  |                   |                      | Analytical       |
|                        |                                     |               |             | Hand-Auger Boring terminated at 1.5 feet. Refusal encountered due to presence of oversize cobbles.                               |                   |                      |                  |

GEOTECH DB 75010-2 REYES ADOBE INTERCHANGE UPDATED 5-07.GPJ KA ROLIND.GDT 5/29/07



Proposed West Side Widening  
 Reyes Adobe Road OC  
 Agoura Hills, CA

PLATE

A-5

PROJECT NO. 75010-2

LOG OF BORING HB-1

Drafted By:      Reviewed By:

Note: The boundaries between soil types shown on the logs are approximate as the transition between different soil layers may be gradual.

Date Drilled: 1/4/07      Water Depth: > 1.5 feet  
 Drilled By:      Date Measured: 1/4/2007  
 Drilling Method: Hand-Auger Boring      Elevation: 926 feet (approx.)  
 Logged By: M. Janousek      Datum: MSL

| Elevation<br>(feet)<br>Depth | Sample Type                         | Sample Number | Graphic Log | SOIL DESCRIPTION<br>AND<br>CLASSIFICATION   | Dry Density<br>(pcf) | Moisture<br>Content (%) | Additional<br>Tests |
|------------------------------|-------------------------------------|---------------|-------------|---|----------------------|-------------------------|---------------------|
|                              |                                     |               |             |   |                      |                         |                     |
| 925                          | <input checked="" type="checkbox"/> | 1             |             | <b>Artificial Fill (Af):</b><br>Silty Sand (SM): brown, moist, fine to coarse grained, with fine gravel, with roots.  |                      |                         | Analytical          |
|                              | <input checked="" type="checkbox"/> | 2             |             | <b>Clayey Sand (SC):</b> yellow brown, moist, fine to coarse grained, with cobbles up to 6 inches diameter.<br>Hand-Auger Boring terminated at 1.5 feet. Refusal encountered due to presence of oversize cobbles. |                      |                         | Analytical          |

GEOTECH DB 75010-2 REYES ADOBE INTERCHANGE UPDATED 5-07-07.P1 KA RD.LND.GDT 5/29/07



Proposed West Side Widening  
 Reyes Adobe Road OC  
 Agoura Hills, CA

PLATE  
 A-6

PROJECT NO. 75010-2

LOG OF BORING HB-2

Drafted By:      Reviewed By:

Note: The boundaries between soil types shown on the logs are approximate as the transition between different soil layers may be gradual.



Date Drilled: 1/4/07      Water Depth: > 3 feet  
 Drilled By:                      Date Measured: 1/4/2007  
 Drilling Method: Hand-Auger Boring      Elevation: 924 feet (approx.)  
 Logged By: M. Janousek      Datum: MSL

| Elevation (feet)<br>Depth | Sample Type | Sample Number | Graphic Log | SOIL DESCRIPTION AND CLASSIFICATION  | Dry Density (pcf) | Moisture Content (%) | Additional Tests |
|---------------------------|-------------|---------------|-------------|--|-------------------|----------------------|------------------|
|                           | X           | 1             |             | <b>Artificial Fill (AF):</b><br>Silty Sand (SM): brown, moist, fine to medium grained. |                   |                      | Analytical       |
|                           | X           | 2             |             | - gray brown.  |                   |                      | Analytical       |
|                           | X           | 3             |             | <b>Sandy Clay (CL):</b> yellow brown, moist, fine to medium sand, some fine gravel.    |                   |                      | Analytical       |
|                           | X           | 4             |             |  |                   |                      | Analytical       |
| -920                      |             |               |             | Total Depth: 3.0 feet.<br>Boring backfilled with soil cuttings.                        |                   |                      |                  |

GEO TECH DB 75010-2 REYES ADOBE INTERCHANGE UPDATED 5-07.GPJ KA RDLND.GDT 5/29/07



Proposed West Side Widening  
 Reyes Adobe Road OC  
 Agoura Hills, CA

PLATE  
 A-7

PROJECT NO. 75010-2

**LOG OF BORING HB-3**

Drafted By:      Reviewed By:

Note: The boundaries between soil types shown on the logs are approximate as the transition between different soil layers may be gradual.



**APPENDIX B  
LABORATORY TESTING**

---

## **APPENDIX B LABORATORY TESTING**

---

Laboratory tests were performed on representative intact and bulk soil samples to estimate engineering characteristics of the various earth materials encountered. Testing was performed in accordance with one of the following references:

- 1) ASTM Standards for Soil Testing, latest revisions
- 2) Caltrans California Testing Methods (CTM), latest revisions

### **LABORATORY MOISTURE AND UNIT WEIGHT DETERMINATIONS**

Natural moisture content and dry unit weight tests were performed on soil samples collected from the borings in accordance with ASTM D2216-92 and D2937-94, respectively. The results are presented on the Logs of Borings and are summarized in Table B-1, Moisture and Unit Weight.

### **SIEVE ANALYSES**

Sieve analyses were performed on two samples of the materials encountered at the site to evaluate the grain size distribution characteristics of the soils and to aid in their classification. Tests were performed in general accordance with ASTM Test Method D 422. Results of these tests are presented as Plate B-1, Grain Size Distribution.

### **WASH SIEVE**

The percent passing #200 sieve of two selected soil samples were performed by wash sieving in accordance with ASTM Standard Test Method D 1140-92. The test results are summarized in Table B-2, Wash Sieve Test Results.

### **PLASTICITY INDEX**

Plasticity index testing was performed on two soil samples to evaluate the plasticity characteristics and to aid in the classification of the soils. The tests were performed in accordance with ASTM Standard Test Method D 4318. The results are presented as Plate B-2, Plasticity Chart.

## **DIRECT SHEAR**

Direct shear tests were conducted on four relatively undisturbed soil samples in accordance with ASTM Standard Test Method D 3080-90 to evaluate the shear strength parameters of the materials. Prior to shearing, the samples were soaked with water to saturation or near saturation moisture contents. The in-situ dry density and moisture content of the sample is presented in Table B-1 and on the boring logs. The test results are presented as Plates B-3 through B-6, Direct Shear Test.

## **CONSOLIDATION**

Consolidation testing was performed on two select, relatively undisturbed samples. The tests were performed in general accordance with ASTM Standard Test Method D 2435. The test results are presented as Plates B-7 and B-8, Consolidation Test. The specimen was inundated at 2.14 ksf which corresponds to approximately 15 to 20 feet of overburden for a finished grade condition.

## **R-VALUE TEST**

R-value testing was performed on one sample of the near-surface soils encountered at the site. The test was performed in general accordance with Caltrans Standard Test Method 301. The test result is presented in Table B-3, R-Value Test Result.

## **CORROSIVITY TESTS**

A series of chemical tests were performed on one selected sample collected from a depth between approximately 2.5 to 5.0 feet below the existing grade to estimate pH, resistivity, and sulfate and chloride contents. The test results may be used by a qualified corrosion engineer to evaluate the general corrosion potential with respect to the construction materials. The results of the tests are presented in Table B-4, Corrosion Test Results.

**Table B-1  
Moisture and Unit Weight**

| <b>Boring</b> | <b>Depth (ft)</b> | <b>Dry Unit Weight (pcf)</b> | <b>Moisture Content (%)</b> |
|---------------|-------------------|------------------------------|-----------------------------|
| B-1           | 5                 | 116                          | 13.7                        |
| B-1           | 10                | 109                          | 18.2                        |
| B-1           | 30                | 97                           | 25.9                        |
| B-2           | 15                | 104                          | 16.9                        |
| B-3           | 5                 | 107                          | 11.3                        |
| B-3           | 10                | 105                          | 17.8                        |
| B-3           | 30                | 95                           | 24.8                        |

**Table B-2  
Wash Sieve Test Results**

| <b>Boring</b> | <b>Depth (ft)</b> | <b>Percent Passing No. 200 Sieve</b> |
|---------------|-------------------|--------------------------------------|
| B-1           | 16                | 10                                   |
| B-2           | 20                | 13                                   |

**Table B-3  
R-Value Test Result**

| <b>Boring</b> | <b>Depth (ft)</b> | <b>R-Value</b> |
|---------------|-------------------|----------------|
| B-3           | 2.5 - 5           | 20             |

**Table B-4  
Corrosion Test Results**


| <b>Boring</b> | <b>Depth (ft)</b> | <b>PH</b> | <b>Sulfate (ppm)</b> | <b>Chloride (ppm)</b> | <b>Resistivity (<math>\Omega</math>-cm)</b> |
|---------------|-------------------|-----------|----------------------|-----------------------|---|
| B-3           | 2.5 - 5           | 7.8       | 14                   | 63                    | 1100  |

**SIEVE ANALYSIS**

**HYDROMETER**

U.S. STANDARD SIEVE SIZES

3" 1.5" 3/4" 3/8" #4 #10 #16 #30 #60 #100 #200



| GRAVEL |      | SAND   |        |      | SILT | CLAY |
|--------|------|--------|--------|------|------|------|
| coarse | fine | coarse | medium | fine |      |      |

| Symbol | Sample | Depth (ft) | Description | Classification |
|--------|--------|------------|-------------|----------------|
| ●      | B-1    | 10.0       | Sandy Clay  | CL             |
| ☒      | B-3    | 5.0        | Silty Sand  | SM             |



**KLEINFELDER**


Proposed West Side Widening  
 Reyes Adobe Road OC  
 Agoura Hills, CA

PLATE

**GRAIN SIZE DISTRIBUTION**

**B-1**

PROJECT NO. 75010-2



|   | Sample | Depth (ft) | LL (%) | PL (%) | PI (%) | LI (-) | Description            |
|---|--------|------------|--------|--------|--------|--------|------------------------|
| ● | B-1    | 6.0        | 33     | 12     | 21     |        | Sandy Clay (CL)        |
| ⊠ | B-2    | 30.0       | 53     | 25     | 28     |        | Weathered Bedrock (CH) |
| ▲ | B-3    | 16.5       | 52     | 28     | 24     |        | Silty Clay (CH)        |
| ★ | B-3    | 20.0       | 53     | 28     | 25     |        | Silty Clay (CH)        |

LL - Liquid Limit

PI - Plasticity Index

PL - Plasticity Limit

LI - Liquidity Index

**Unified Soil Classification  
Fine Grained Soil Groups**

|    | LL < 50  |
|----|--|
| ML | Inorganic clayey silts to very fine sands of slight plasticity |
| CL | Inorganic clays of low to medium plasticity                    |
| OL | Organic silts and organic silty clays of low plasticity        |

|    | LL > 50   |
|----|---|
| MH | Inorganic silts and clayey silts of high plasticity       |
| CH | Inorganic clays of high plasticity                        |
| OH | Organic clays of medium to high plasticity, organic silts |




Proposed West Side Widening  
Reyes Adobe Road OC  
Agoura Hills, CA

PLATE

**PLASTICITY CHART**

**B-2**

PROJECT NO. 75010-2



|                        |                          |      |      |
|------------------------|--------------------------|------|------|
| Test type              | controlled - strain test |      |      |
| Rate of shear - in/min | 0.004                    |      |      |
| Normal Stress - psf    | 2000                     | 4000 | 6000 |
| Peak Shear - psf       | 2016                     | 2348 | 4560 |
| Ultimate Shear - psf   | 1356                     | 2316 | 3960 |

Initial Moisture Content : 25.9%

Initial Dry Density : 97 pcf

Final Moisture Content : 28.1 %

|                |                         |
|----------------|-------------------------|
| Boring         | B-1                     |
| Depth - ft     | 30.0                    |
| Description    | Weathered Bedrock       |
| Classification | Upper Topanga Formation |

● Peak    ☒ Ultimate

|                      |       |       |
|----------------------|-------|-------|
| Friction Angle - deg | 32    | 33    |
| Cohesion - ksf       | 0.500 | 0.000 |



**KLEINFELDER**

Proposed West Side Widening  
Reyes Adobe Road OC  
Agoura Hills, CA


PLATE

**DIRECT SHEAR TEST**

**B-3**

PROJECT NO. 75010-2





|                        |                          |      |      |
|------------------------|--------------------------|------|------|
| Test type              | controlled - strain test |      |      |
| Rate of shear - in/min | 0.004                    |      |      |
| Normal Stress - psf    | 1000                     | 2000 | 4000 |
| Peak Shear - psf       | 1368                     | 1608 | 2556 |
| Ultimate Shear - psf   | 1044                     | 1368 | 2340 |

Initial Moisture Content : 16.9%

Initial Dry Density : 107 pcf

Final Moisture Content : 26.6%

|                |            |  |
|----------------|------------|--|
| Boring         | B-2        |  |
| Depth - ft     | 15.0       |  |
| Description    | Sandy Clay |  |
| Classification | CL         |  |

● Peak    ☒ Ultimate

|                      |       |       |
|----------------------|-------|-------|
| Friction Angle - deg | 24    | 24    |
| Cohesion - ksf       | 0.900 | 0.600 |




Proposed West Side Widening  
Reyes Adobe Road OC  
Agoura Hills, CA

PLATE

**DIRECT SHEAR TEST**

**B-4**

PROJECT NO. 75010-2



|                        |                          |      |      |
|------------------------|--------------------------|------|------|
| Test type              | controlled - strain test |      |      |
| Rate of shear - in/min | 0.004                    |      |      |
| Normal Stress - psf    | 2000                     | 4000 | 6000 |
| Peak Shear - psf       | 1692                     | 2652 | 3036 |
| Ultimate Shear - psf   | 1128                     | 2064 | 2412 |

Initial Moisture Content : 24.8%

Initial Dry Density : 95 pcf

Final Moisture Content : 28.5 %

|                |                         |
|----------------|-------------------------|
| Boring         | B-3                     |
| Depth - ft     | 30.0                    |
| Description    | Weathered Bedrock       |
| Classification | Upper Topanga Formation |

● Peak    □ Ultimate

|                      |       |       |
|----------------------|-------|-------|
| Friction Angle - deg | 19    | 18    |
| Cohesion - ksf       | 1.120 | 0.600 |



**KLEINFELDER**


Proposed West Side Widening  
Reyes Adobe Road OC  
Agoura Hills, CA

**DIRECT SHEAR TEST**

PLATE

**B-5**

PROJECT NO. 75010-2



|                        |                          |      |      |
|------------------------|--------------------------|------|------|
| Test type              | controlled - strain test |      |      |
| Rate of shear - in/min | 0.004                    |      |      |
| Normal Stress - psf    | 2000                     | 4000 | 6000 |
| Peak Shear - psf       | 1860                     | 2664 | 4320 |
| Ultimate Shear - psf   | 1212                     | 2052 | 2940 |

Initial Moisture Content : 14.0%

Initial Dry Density : 112 pcf

Final Moisture Content : 29.1 %

|                |                         |
|----------------|-------------------------|
| Boring         | B-3                     |
| Depth - ft     | 40.0                    |
| Description    | Weathered Bedrock       |
| Classification | Upper Topanga Formation |

● Peak    □ Ultimate

|                      |       |       |
|----------------------|-------|-------|
| Friction Angle - deg | 25    | 23    |
| Cohesion - ksf       | 0.840 | 0.350 |



**KLEINFELDER**


Proposed West Side Widening  
Reyes Adobe Road OC  
Agoura Hills, CA

**DIRECT SHEAR TEST**

PLATE

**B-6**

PROJECT NO. 75010-2



\*Note: Sample was Inudated at 2.14 ksf

|                |            |
|----------------|------------|
| Sample         | B-1        |
| Depth          | 10.0       |
| Description    | Sandy Clay |
| Classification | CL         |

Initial Moisture Content : 18.2 %  
 Initial Dry Density : 109 pcf  
 Final Moisture Content : 19.4 %




Proposed West Side Widening  
 Reyes Adobe Road OC  
 Agoura Hills, CA

PLATE

**CONSOLIDATION TEST**

**B-7**

PROJECT NO. 75010-2



\*Note: Sample was inudated at 2.14 ksf

|                |            |
|----------------|------------|
| Sample         | B-2        |
| Depth          | 5.0        |
| Description    | Sandy Clay |
| Classification | CL         |

Initial Moisture Content : 20.1 %  
 Initial Dry Density : 97 pcf  
 Final Moisture Content : 19.0 %



**KLEINFELDER**

Proposed West Side Widening  
 Reyes Adobe Road OC  
 Agoura Hills, CA

**CONSOLIDATION TEST**

PLATE

**B-8**

PROJECT NO. 75010-2



**APPENDIX C**  
**OUTPUTS OF ENGINEERING ANALYSES**

## **Appendix C**

**Including:**

1. Axial Pile Capacity Analysis (APILE)  
Abutment 1, Bents 2 and 3, Bent 4, Abutment 5
2. Lateral Pile Capacity Analysis (LIPLC)  
Abutment 1, Bents 2 and 3, Bent 4, Abutment 5
3. Slope Stability Analysis (SLIDE)  
Cross Section A-A North  
Cross Section A-A South  
Cross Section B-B

LPILE Plus for Windows, Version 5.0 (5.0.11)  
 Analysis of Individual Piles and Drilled Shafts  
 Subjected to Lateral Loading Using the p-y Method

(c) Copyright ENSOFT, Inc., 1985-2005  
 All Rights Reserved

This program is licensed to:

Youwei Zhou  
 Kleifelder

Path to file locations: U:\Y Zhou\Projects\75010\Analysis\LPILE\A5\  
 Name of input data file: A5p25mm.lpd  
 Name of output file: A5p25mm.lpo  
 Name of plot output file: A5p25mm.lpp  
 Name of runtime file: A5p25mm.lpr

Time and Date of Analysis

Date: May 30, 2007 Time: 13:29:41

Problem Title

A5, pinned head, 1.0 inch

Program Options

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
 - Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:  
 - Only internally-generated p-y curves used in analysis  
 - Analysis does not use p-y multipliers (individual pile or shaft section only)  
 - Analysis assumes no shear resistance at pile tip  
 - Analysis includes automatic computation of pile-top deflection vs. pile embedment length  
 - No computation of foundation stiffness matrix elements  
 - Output pile response for full length of pile  
 - Analysis assumes no soil movements acting on pile  
 - No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:  
 - Number of pile increments = 200  
 - Maximum number of iterations allowed = 200  
 - Deflection tolerance for convergence = 1.0000E-05 in  
 - Maximum allowable deflection = 1.0000E+01 in

Printing Options:  
 - Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile.  
 - Printing increment (spacing of output points) = 1

File Structural Properties and Geometry

Pile Length = 429.80 in  
 Depth of ground surface below top of pile = -86.20 in  
 Slope angle of ground surface = 25.00 deg.

Structural properties of pile defined using 2 points

| Point | Depth<br>x<br>in | Pile<br>Diameter<br>in | Moment of<br>Inertia<br>in <sup>4</sup> | Pile<br>Area<br>Sq.in | Modulus of<br>Elasticity<br>lbs/Sq.in |
|-------|------------------|------------------------|---|-----------------------|---------------------------------------|
| 1     | 0.0000           | 15.00000000            | 1242.5000                               | 176.7000              | 4300000.                              |
| 2     | 500.0000         | 15.00000000            | 1242.5000                               | 176.7000              | 4300000.                              |

Soil and Rock Layering Information

The soil profile is modelled using 6 layers

Layer 1 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = -86.200 in  
 Distance from top of pile to bottom of layer = 249.800 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 2 is stiff clay without free water  
 Distance from top of pile to top of layer = 249.800 in  
 Distance from top of pile to bottom of layer = 333.800 in

Layer 3 is stiff clay with water-induced erosion  
 Distance from top of pile to top of layer = 333.800 in  
 Distance from top of pile to bottom of layer = 357.800 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>



NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = 357.800 in  
 Distance from top of pile to bottom of layer = 417.800 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 417.800 in  
 Distance from top of pile to bottom of layer = 477.800 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 6 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 477.800 in  
 Distance from top of pile to bottom of layer = 600.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends 170.20 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth is defined using 12 points

| Point No. | Depth X in | Eff. Unit Weight lbs/in <sup>3</sup> |
|-----------|------------|--------------------------------------|
| 1         | -86.20     | .07234                               |
| 2         | 249.80     | .07234                               |
| 3         | 249.80     | .07234                               |
| 4         | 333.80     | .07234                               |
| 5         | 333.80     | .03623                               |
| 6         | 357.80     | .03623                               |
| 7         | 357.80     | .03623                               |
| 8         | 417.80     | .03623                               |
| 9         | 417.80     | .03333                               |
| 10        | 477.80     | .03333                               |
| 11        | 477.80     | .03623                               |
| 12        | 600.00     | .03623                               |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth defined using 12 points

| Point No. | Depth X in | Cohesion c lbs/in <sup>2</sup> | Angle of Friction Deg. | E50 or k <sub>em</sub> | RQD % |
|-----------|------------|--------------------------------|------------------------|------------------------|-------|
| 1         | -86.200    | .00000                         | 30.00                  | -----                  | ----- |
| 2         | 249.800    | .00000                         | 30.00                  | -----                  | ----- |
| 3         | 249.800    | 6.25000                        | .00                    | -----                  | ----- |
| 4         | 333.800    | 6.25000                        | .00                    | -----                  | ----- |
| 5         | 333.800    | 6.25000                        | .00                    | -----                  | ----- |
| 6         | 357.800    | 6.25000                        | .00                    | -----                  | ----- |
| 7         | 357.800    | .00000                         | 30.00                  | -----                  | ----- |
| 8         | 417.800    | .00000                         | 30.00                  | -----                  | ----- |
| 9         | 417.800    | 5.56000                        | 25.00                  | -----                  | ----- |
| 10        | 477.800    | 5.56000                        | 25.00                  | -----                  | ----- |
| 11        | 477.800    | 3.47000                        | 32.00                  | -----                  | ----- |
| 12        | 600.000    | 3.47000                        | 32.00                  | -----                  | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k<sub>em</sub> are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 Pile-head Loading and Pile-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number 1

Pile-head boundary conditions are Displacement and Moment (BC Type 4)  
 Deflection at pile head = 1.000 in  
 Bending moment at pile head = .000 in-lbs  
 Axial load at pile head = 30000.000 lbs





Number of iterations = 7  
 Number of zero deflection points = 5

-----  
 Summary of File-Head Response(s)  
 -----

Definition of Symbols for File-Head Loading Conditions:

Type 1 = Shear and Moment,      y = pile-head displacement in  
 Type 2 = Shear and Slope,      M = pile-head moment lbs-in  
 Type 3 = Shear and Rot. Stiffness, V = pile-head shear force lbs  
 Type 4 = Deflection and Moment,    s = pile-head slope, radians  
 Type 5 = Deflection and Slope,    R = rotational stiffness of pile-head-in-lbs/rad

| Load Type | Boundary Condition 1 | Boundary Condition 2 | Axial Load lbs | File-Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|-----------|----------------------|----------------------|----------------|-------------------------|-----------------------|-------------------|
| 4         | y = 1.000000         | M = 0.000            | 90000.0000     | 1.0000000               | 1060195.              | 35961.6920        |

-----  
 File-head Deflection vs. File Length  
 -----

Boundary Condition Type 4, Deflection and Moment

Deflection = 1.00000 in  
 Moment = 0. in-lbs  
 Axial Load = 90000. lbs

| File Length in | File Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|----------------|-------------------------|-----------------------|-------------------|
| 429.800        | 1.00000000              | 1060195.              | 35961.69205       |
| 408.310        | 1.00000000              | 1059918.              | 35959.83670       |
| 386.820        | 1.00000000              | 1060088.              | 35962.68179       |
| 365.330        | 1.00000000              | 1059926.              | 35965.12312       |
| 343.840        | 1.00000000              | 1060046.              | 35964.27954       |
| 322.350        | 1.00000000              | 1060065.              | 35966.13564       |
| 300.860        | 1.00000000              | 1060101.              | 35964.20617       |
| 279.370        | 1.00000000              | 1059982.              | 35963.83531       |
| 257.880        | 1.00000000              | 1059963.              | 35962.37321       |
| 236.390        | 1.00000000              | 1059012.              | 35946.35025       |

The analysis ended normally.

LPILE Plus for Windows, Version 5.0 (5.0.11)  
 Analysis of Individual Piles and Drilled Shafts  
 Subjected to Lateral Loading Using the p-y Method  
 (c) Copyright EHSOFT, Inc., 1985-2005  
 All Rights Reserved

This program is licensed to:

Youwei Zhou  
 Kleinfelder

Path to file locations: U:\Yzhou\Projects\75010\Analysis\LPILE\AS\  
 Name of input data file: A5p6m.ipc  
 Name of output file: A5p6m.lpc  
 Name of plot output file: A5p6m.lpp  
 Name of runtime file: A5p6m.ipr

Time and Date of Analysis

Date: May 30, 2007 Time: 13:28:42

Problem Title

A5, pinned head, 0.25 inch

Program Options

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
 - Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:

- Only internally-generated p-y curves used in analysis
- Analysis does not use p-y multipliers (individual pile or shaft action only)
- Analysis assumes no shear resistance at pile tip
- Analysis includes automatic computation of pile-top deflection vs. pile embedment length
- No computation of foundation stiffness matrix elements
- Output pile response for full length of pile
- Analysis assumes no soil movements acting on pile
- No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:

- Number of pile increments = 200  
 - Maximum number of iterations allowed = 200  
 - Deflection tolerance for convergence = 1.0000E-05 in  
 - Maximum allowable deflection = 1.0000E+01 in

Printing Options:

- Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile.
- Printing Increment (spacing of output points) = 1

Pile Structural Properties and Geometry

File Length = 429.80 in  
 Depth of ground surface below top of pile = -86.20 in  
 Slope angle of ground surface = 25.00 deg.

Structural properties of pile defined using 2 points

| Point | Depth X in | Pile Diameter in | Moment of Inertia in <sup>4</sup> | File Area Sq.in | Modulus of Elasticity lbs/Sq.in |
|-------|------------|------------------|-----------------------------------|-----------------|---------------------------------|
| 1     | 0.0000     | 15.00000000      | 2485.0000                         | 176.7000        | 4300000.                        |
| 2     | 500.0000   | 15.00000000      | 2485.0000                         | 176.7000        | 4300000.                        |

Soil and Rock Layering Information

The soil profile is modeled using 6 layers

Layer 1 is sand, p-y criteria by Reese et al., 1974

Distance from top of pile to top of layer = -86.200 in  
 Distance from top of pile to bottom of layer = 249.800 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 2 is stiff clay without free water  
 Distance from top of pile to top of layer = 249.800 in  
 Distance from top of pile to bottom of layer = 333.400 in

Layer 3 is stiff clay with water-induced erosion  
 Distance from top of pile to top of layer = 333.800 in  
 Distance from top of pile to bottom of layer = 357.800 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = 357.800 in  
 Distance from top of pile to bottom of layer = 417.800 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 417.800 in  
 Distance from top of pile to bottom of layer = 477.800 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 6 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 477.800 in  
 Distance from top of pile to bottom of layer = 600.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends 170.20 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth is defined using 12 points

| Point No. | Depth X in | Eff. Unit Weight lbs/in**3 |
|-----------|------------|----------------------------|
| 1         | -86.20     | .07234                     |
| 2         | 249.80     | .07234                     |
| 3         | 249.80     | .07234                     |
| 4         | 333.80     | .07234                     |
| 5         | 333.80     | .03623                     |
| 6         | 357.80     | .03623                     |
| 7         | 357.80     | .03623                     |
| 8         | 417.80     | .03623                     |
| 9         | 417.80     | .03333                     |
| 10        | 477.80     | .03333                     |
| 11        | 477.80     | .03623                     |
| 12        | 600.00     | .03623                     |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth defined using 12 points

| Point No. | Depth X in | Cohesion c lbs/in**2 | Angle of Friction Deg. | E50 or k <sub>zm</sub> | RQD % |
|-----------|------------|----------------------|------------------------|------------------------|-------|
| 1         | -86.200    | .00000               | 30.00                  | -----                  | ----- |
| 2         | 249.800    | .00000               | 30.00                  | -----                  | ----- |
| 3         | 249.800    | 6.25000              | .00                    | -----                  | ----- |
| 4         | 333.800    | 6.25000              | .00                    | -----                  | ----- |
| 5         | 333.800    | 6.25000              | .00                    | -----                  | ----- |
| 6         | 357.800    | 6.25000              | .00                    | -----                  | ----- |
| 7         | 357.800    | .00000               | 30.00                  | -----                  | ----- |
| 8         | 417.800    | .00000               | 30.00                  | -----                  | ----- |
| 9         | 417.800    | 5.56000              | 25.00                  | -----                  | ----- |
| 10        | 477.800    | 5.56000              | 25.00                  | -----                  | ----- |
| 11        | 477.800    | 3.47000              | 32.00                  | -----                  | ----- |
| 12        | 600.000    | 3.47000              | 32.00                  | -----                  | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k<sub>zm</sub> are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 File-head Loading and File-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number 1

File-head boundary conditions are Displacement and Moment (BC Type 4)  
 Deflection at pile head = .250 in  
 Bending moment at pile head = .000 in-lbs  
 Axial load at pile head = 90000.000 lbs

Computed Values of Load Distribution and Deflection  
for Lateral Loading for Load Case Number 1

File-head boundary conditions are Displacement and Moment (BC Type 4)  
Specified deflection at pile head = .250000 in  
Specified moment at pile head = .000 in-lbs  
Specified axial load at pile head = 90000.000 lbs

Table with 7 columns: Depth X in, Deflect. y in, Moment M lbs-in, Shear V lbs, Slope S Rad., Total Stress p lbs/in^2, Soil Res. q lbs/in. Rows contain numerical data points for various depths from 0.000 to 212.751.





Number of iterations = 5  
 Number of zero deflection points = 4

-----  
 Summary of File-Head Response(s)  
 -----

Definition of Symbols for File-Head Loading Conditions:

Type 1 = Shear and Moment, y = pile-head displacement in  
 Type 2 = Shear and Slope, M = pile-head moment lba-in  
 Type 3 = Shear and Rot. Stiffness, V = pile-head shear force lbs  
 Type 4 = Deflection and Moment, S = pile-head slope, radians  
 Type 5 = Deflection and Slope, R = rotational stiffness of pile-head-in-lba/rad

| Load Type | Boundary Condition | Boundary Condition | Axial Load lbs | File-Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|-----------|--------------------|--------------------|----------------|-------------------------|-----------------------|-------------------|
|           | 1                  | 2                  |                |                         |                       |                   |
| 4         | y = .250000        | M = 0.000          | 90000.0000     | .2500000                | 451550.               | 16409.0641        |

-----  
 File-head Deflection vs. File Length  
 -----

Boundary Condition Type 4, Deflection and Moment

Deflection = .25000 in  
 Moment = 0. in-lbs  
 Axial Load = 90000. lbs

| Pile Length in | File Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|----------------|-------------------------|-----------------------|-------------------|
| 429.800        | .25000000               | 451450.17358          | 16409.06409       |
| 408.310        | .25000000               | 451475.23290          | 16409.19244       |
| 386.820        | .25000000               | 451537.38803          | 16409.06146       |
| 365.330        | .25000000               | 451452.09435          | 16409.29340       |
| 343.840        | .25000000               | 451531.28136          | 16410.11709       |
| 322.350        | .25000000               | 451499.94432          | 16409.61582       |
| 300.860        | .25000000               | 451540.78084          | 16409.54861       |
| 279.370        | .25000000               | 451454.36845          | 16408.82171       |
| 257.880        | .25000000               | 451179.83504          | 16403.71831       |
| 236.390        | .25000000               | 450778.79227          | 16394.75533       |

The analysis ended normally.

LPFILE Plus for Windows, Version 5.0 (5.0.11)  
 Analysis of Individual Piles and Drilled Shafts  
 Subjected to Lateral Loading Using the p-y Method  
 (c) Copyright ENSOFT, Inc., 1985-2005  
 All Rights Reserved

This program is licensed to:

Younsi Zhou  
 Klaisfelder

Path to file locations: U:\Yzhou\Projects\75010\Analysis\LPFILE\AS\  
 Name of input data file: A5f25mm.lpd  
 Name of output file: A5f25mm.lpo  
 Name of plot output file: A5f25mm.lpp  
 Name of runtime file: A5f25mm.lpr

Time and Date of Analysis

Date: May 30, 2007 Time: 13:27:50

Problem Title

A5, fixed head, 1.0 inch

Program Options

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
 - Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:  
 - Only internally-generated p-y curves used in analysis  
 - Analysis does not use p-y multipliers (individual pile or shaft action only)  
 - Analysis assumes no shear resistance at pile tip  
 - Analysis includes automatic computation of pile-top deflection vs. pile embedment length  
 - No computation of foundation stiffness matrix elements  
 - Output pile response for full length of pile  
 - Analysis assumes no soil movements acting on pile  
 - No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:  
 - Number of pile increments = 200  
 - Maximum number of iterations allowed = 200  
 - Deflection tolerance for convergence = 1.0000E-05 in  
 - Maximum allowable deflection = 1.0000E+01 in

Printing Options:  
 - Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile.  
 - Printing increment (spacing of output points) = 1

File Structural Properties and Geometry

Pile Length = 429.00 in  
 Depth of ground surface below top of pile = -86.20 in  
 Slope angle of ground surface = 25.00 deg.

Structural properties of pile defined using 2 points

| Point | Depth<br>X<br>in | Pile<br>Diameter<br>in | Moment of<br>Inertia<br>in <sup>4</sup> | Pile<br>Area<br>Sq. in | Modulus of<br>Elasticity<br>lbs/Sq. in |
|-------|------------------|------------------------|---|------------------------|--|
| 1     | 0.0000           | 15.00000000            | 1242.5000                               | 176.7000               | 4300000.                               |
| 2     | 500.0000         | 15.00000000            | 1242.5000                               | 176.7000               | 4300000.                               |

Soil and Rock Layering Information

The soil profile is modelled using 6 layers

Layer 1 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = -86.200 in  
 Distance from top of pile to bottom of layer = 249.800 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 2 is stiff clay without free water  
 Distance from top of pile to top of layer = 249.800 in  
 Distance from top of pile to bottom of layer = 333.800 in

Layer 3 is stiff clay with water-induced erosion  
 Distance from top of pile to top of layer = 333.800 in  
 Distance from top of pile to bottom of layer = 357.800 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = 357.800 in  
 Distance from top of pile to bottom of layer = 417.800 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 417.800 in  
 Distance from top of pile to bottom of layer = 477.800 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 6 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 477.800 in  
 Distance from top of pile to bottom of layer = 600.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends 170.20 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth is defined using 12 points

| Point No. | Depth X in | Eff. Unit Weight lbs/in**3 |
|-----------|------------|----------------------------|
| 1         | -86.20     | .07234                     |
| 2         | 249.80     | .07234                     |
| 3         | 249.80     | .07234                     |
| 4         | 333.80     | .07234                     |
| 5         | 333.80     | .03623                     |
| 6         | 357.80     | .03623                     |
| 7         | 357.80     | .03623                     |
| 8         | 417.80     | .03623                     |
| 9         | 417.80     | .03333                     |
| 10        | 477.80     | .03333                     |
| 11        | 477.80     | .03623                     |
| 12        | 600.00     | .03623                     |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth defined using 12 points

| Point No. | Depth X in | Cohesion c lbs/in**2 | Angle of Friction Deg. | E50 or k_rm | RQD % |
|-----------|------------|----------------------|------------------------|-------------|-------|
| 1         | -86.200    | .00000               | 30.00                  | -----       | ----- |
| 2         | 249.800    | .00000               | 30.00                  | -----       | ----- |
| 3         | 249.800    | 6.25000              | .00                    | -----       | ----- |
| 4         | 333.800    | 6.25000              | .00                    | -----       | ----- |
| 5         | 333.800    | 6.25000              | .00                    | -----       | ----- |
| 6         | 357.800    | 6.25000              | .00                    | -----       | ----- |
| 7         | 357.800    | .00000               | 30.00                  | -----       | ----- |
| 8         | 417.800    | .00000               | 30.00                  | -----       | ----- |
| 9         | 417.800    | 5.56000              | 25.00                  | -----       | ----- |
| 10        | 477.800    | 5.56000              | 25.00                  | -----       | ----- |
| 11        | 477.800    | 3.47000              | 32.00                  | -----       | ----- |
| 12        | 600.000    | 3.47000              | 32.00                  | -----       | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k\_rm are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 File-head Loading and File-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number 1

File-head boundary conditions are Displacement and Slope (BC Type 5)  
 Deflection at pile head = 1.000 in  
 Slope at pile head = .000 in/in  
 Axial load at pile head = 90000.000 lbs





Number of iterations = 7  
 Number of zero deflection points = 5

-----  
 Summary of Pile-Head Response(s)  
 -----

Definition of Symbols for Pile-Head Loading Conditions:

Type 1 = Shear and Moment, y = pile-head displacement in  
 Type 2 = Shear and Slope, M = pile-head moment lbs-in  
 Type 3 = Shear and Rot. Stiffness, V = pile-head shear force lbs  
 Type 4 = Deflection and Moment, s = pile-head slope, radians  
 Type 5 = Deflection and Slope, R = rotational stiffness of pile-head-in-lbs/rd

| Load Type | Boundary Condition 1 | Boundary Condition 2 | Axial Load lbs | File-Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|-----------|----------------------|----------------------|----------------|-------------------------|-----------------------|-------------------|
| 5         | y = 1.000000         | s = 0.000            | 90000.0000     | 1.0000000               | -2998071.             | 78270.8245        |

-----  
 File-head Deflection vs. File Length  
 -----

Boundary Condition Type 5, Deflection and Slope

Deflection = 1.00000 in  
 Slope = .00000  
 Axial Load = 90000. lbs

| File Length in | File Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|----------------|-------------------------|-----------------------|-------------------|
| 429.800        | 1.00000000              | -2998071.             | 78270.82446       |
| 408.310        | 1.00000000              | -2998271.             | 78273.57771       |
| 386.820        | 1.00000000              | -2998182.             | 78267.39492       |
| 365.330        | 1.00000000              | -2998535.             | 78274.47786       |
| 343.840        | 1.00000000              | -2998527.             | 78270.81258       |
| 322.350        | 1.00000000              | -2998588.             | 78269.96375       |
| 300.860        | 1.00000000              | -2998782.             | 78273.23172       |
| 279.370        | 1.00000000              | -2998646.             | 78267.30608       |
| 257.880        | 1.00000000              | -2998388.             | 78256.56089       |
| 236.390        | 1.00000000              | -2998602.             | 78246.02222       |

The analysis ended normally.

LPILE Plus for Windows, Version 5.0 (5.0.11)  
Analysis of Individual Piles and Drilled Shafts  
Subjected to Lateral Loading Using the p-y Method  
(c) Copyright ENSOFT, Inc., 1985-2005  
All Rights Reserved

This program is licensed to:

Yusei Shou  
Kleifelder

Path to file locations: U:\Yshou\Projects\75010\Analysis\LPILE\A5\  
Name of input data file: A5f6mm.lpd  
Name of output file: A5f6mm.lpo  
Name of plot output file: A5f6mm.lpp  
Name of runtime file: A5f6mm.lpr

Time and Date of Analysis

Date: May 30, 2007 Time: 11:14:29

Problem Title

A5, fixed head, 0.25 inch

Program Options

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
- Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:

- Only internally-generated p-y curves used in analysis
- Analysis does not use p-y multipliers (individual pile or shaft action only)
- Analysis assumes no shear resistance at pile tip
- Analysis includes automatic computation of pile-top deflection vs. pile embedment length
- No computation of foundation stiffness matrix elements
- Output pile response for full length of pile
- Analysis assumes no soil movements acting on pile
- No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:

- Number of pile increments = 200
- Maximum number of iterations allowed = 200
- Deflection tolerance for convergence = 1.0000E-05 in
- Maximum allowable deflection = 1.0000E+01 in

Printing Options:

- Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile.
- Printing Increment (spacing of output points) = 1

Pile Structural Properties and Geometry

Pile Length = 429.80 in  
Depth of ground surface below top of pile = -86.20 in  
Slope angle of ground surface = 25.00 deg.

Structural properties of pile defined using 2 points

| Point | Depth<br>y<br>in | Pile<br>Diameter<br>in | Moment of<br>Inertia<br>in <sup>4</sup> | Pile<br>Area<br>Sq.in | Modulus of<br>Elasticity<br>lbs/Sq.in |
|-------|------------------|------------------------|---|-----------------------|---------------------------------------|
| 1     | 0.0000           | 15.00000000            | 2485.0000                               | 176.7000              | 4300000.                              |
| 2     | 500.0000         | 15.00000000            | 2485.0000                               | 176.7000              | 4300000.                              |

Soil and Rock Layering Information

The soil profile is modelled using 6 layers

Layer 1 is sand, p-y criteria by Reese et al., 1974  
Distance from top of pile to top of layer = -86.200 in  
Distance from top of pile to bottom of layer = 249.800 in  
p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 2 is stiff clay without free water  
Distance from top of pile to top of layer = 249.800 in  
Distance from top of pile to bottom of layer = 333.800 in

Layer 3 is stiff clay with water-induced erosion  
Distance from top of pile to top of layer = 333.800 in  
Distance from top of pile to bottom of layer = 357.800 in  
p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = 357.800 in  
 Distance from top of pile to bottom of layer = 417.800 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 417.800 in  
 Distance from top of pile to bottom of layer = 477.800 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 6 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 477.800 in  
 Distance from top of pile to bottom of layer = 600.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends 170.20 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth is defined using 12 points

| Point No. | Depth X in | Eff. Unit Weight lbs/in**3 |
|-----------|------------|----------------------------|
| 1         | -96.20     | .07234                     |
| 2         | 249.80     | .07234                     |
| 3         | 249.80     | .07234                     |
| 4         | 333.80     | .07234                     |
| 5         | 333.80     | .03623                     |
| 6         | 357.80     | .03623                     |
| 7         | 357.80     | .03623                     |
| 8         | 417.80     | .03623                     |
| 9         | 417.80     | .03333                     |
| 10        | 477.80     | .03333                     |
| 11        | 477.80     | .03623                     |
| 12        | 600.00     | .03623                     |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth defined using 12 points

| Point No. | Depth X in | Cohesion c lbs/in**2 | Angle of Friction Deg. | E50 or k <sub>sm</sub> | RQD % |
|-----------|------------|----------------------|------------------------|------------------------|-------|
| 1         | -96.200    | .00000               | 30.00                  | -----                  | ----- |
| 2         | 249.800    | .00000               | 30.00                  | -----                  | ----- |
| 3         | 249.800    | 6.25000              | .00                    | -----                  | ----- |
| 4         | 333.800    | 6.25000              | .00                    | -----                  | ----- |
| 5         | 333.800    | 6.25000              | .00                    | -----                  | ----- |
| 6         | 357.800    | 6.25000              | .00                    | -----                  | ----- |
| 7         | 357.800    | .00000               | 30.00                  | -----                  | ----- |
| 8         | 417.800    | .00000               | 30.00                  | -----                  | ----- |
| 9         | 417.800    | 5.56000              | 25.00                  | -----                  | ----- |
| 10        | 477.800    | 5.56000              | 25.00                  | -----                  | ----- |
| 11        | 477.800    | 3.47000              | 32.00                  | -----                  | ----- |
| 12        | 600.000    | 3.47000              | 32.00                  | -----                  | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k<sub>sm</sub> are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 Pile-head Loading and Pile-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number 1

File-head boundary conditions are Displacement and Slope (BC Type 5)  
 Deflection at pile head = .250 in  
 Slope at pile head = .000 in/in  
 Axial load at pile head = 90000.000 lbs



Computed Values of Load Distribution and Deflection  
for Lateral Loading for Load Case Number 1

File-head boundary conditions are Displacement and Slope (BC Type 5)  
Specified deflection at pile head = 250000 in  
Specified slope at pile head = 0.0008\*00 in/in  
Specified axial load at pile head = 90000.000 lbs

| Depth<br>X<br>in | Deflect.<br>y<br>in | Moment<br>M<br>lbs-in | Shear<br>V<br>lbs | Slope<br>S<br>Rad. | Total<br>Stress<br>lbs/in**2 | Soil Res<br>p<br>lbs/in |
|------------------|---------------------|-----------------------|-------------------|--------------------|------------------------------|-------------------------|
| 0.000            | .250000             | -1356901.             | 36238.0033        | 0.0000             | 4604.6131                    | -274.8419               |
| 2.149            | .249707             | -1279662.             | 35620.9368        | -.0002651          | 4371.4978                    | -287.1182               |
| 4.298            | .248860             | -1203700.             | 34990.9377        | -.0005148          | 4142.2342                    | -299.2460               |
| 6.447            | .247494             | -1129072.             | 34335.0186        | -.0007494          | 3917.0002                    | -311.1953               |
| 8.596            | .245639             | -1055838.             | 33653.6436        | -.0009891          | 3695.9712                    | -322.9368               |
| 10.745           | .243299             | -984054.              | 32954.2806        | -.0012743          | 3479.3194                    | -334.4416               |
| 12.894           | .240593             | -913776.              | 32216.4985        | -.0013651          | 3267.2137                    | -345.6813               |
| 15.043           | .237462             | -845059.              | 31461.8665        | -.0015420          | 3059.8188                    | -356.6286               |
| 17.192           | .233965             | -777937.              | 30684.0522        | -.0017052          | 2857.2955                    | -367.2563               |
| 19.341           | .230123             | -712520.              | 29883.7700        | -.0018550          | 2659.7997                    | -377.5386               |
| 21.490           | .225992             | -648799.              | 29061.7894        | -.0019919          | 2467.4826                    | -387.4503               |
| 23.639           | .221571             | -586842.              | 28218.9329        | -.0021162          | 2280.4896                    | -396.9871               |
| 25.788           | .216957             | -526995.              | 27356.0739        | -.0022282          | 2098.9609                    | -406.0658               |
| 27.937           | .212195             | -468403.              | 26474.1347        | -.0023282          | 1923.0299                    | -414.7244               |
| 30.086           | .206990             | -412009.              | 25574.0839        | -.0024167          | 1752.8246                    | -422.9217               |
| 32.235           | .201608             | -357551.              | 24654.9341        | -.0024941          | 1588.4658                    | -430.6378               |
| 34.384           | .196170             | -305068.              | 23723.7395        | -.0025608          | 1430.0673                    | -437.8541               |
| 36.533           | .190601             | -254596.              | 22775.5990        | -.0026170          | 1277.7358                    | -444.5531               |
| 38.682           | .184922             | -206167.              | 21813.6236        | -.0026634          | 1131.5709                    | -450.7185               |
| 40.831           | .179154             | -159811.              | 20838.9939        | -.0027002          | 991.6638                     | -456.3356               |
| 42.980           | .173317             | -115556.              | 19852.8971        | -.0027279          | 858.0985                     | -461.3906               |
| 45.129           | .167420             | -73427.7144           | 18856.5542        | -.0027469          | 730.9507                     | -465.8713               |
| 47.278           | .161511             | -33448.0229           | 17851.2111        | -.0027576          | 610.2876                     | -469.7668               |
| 49.427           | .155578             | 4363.4922             | 16838.1358        | -.0027605          | 522.5074                     | -473.0673               |
| 51.576           | .149646             | 39990.1175            | 15818.6158        | -.0027561          | 430.0324                     | -475.7646               |
| 53.725           | .143722             | 73418.0107            | 14793.9552        | -.0027447          | 330.9214                     | -477.8516               |
| 55.874           | .137850             | 104636.               | 13765.4718        | -.0027268          | 225.1414                     | -479.3223               |
| 58.023           | .132012             | 133637.               | 12738.9989        | -.0027028          | 912.6682                     | -475.9805               |
| 60.172           | .126233             | 160434.               | 11731.2206        | -.0026732          | 993.5450                     | -461.9240               |
| 62.321           | .120523             | 185092.               | 10754.0402        | -.0026385          | 1067.9645                    | -447.5040               |
| 64.470           | .114893             | 207675.               | 9808.1838         | -.0025990          | 1136.1249                    | -432.7718               |
| 66.619           | .109352             | 228253.               | 8894.2685         | -.0025552          | 1198.2289                    | -417.7775               |
| 68.768           | .103911             | 246891.               | 8012.8049         | -.0025074          | 1254.4829                    | -402.5701               |
| 70.917           | .098575             | 263661.               | 7168.2000         | -.0024560          | 1305.0969                    | -387.1972               |
| 73.066           | .093354             | 278633.               | 6348.7600         | -.0024015          | 1350.2831                    | -371.7047               |
| 75.215           | .088254             | 291877.               | 5566.6940         | -.0023441          | 1390.2556                    | -356.1371               |
| 77.364           | .083279             | 303466.               | 4818.1174         | -.0022843          | 1425.2300                    | -340.5473               |
| 79.513           | .078436             | 313469.               | 4103.0532         | -.0022222          | 1455.4222                    | -324.9463               |
| 81.662           | .073728             | 321983.               | 3421.4463         | -.0021583          | 1481.0485                    | -309.4835               |
| 83.811           | .069159             | 329010.               | 2773.1469         | -.0020929          | 1502.3245                    | -293.9463               |
| 85.960           | .064733             | 334689.               | 2157.9351         | -.0020261          | 1519.4647                    | -278.6101               |
| 88.109           | .060451             | 339068.               | 1575.5144         | -.0019584          | 1532.6823                    | -263.4287               |
| 90.258           | .056316             | 342218.               | 1025.5184         | -.0018899          | 1542.1884                    | -248.4336               |
| 92.407           | .052328             | 344207.               | 507.5146          | -.0018209          | 1548.1915                    | -233.6546               |
| 94.556           | .048490             | 345103.               | 21.0089           | -.0017516          | 1550.8975                    | -219.1194               |
| 96.705           | .044800             | 344975.               | -324.5503         | -.0016822          | 1550.5089                    | -204.8528               |
| 98.854           | .041260             | 343886.               | -859.7679         | -.0016129          | 1547.2245                    | -190.8815               |
| 101.003          | .037860             | 341903.               | -1255.2976        | -.0015439          | 1541.2391                    | -177.2244               |
| 103.152          | .034624             | 339088.               | -1621.0382        | -.0014755          | 1532.7435                    | -163.9023               |
| 105.301          | .031526             | 335503.               | -1960.1290        | -.0014076          | 1521.8235                    | -150.9332               |
| 107.450          | .028574             | 331208.               | -2270.9459        | -.0013406          | 1508.9603                    | -138.3334               |
| 109.599          | .025765             | 326261.               | -2555.0978        | -.0012745          | 1494.0302                    | -126.1170               |
| 111.748          | .023096             | 320719.               | -2813.4221        | -.0012094          | 1477.3039                    | -114.2965               |
| 113.897          | .020567             | 314637.               | -3046.7811        | -.0011455          | 1458.9469                    | -102.8827               |
| 116.046          | .018173             | 308067.               | -3256.0587        | -.0010829          | 1439.1190                    | -91.8847                |
| 118.195          | .015912             | 301061.               | -3442.1562        | -.0010214          | 1417.9741                    | -81.3098                |
| 120.344          | .013782             | 293648.               | -3605.9891        | -.0009618          | 1395.6606                    | -71.1639                |
| 122.493          | .011778             | 285935.               | -3748.4841        | -.0009036          | 1372.3207                    | -61.4512                |
| 124.642          | .009898             | 277907.               | -3870.5752        | -.0008469          | 1348.0908                    | -52.1747                |
| 126.791          | .008119             | 269627.               | -3972.2011        | -.0007918          | 1323.1010                    | -43.3297                |
| 128.940          | .006495             | 261136.               | -4057.3024        | -.0007384          | 1297.4755                    | -34.8344                |
| 131.089          | .004965             | 252474.               | -4123.8183        | -.0006868          | 1271.3324                    | -26.9696                |
| 133.238          | .003543             | 243678.               | -4173.6844        | -.0006369          | 1244.7838                    | -19.4390                |
| 135.387          | .002227             | 234782.               | -4207.8300        | -.0005888          | 1217.9356                    | -12.3391                |
| 137.536          | .001013             | 225820.               | -4227.1757        | -.0005425          | 1190.8879                    | -5.6653                 |
| 139.685          | -.000104            | 216823.               | -4232.4314        | -.0004979          | 1163.7347                    | 58.78230                |
| 141.834          | -.001127            | 207821.               | -4225.0943        | -.0004552          | 1136.5643                    | 6.4287                  |
| 143.983          | -.002061            | 198840.               | -4205.4465        | -.0004144          | 1109.4590                    | 11.8587                 |
| 146.132          | -.002908            | 189906.               | -4174.5540        | -.0003753          | 1082.4957                    | 16.8919                 |
| 148.281          | -.003674            | 181043.               | -4133.2644        | -.0003380          | 1055.7455                    | 21.5349                 |
| 150.430          | -.004361            | 172272.               | -4082.4058        | -.0003024          | 1029.2742                    | 25.7974                 |
| 152.579          | -.004973            | 163614.               | -4022.7855        | -.0002687          | 1003.1423                    | 29.6892                 |
| 154.728          | -.005515            | 155086.               | -3955.1896        | -.0002366          | 977.4050                     | 33.2209                 |
| 156.877          | -.005990            | 146706.               | -3880.3772        | -.0002063          | 952.1125                     | 36.4035                 |
| 159.026          | -.006402            | 138488.               | -3799.0890        | -.0001776          | 927.3102                     | 39.2485                 |
| 161.175          | -.006754            | 130446.               | -3712.0373        | -.0001505          | 903.0387                     | 41.7675                 |
| 163.324          | -.007049            | 122592.               | -3619.9094        | -.0001251          | 879.3340                     | 43.9727                 |
| 165.473          | -.007291            | 114936.               | -3523.3669        | -.0001012          | 856.2279                     | 45.8762                 |
| 167.622          | -.007484            | 107480.               | -3423.0444        | -7.8847E-05        | 833.7477                     | 47.4905                 |
| 169.771          | -.007630            | 100254.               | -3319.5499        | -5.7857E-05        | 812.9148                     | 48.8182                 |
| 171.920          | -.007733            | 93242.7804            | -3213.4642        | -3.8498E-05        | 790.7547                     | 49.8021                 |
| 174.069          | -.007794            | 86457.9075            | -3105.3406        | -2.0429E-05        | 770.2772                     | 50.7248                 |
| 176.218          | -.007821            | 79903.9288            | -2995.7053        | -3.7004E-06        | 750.4966                     | 51.3091                 |
| 178.367          | -.007812            | 73583.7975            | -2895.0569        | 1.1734E-05         | 731.4218                     | 51.6676                 |
| 180.516          | -.007771            | 67499.4155            | -2793.8668        | 2.5921E-05         | 713.0584                     | 51.8131                 |
| 182.665          | -.007700            | 61651.6914            | -2692.5794        | 3.8908E-05         | 695.4094                     | 51.7581                 |
| 184.814          | -.007600            | 56046.5888            | -2591.8139        | 5.0742E-05         | 678.4745                     | 51.6151                 |
| 186.963          | -.007482            | 50665.2333            | -2491.3566        | 6.1472E-05         | 662.2510                     | 51.0962                 |
| 189.112          | -.007339            | 45523.8694            | -2392.1769        | 7.1145E-05         | 646.7338                     | 50.5136                 |
| 191.261          | -.007176            | 40614.0166            | -2294.4125        | 7.9807E-05         | 631.9154                     | 49.7791                 |
| 193.410          | -.006996            | 35932.4738            | -2198.3771        | 8.7504E-05         | 617.7860                     | 48.9084                 |
| 195.559          | -.006800            | 31475.3837            | -2094.3596        | 9.4282E-05         | 604.3340                     | 47.9010                 |
| 197.708          | -.006591            | 27238.2858            | -1992.4249        | 0.0001002          | 591.5460                     | 46.7800                 |
| 199.857          | -.006370            | 23216.1677            | -1893.4139        | 0.0001055          | 579.4068                     | 45.5523                 |
| 202.006          | -.006138            | 19403.5161            | -1796.9445        | 0.0001095          | 567.8998                     | 44.2285                 |
| 204.155          | -.005899            | 15794.3660            | -1623.4119        | 0.0001131          | 557.0070                     | 42.8190                 |
| 206.304          | -.005652            | 12382.3484            | -1532.9896        | 0.0001158          | 546.7091                     | 41.3339                 |
| 208.453          | -.005401            | 9160.7372             | -1445.8297        | 0.0001181          | 536.9860                     | 39.7828                 |
| 210.602          | -.005145            | 6122.4949             | -1362.0636        | 0.0001196          | 527.8162                     | 38.1753                 |
| 212.751          | -.004887            | 3260.3158             | -1281.8028        | 0.0001206          | 519.1778                     | 36.5206                 |

|         |           |             |            |             |          |          |
|---------|-----------|-------------|------------|-------------|----------|----------|
| 214.900 | -0.04627  | 566.6695    | -1205.1392 | .0001209    | 511.0481 | 34.8275  |
| 217.049 | -0.04367  | -1866.1584  | -1132.1462 | .0001208    | 515.2719 | 33.1046  |
| 219.198 | -0.04107  | -4346.0261  | -1062.8786 | .0001202    | 522.4946 | 31.3603  |
| 221.347 | -0.03850  | -6580.8966  | -997.3740  | .0001191    | 529.1997 | 29.6026  |
| 223.496 | -0.03596  | -8678.8005  | -935.6529  | .0001175    | 535.5314 | 27.8392  |
| 225.645 | -0.03345  | -10647.8000 | -877.7192  | .0001156    | 541.4741 | 26.0777  |
| 227.794 | -0.03099  | -12495.9531 | -822.5610  | .0001133    | 547.0520 | 24.3254  |
| 229.943 | -0.02858  | -14231.2804 | -773.1510  | .0001106    | 552.2894 | 22.5894  |
| 232.092 | -0.02624  | -15861.7319 | -726.4470  | .0001074    | 557.2103 | 20.8764  |
| 234.241 | -0.02396  | -17395.1549 | -683.3923  | .0001042    | 561.8303 | 19.1932  |
| 236.390 | -0.02176  | -18839.2635 | -643.9160  | .0001006    | 566.1968 | 17.5461  |
| 238.539 | -0.01964  | -20201.6019 | -607.9337  | 9.6643E-05  | 570.3085 | 15.9414  |
| 240.688 | -0.01760  | -21489.5459 | -575.3476  | 9.2451E-05  | 574.1956 | 14.3853  |
| 242.837 | -0.01566  | -22710.2136 | -546.0469  | 8.8006E-05  | 577.8798 | 12.8828  |
| 244.986 | -0.01382  | -23870.4979 | -519.9080  | 8.3322E-05  | 581.3816 | 11.4427  |
| 247.135 | -0.01208  | -24977.0090 | -496.7950  | 7.8410E-05  | 584.7212 | 10.0678  |
| 249.284 | -0.01045  | -26036.0535 | -476.5596  | 7.3281E-05  | 587.9175 | 8.7647   |
| 251.433 | -0.00893  | -27053.6083 | -458.6169  | 6.7942E-05  | 590.9886 | 7.5293   |
| 253.582 | -0.00753  | -27646.6503 | -442.5824  | 6.2441E-05  | 592.7785 | 6.3514   |
| 255.731 | -0.00625  | -27932.4150 | 9.2436     | 5.6863E-05  | 593.3391 | 5.2316   |
| 257.880 | -0.00509  | -27628.9169 | 185.4841   | 5.1206E-05  | 592.7249 | 4.1630   |
| 260.029 | -0.00404  | -27055.0429 | 352.7065   | 4.5787E-05  | 590.9929 | 3.1546   |
| 262.178 | -0.00312  | -26130.6958 | 510.3922   | 4.0439E-05  | 588.2031 | 2.2071   |
| 264.327 | -0.00231  | -24877.0197 | 643.9907   | 3.5309E-05  | 584.4194 | 1.3244   |
| 266.476 | -0.00160  | -23376.4824 | 740.9181   | 3.0457E-05  | 579.8906 | 0.5029   |
| 268.625 | -9.97E-05 | -21704.3351 | 805.3630   | 2.5924E-05  | 574.8439 | 0.0000   |
| 270.774 | -4.86E-05 | -19925.0602 | 842.1599   | 2.1738E-05  | 569.4739 | 0.0000   |
| 272.923 | -6.29E-06 | -18093.1403 | 855.7734   | 1.7915E-05  | 563.9449 | 0.0000   |
| 275.072 | 2.84E-05  | -16253.8758 | 850.2807   | 1.4461E-05  | 558.3930 | -6.5499  |
| 277.221 | 5.59E-05  | -14444.2278 | 829.3652   | 1.1374E-05  | 552.9321 | -12.9155 |
| 279.370 | 7.72E-05  | -12693.6641 | 796.3191   | 8.6453E-06  | 547.6487 | -17.8394 |
| 281.519 | 9.31E-05  | -11024.9926 | 754.0528   | 6.2603E-06  | 542.6125 | -21.4964 |
| 283.668 | .000104   | -9455.1670  | 705.1099   | 4.2008E-06  | 537.8746 | -24.0530 |
| 285.817 | .000111   | -7996.0552  | 651.8809   | 2.4460E-06  | 533.4708 | -25.6559 |
| 287.966 | .000115   | -6603.1403  | 595.6592   | 9.7271E-07  | 529.4239 | -26.4808 |
| 290.115 | .000115   | -5436.3054  | 538.5861   | -2.4317E-07 | 525.7452 | -26.6314 |
| 292.264 | .000114   | -4340.2257  | 481.7764   | -1.2263E-06 | 522.4371 | -26.2394 |
| 294.413 | .000110   | -3365.1561  | 426.2745   | -2.0011E-06 | 519.4943 | -25.4143 |
| 296.562 | .000105   | -2507.3239  | 372.9067   | -2.5916E-06 | 516.9052 | -24.2532 |
| 298.711 | 9.89E-05  | -1761.4005  | 322.3029   | -3.0209E-06 | 514.6540 | -22.8420 |
| 300.860 | 9.20E-05  | -1120.8975  | 274.9208   | -3.3107E-06 | 512.7209 | -21.2549 |
| 303.009 | 8.47E-05  | -578.5302   | 231.0696   | -3.4816E-06 | 511.0839 | -19.5559 |
| 305.158 | 7.11E-05  | -126.4137   | 190.9314   | -3.5525E-06 | 509.7194 | -17.7992 |
| 307.307 | 6.94E-05  | 243.4872    | 154.5820   | -3.5407E-06 | 510.0727 | -16.0299 |
| 309.456 | 6.19E-05  | 539.3493    | 122.0087   | -3.4620E-06 | 510.9657 | -14.2849 |
| 311.605 | 5.45E-05  | 769.2197    | 93.1276    | -3.3304E-06 | 511.6594 | -12.5937 |
| 313.754 | 4.75E-05  | 940.8998    | 67.7983    | -3.1584E-06 | 512.1776 | -10.9793 |
| 315.903 | 4.10E-05  | 1061.8905   | 45.8375    | -2.9570E-06 | 512.5426 | -9.4588  |
| 318.052 | 3.48E-05  | 1139.0531   | 27.0303    | -2.7357E-06 | 512.7756 | -8.0443  |
| 320.201 | 2.92E-05  | 1179.0731   | 11.1408    | -2.5026E-06 | 512.8964 | -6.7435  |
| 322.350 | 2.41E-05  | 1187.9044   | -2.0797    | -2.2646E-06 | 512.9231 | -5.5603  |
| 324.499 | 1.95E-05  | 1171.0107   | -12.8849   | -2.0274E-06 | 512.8721 | -4.4958  |
| 326.648 | 1.54E-05  | 1133.3092   | -21.5280   | -1.7957E-06 | 512.7583 | -3.5480  |
| 328.797 | 1.17E-05  | 1079.1779   | -28.2560   | -1.5732E-06 | 512.5949 | -2.7135  |
| 330.946 | 8.60E-06  | 1012.4734   | -33.3062   | -1.3629E-06 | 512.3936 | -1.9866  |
| 333.095 | 5.89E-06  | 936.9060    | -36.9028   | -1.1649E-06 | 512.1645 | -1.3607  |
| 335.244 | 3.58E-06  | 854.3164    | -40.9713   | -9.8680E-07 | 511.9163 | -0.8425  |
| 337.393 | 1.65E-06  | 760.8421    | -45.3361   | -8.2438E-07 | 511.6342 | -0.4665  |
| 339.542 | 4.39E-08  | 659.7808    | -47.2974   | -6.8153E-07 | 511.3292 | -0.2504  |
| 341.691 | -1.20E-06 | 557.8215    | -45.8958   | -5.5909E-07 | 511.0214 | 0.0000   |
| 343.840 | -2.36E-06 | 462.7370    | -42.1254   | -4.5647E-07 | 510.7345 | 0.0000   |
| 345.989 | -3.21E-06 | 376.9431    | -37.4229   | -3.7203E-07 | 510.4755 | 0.0000   |
| 348.138 | -3.90E-06 | 302.0371    | -32.0809   | -3.0376E-07 | 510.2494 | 0.0000   |
| 350.287 | -4.55E-06 | 239.1772    | -26.2656   | -2.4933E-07 | 510.0597 | 0.0000   |
| 352.436 | -5.03E-06 | 189.2439    | -20.0863   | -2.0625E-07 | 509.9090 | 0.0000   |
| 354.585 | -5.43E-06 | 152.9261    | -13.6193   | -1.7184E-07 | 509.7994 | 0.0000   |
| 356.734 | -5.77E-06 | 130.7747    | -6.9209    | -1.4332E-07 | 509.7326 | 0.0000   |
| 358.883 | -6.05E-06 | 123.2356    | -3.4696    | -1.1777E-07 | 509.7088 | 0.0000   |
| 361.032 | -6.27E-06 | 115.9060    | -3.3697    | -9.3727E-08 | 509.6877 | 0.0000   |
| 363.181 | -6.45E-06 | 108.8019    | -3.2597    | -7.1131E-08 | 509.6662 | 0.0000   |
| 365.330 | -6.58E-06 | 101.9254    | -3.1494    | -4.9943E-08 | 509.6455 | 0.0000   |
| 367.479 | -6.67E-06 | 95.2852     | -3.0365    | -3.0110E-08 | 509.6254 | 0.0000   |
| 369.628 | -6.71E-06 | 88.8863     | -2.9217    | -1.1590E-08 | 509.6061 | 0.0000   |
| 371.777 | -6.72E-06 | 82.7322     | -2.8058    | 5.6674E-09  | 509.5876 | 0.0000   |
| 373.926 | -6.69E-06 | 76.8250     | -2.6892    | 2.1712E-08  | 509.5699 | 0.0000   |
| 376.075 | -6.62E-06 | 71.1655     | -2.5727    | 3.6591E-08  | 509.5526 | 0.0000   |
| 378.224 | -6.53E-06 | 65.7532     | -2.4569    | 5.0362E-08  | 509.5363 | 0.0000   |
| 380.373 | -6.41E-06 | 60.5864     | -2.3422    | 6.3066E-08  | 509.5207 | 0.0000   |
| 382.522 | -6.26E-06 | 55.6622     | -2.2291    | 7.4755E-08  | 509.5059 | 0.0000   |
| 384.671 | -6.08E-06 | 50.9766     | -2.1183    | 8.5479E-08  | 509.4917 | 0.0000   |
| 386.820 | -5.89E-06 | 46.5248     | -2.0100    | 9.5283E-08  | 509.4783 | 0.0000   |
| 388.969 | -5.67E-06 | 42.3008     | -1.9048    | 1.0422E-07  | 509.4655 | 0.0000   |
| 391.118 | -5.44E-06 | 38.2978     | -1.8030    | 1.1232E-07  | 509.4534 | 0.0000   |
| 393.267 | -5.19E-06 | 34.5081     | -1.7050    | 1.1964E-07  | 509.4420 | 0.0000   |
| 395.416 | -4.93E-06 | 30.9234     | -1.6112    | 1.2622E-07  | 509.4312 | 0.0000   |
| 397.565 | -4.65E-06 | 27.5345     | -1.5210    | 1.3210E-07  | 509.4210 | 0.0000   |
| 399.714 | -4.36E-06 | 24.3316     | -1.4372    | 1.3731E-07  | 509.4113 | 0.0000   |
| 401.863 | -4.06E-06 | 21.3041     | -1.3577    | 1.4190E-07  | 509.4022 | 0.0000   |
| 404.012 | -3.75E-06 | 18.4412     | -1.2825    | 1.4590E-07  | 509.3935 | 0.0000   |
| 406.161 | -3.43E-06 | 15.7312     | -1.2148    | 1.4934E-07  | 509.3853 | 0.0000   |
| 408.310 | -3.11E-06 | 13.1620     | -1.1519    | 1.5224E-07  | 509.3776 | 0.0000   |
| 410.459 | -2.78E-06 | 10.7212     | -1.0950    | 1.5464E-07  | 509.3702 | 0.0000   |
| 412.608 | -2.44E-06 | 8.3959      | -1.0442    | 1.5657E-07  | 509.3632 | 0.0000   |
| 414.757 | -2.10E-06 | 6.1728      | -.999697   | 1.5801E-07  | 509.3565 | 0.0000   |
| 416.906 | -1.76E-06 | 4.0383      | -.961548   | 1.5906E-07  | 509.3500 | 0.0000   |
| 419.055 | -1.42E-06 | 1.9785      | -.934340   | 1.5964E-07  | 509.3438 | 0.0000   |
| 421.204 | -1.08E-06 | 0.0000      | -.919748   | 1.5994E-07  | 509.3401 | 0.0000   |
| 423.353 | -7.34E-07 | -.1115780   | -.9164534  | 1.6002E-07  | 509.3382 | 0.0000   |
| 425.502 | -3.90E-07 | -.0859738   | -.9247022  | 1.6002E-07  | 509.3381 | 0.0000   |
| 427.651 | -4.62E-08 | -.0564921   | .0344040   | 1.6001E-07  | 509.3380 | 0.0000   |
| 429.800 | 2.98E-07  | 0.0000      | 0.0000     | 1.6000E-07  | 509.3379 | 0.0000   |

Output Verification:

Computed forces and moments are within specified convergence limits.

Output Summary for Load Case No. 1:

|                                 |   |                  |
|---------------------------------|---|------------------|
| File-head deflection            | = | .25000000 in     |
| Computed slope at pile head     | = | -.00000777       |
| Maximum bending moment          | = | -1356901. lbs-in |
| Maximum shear force             | = | 36238.00331 lbs  |
| Depth of maximum bending moment | = | 0.00000 in       |
| Depth of maximum shear force    | = | 0.00000 in       |

Number of iterations = 5  
 Number of zero deflection points = 4

-----  
 Summary of File-Head Responso(s)  
 -----

Definition of Symbols for File-Head Loading Conditions:

Type 1 = Shear and Moment, y = pile-head displacement in  
 Type 2 = Shear and Slope, M = pile-head moment lbs-in  
 Type 3 = Shear and Rot. Stiffness, V = pile-head shear force lbs  
 Type 4 = Deflection and Moment, S = pile-head slope, radians  
 Type 5 = Deflection and Slope, R = rotational stiffness of pile-head-in-lbs/rad

| Load Type | Boundary Condition | Boundary Condition | Axial Load lbs | File-Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|-----------|--------------------|--------------------|----------------|-------------------------|-----------------------|-------------------|
|           | 1                  | 2                  |                |                         |                       |                   |
| 5         | y = .250000        | S = 0.000          | 90000.0000     | .2500000                | -1356901.             | 36238.0033        |

-----  
 File-head Deflection vs. File Length  
 -----

Boundary Condition Type 5, Deflection and Slope

Deflection = .25000 in  
 Slope = .00000  
 Axial Load = 90000. lbs

| File Length in | File Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|----------------|-------------------------|-----------------------|-------------------|
| 429.800        | .25000000               | -1356901.             | 36238.00331       |
| 408.110        | .25000000               | -1356995.             | 36238.93276       |
| 386.820        | .25000000               | -1357017.             | 36237.88847       |
| 365.330        | .25000000               | -1357090.             | 36238.29044       |
| 343.840        | .25000000               | -1357130.             | 36238.00825       |
| 322.350        | .25000000               | -1357202.             | 36238.56784       |
| 300.860        | .25000000               | -1357219.             | 36237.99232       |
| 279.370        | .25000000               | -1357053.             | 36231.72021       |
| 257.880        | .25000000               | -1356926.             | 36222.40031       |
| 236.390        | .25000000               | -1356657.             | 36219.31920       |

The analysis ended normally.

LPILE Plus for Windows, Version 5.0 (5.0.11)  
Analysis of Individual Piles and Drilled Shafts  
Subjected to Lateral Loading Using the p-y Method  
(c) Copyright ENSOFT, Inc., 1985-2005  
All Rights Reserved

This program is licensed to:

Yuwai Zhou  
Kleifelder

Path to file locations: U:\Yzhou\Projects\75010\Analysis\LPILE\AS\  
Name of input data file: ASStability.lpd  
Name of output file: ASStability.lpo  
Name of plot output file: ASStability.lpp  
Name of runtime file: ASStability.lpr

Time and Date of Analysis

Date: May 30, 2007 Time: 13:24:15

Problem Title

AS Stability

Program Options

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
- Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:

- Only internally-generated p-y curves used in analysis
- Analysis does not use p-y multipliers (individual pile or shaft action only)
- Analysis assumes no shear resistance at pile tip
- Analysis includes automatic computation of pile-top deflection vs. pile embedment length
- No computation of foundation stiffness matrix elements
- Output pile response for full length of pile
- Analysis assumes no soil movements acting on pile
- No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:

- Number of pile increments = 200
- Maximum number of iterations allowed = 200
- Deflection tolerance for convergence = 1.0000E-05 in
- Maximum allowable deflection = 1.0000E+01 in

Printing Options:

- Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile.
- Printing Increment (spacing of output points) = 1

Pile Structural Properties and Geometry

Pile Length = 200.00 in  
Depth of ground surface below top of pile = -86.20 in  
Slope angle of ground surface = 25.00 deg.

Structural properties of pile defined using 2 points

| Point | Depth X in | Pile Diameter in | Moment of Inertia in <sup>4</sup> | Pile Area Sq. in | Modulus of Elasticity lbs/Sq.in |
|-------|------------|------------------|-----------------------------------|------------------|---------------------------------|
| 1     | 0.0000     | 15.00000000      | 1242.5000                         | 176.7000         | 4300000.                        |
| 2     | 500.0000   | 15.00000000      | 1242.5000                         | 176.7000         | 4300000.                        |

Soil and Rock Layering Information

The soil profile is modelled using 6 layers

Layer 1 is sand, p-y criteria by Reese et al., 1974  
Distance from top of pile to top of layer = -86.200 in  
Distance from top of pile to bottom of layer = 249.800 in  
p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 2 is stiff clay without free water  
Distance from top of pile to top of layer = 249.800 in  
Distance from top of pile to bottom of layer = 333.800 in

Layer 3 is stiff clay with water-induced erosion  
Distance from top of pile to top of layer = 333.800 in  
Distance from top of pile to bottom of layer = 357.800 in  
p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = 357.800 in  
 Distance from top of pile to bottom of layer = 417.800 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 417.800 in  
 Distance from top of pile to bottom of layer = 477.800 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 6 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 477.800 in  
 Distance from top of pile to bottom of layer = 600.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends 400.00 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth  
 is defined using 12 points

| Point No. | Depth X in | Eff. Unit Weight lbs/in**3 |
|-----------|------------|----------------------------|
| 1         | -86.20     | .07234                     |
| 2         | 249.80     | .07234                     |
| 3         | 249.80     | .07234                     |
| 4         | 333.80     | .07234                     |
| 5         | 333.80     | .03623                     |
| 6         | 357.80     | .03623                     |
| 7         | 357.80     | .03623                     |
| 8         | 417.80     | .03623                     |
| 9         | 417.80     | .03333                     |
| 10        | 477.80     | .03333                     |
| 11        | 477.80     | .03623                     |
| 12        | 600.00     | .03623                     |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth  
 defined using 12 points

| Point No. | Depth X in | Cohesion c lbs/in**2 | Angle of Friction Deg. | ES0 or k_fm | RQD % |
|-----------|------------|----------------------|------------------------|-------------|-------|
| 1         | -86.200    | .00000               | 30.00                  | -----       | ----- |
| 2         | 249.800    | .00000               | 30.00                  | -----       | ----- |
| 3         | 249.800    | 6.25000              | .00                    | -----       | ----- |
| 4         | 333.800    | 6.25000              | .00                    | -----       | ----- |
| 5         | 333.800    | 6.25000              | .00                    | -----       | ----- |
| 6         | 357.800    | 6.25000              | .00                    | -----       | ----- |
| 7         | 357.800    | .00000               | 30.00                  | -----       | ----- |
| 8         | 417.800    | .00000               | 30.00                  | -----       | ----- |
| 9         | 417.800    | 5.56000              | 25.00                  | -----       | ----- |
| 10        | 477.800    | 5.56000              | 25.00                  | -----       | ----- |
| 11        | 477.800    | 3.47000              | 32.00                  | -----       | ----- |
| 12        | 600.000    | 3.47000              | 32.00                  | -----       | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of ES0 are reported for clay strata.
- (3) Default values will be generated for ES0 when input values are 0.
- (4) RQD and k\_fm are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 File-head Loading and Pile-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number 1

File-head boundary conditions are Shear and Moment (BC Type 1)  
 Shear force at pile head = 36000.000 lbs  
 Bending moment at pile head = .000 in-lbs  
 Axial load at pile head = 90000.000 lbs

(Zero moment at pile head for this load indicates a free-head condition)

Computed Values of Load Distribution and Deflection  
for Lateral Loading for Load Case Number 1

File-head boundary conditions are Shear and Moment (BC Type 1)  
Specified shear force at pile head = 36000.000 lbs  
Specified moment at pile head = .000 in-lbs  
Specified axial load at pile head = 90000.000 lbs

(Zero moment for this load indicates free-head conditions)

| Depth<br>X<br>in | Deflect.<br>W<br>in | Moment<br>M<br>lbs-in | Shear<br>V<br>lbs | Slope<br>P<br>Rad. | Total<br>Stress<br>lbs/in*2 | Soil Res<br>P<br>lbs/in |
|------------------|---------------------|-----------------------|-------------------|--------------------|-----------------------------|-------------------------|
| 0.000            | 1.004               | 1.0677E-05            | 36000.0000        | -.0168279          | 509.3379                    | -483.7266               |
| 1.000            | .986710             | 37272.6443            | 35511.1923        | -.0168244          | 734.3236                    | -493.8807               |
| 2.000            | .969889             | 74050.7720            | 35012.1704        | -.0168140          | 958.3244                    | -504.1552               |
| 3.000            | .953082             | 110323.               | 34502.8297        | -.0167967          | 1175.2745                   | -514.5261               |
| 4.000            | .936296             | 146080.               | 33983.0560        | -.0167727          | 1391.1075                   | -525.0014               |
| 5.000            | .919537             | 181389.               | 33452.7748        | -.0167421          | 1603.7567                   | -535.5810               |
| 6.000            | .902812             | 215999.               | 32911.8518        | -.0167049          | 1813.1545                   | -546.2650               |
| 7.000            | .886127             | 250139.               | 32360.1927        | -.0166613          | 2019.2330                   | -557.0533               |
| 8.000            | .869489             | 283718.               | 31797.6910        | -.0166113          | 2221.9236                   | -567.9461               |
| 9.000            | .852905             | 316725.               | 31224.2484        | -.0165551          | 2421.1571                   | -578.9432               |
| 10.000           | .836379             | 349147.               | 30639.7545        | -.0164928          | 2616.8637                   | -590.0446               |
| 11.000           | .819919             | 380973.               | 30044.1069        | -.0164245          | 2808.9733                   | -601.2505               |
| 12.000           | .803530             | 412191.               | 29437.2013        | -.0163502          | 2997.4148                   | -612.5607               |
| 13.000           | .787218             | 442790.               | 28818.9334        | -.0162702          | 3182.1160                   | -623.9753               |
| 14.000           | .770990             | 472758.               | 28189.1986        | -.0161845          | 3363.0074                   | -635.4942               |
| 15.000           | .754849             | 502082.               | 27547.8928        | -.0160933          | 3540.0139                   | -647.1175               |
| 16.000           | .738803             | 530750.               | 26894.9114        | -.0159967          | 3713.0632                   | -658.8452               |
| 17.000           | .722856             | 558817.               | 26229.7501        | -.0158947          | 3882.0616                   | -670.6773               |
| 18.000           | .707014             | 586302.               | 25553.5046        | -.0157876          | 4046.9948                   | -682.6137               |
| 19.000           | .691281             | 612700.               | 24864.8705        | -.0156754          | 4207.7281                   | -694.6545               |
| 20.000           | .675663             | 638023.               | 24164.1434        | -.0155583          | 4364.2060                   | -706.7997               |
| 21.000           | .660164             | 663289.               | 23451.2189        | -.0154364          | 4516.3525                   | -719.0492               |
| 22.000           | .644790             | 688504.               | 22725.9927        | -.0153098          | 4664.0912                   | -731.4031               |
| 23.000           | .629545             | 712037.               | 21988.3605        | -.0151780          | 4807.3450                   | -743.8614               |
| 24.000           | .614423             | 735013.               | 21239.2177        | -.0150414          | 4946.0363                   | -756.4241               |
| 25.000           | .599415             | 757221.               | 20475.4601        | -.0149007          | 5080.0869                   | -769.0911               |
| 26.000           | .584525             | 778647.               | 19699.9833        | -.0147560          | 5209.4181                   | -781.8625               |
| 27.000           | .569938             | 799278.               | 18911.6829        | -.0146073          | 5333.9506                   | -794.7303               |
| 28.000           | .555401             | 819100.               | 18114.4200        | -.0144609          | 5453.6047                   | -799.7875               |
| 29.000           | .541016             | 838109.               | 17316.3116        | -.0143058          | 5568.3478                   | -799.4292               |
| 30.000           | .526789             | 856308.               | 16521.6817        | -.0141472          | 5678.1982                   | -792.8306               |
| 31.000           | .512722             | 873699.               | 15730.7675        | -.0139843          | 5782.1519                   | -788.9983               |
| 32.000           | .498818             | 890287.               | 14943.7987        | -.0138202          | 5883.3022                   | -784.8389               |
| 33.000           | .485002             | 906074.               | 14160.8997        | -.0136521          | 5978.5998                   | -780.6591               |
| 34.000           | .471514             | 921066.               | 13382.5872        | -.0134811          | 6069.0932                   | -776.1660               |
| 35.000           | .458319             | 935266.               | 12608.7707        | -.0133074          | 6154.8077                   | -771.4668               |
| 36.000           | .445490             | 948679.               | 11839.7529        | -.0131311          | 6235.7704                   | -766.5689               |
| 37.000           | .433085             | 961309.               | 11075.7286        | -.0129525          | 6312.0035                   | -761.4797               |
| 38.000           | .421095             | 973165.               | 10316.8853        | -.0127713          | 6383.5544                   | -756.2070               |
| 39.000           | .409515             | 984242.               | 9563.4025         | -.0125881          | 6450.4357                   | -750.7585               |
| 40.000           | .398349             | 994555.               | 8815.4521         | -.0124029          | 6512.6852                   | -745.1424               |
| 41.000           | .387599             | 1004105.              | 8073.1976         | -.0122159          | 6570.3357                   | -739.3665               |
| 42.000           | .377267             | 1012900.              | 7336.7948         | -.0120271          | 6623.4211                   | -733.4392               |
| 43.000           | .367355             | 1020944.              | 6606.3907         | -.0118368          | 6671.9763                   | -727.3688               |
| 44.000           | .357873             | 1028243.              | 5882.1245         | -.0116450          | 6716.0372                   | -721.1637               |
| 45.000           | .348815             | 1034800.              | 5164.1265         | -.0114519          | 6755.6404                   | -714.8323               |
| 46.000           | .340180             | 1040633.              | 4452.5106         | -.0112577          | 6790.8235                   | -708.3833               |
| 47.000           | .331969             | 1045736.              | 3747.4143         | -.0110625          | 6821.6249                   | -701.8253               |
| 48.000           | .324185             | 1050119.              | 3048.9182         | -.0108663          | 6848.0835                   | -695.1670               |
| 49.000           | .316831             | 1053789.              | 2357.1261         | -.0106694          | 6870.2392                   | -688.4170               |
| 50.000           | .310006             | 1056754.              | 1672.1255         | -.0104719          | 6889.1323                   | -681.5843               |
| 51.000           | .303719             | 1059019.              | 993.9846          | -.0102739          | 6902.8038                   | -674.6775               |
| 52.000           | .297970             | 1060591.              | 322.8031          | -.0100755          | 6911.2950                   | -667.7054               |
| 53.000           | .292762             | 1061478.              | -341.3872         | -.0098769          | 6916.6480                   | -660.6752               |
| 54.000           | .288094             | 1061686.              | -998.4467         | -.0096782          | 6917.9051                   | -653.4438               |
| 55.000           | .283965             | 1061223.              | -1648.1269        | -.0094796          | 6915.1100                   | -645.9166               |
| 56.000           | .280385             | 1060096.              | -2290.1318        | -.0092811          | 6908.3080                   | -638.0934               |
| 57.000           | .277353             | 1058313.              | -2924.1656        | -.0090828          | 6897.5465                   | -629.9742               |
| 58.000           | .274879             | 1055819.              | -3549.8946        | -.0088843          | 6882.8478                   | -621.5589               |
| 59.000           | .272963             | 1052813.              | -4167.1352        | -.0086876          | 6864.3439                   | -612.8472               |
| 60.000           | .271604             | 1049112.              | -4775.4781        | -.0084909          | 6842.0066                   | -603.8386               |
| 61.000           | .270801             | 1044790.              | -5374.6637        | -.0082949          | 6815.9178                   | -594.5327               |
| 62.000           | .270554             | 1039856.              | -5964.3943        | -.0080998          | 6786.1339                   | -584.9285               |
| 63.000           | .270875             | 1034319.              | -6544.3710        | -.0079057          | 6752.7136                   | -575.0249               |
| 64.000           | .271763             | 1028190.              | -7114.2938        | -.0077127          | 6715.7172                   | -564.9207               |
| 65.000           | .273219             | 1021479.              | -7689.8587        | -.0075209          | 6675.2068                   | -554.5092               |
| 66.000           | .275251             | 1014204.              | -8203.8478        | -.0073304          | 6631.2949                   | -521.6690               |
| 67.000           | .277865             | 1006391.              | -8713.3747        | -.0071413          | 6584.1310                   | -497.3847               |
| 68.000           | .281050             | 998063.               | -9198.7994        | -.0069537          | 6533.8624                   | -473.4647               |
| 69.000           | .284815             | 989245.               | -9660.4903        | -.0067677          | 6480.6344                   | -449.9172               |
| 70.000           | .289160             | 979960.               | -10098.8238       | -.0065834          | 6424.3590                   | -426.7497               |
| 71.000           | .294085             | 970232.               | -10514.1832       | -.0064008          | 6365.8701                   | -403.9693               |
| 72.000           | .299591             | 960084.               | -10906.9591       | -.0062203          | 6304.6130                   | -381.5825               |
| 73.000           | .305675             | 949538.               | -11277.5400       | -.0060416          | 6240.9550                   | -359.5954               |
| 74.000           | .312339             | 938616.               | -11626.3525       | -.0058649          | 6175.0298                   | -338.0135               |
| 75.000           | .319572             | 927341.               | -11953.7803       | -.0056902          | 6106.9689                   | -316.8421               |
| 76.000           | .327377             | 915733.               | -12260.2441       | -.0055178          | 6036.9011                   | -296.0856               |
| 77.000           | .335755             | 903814.               | -12546.1610       | -.0053475          | 5964.9530                   | -275.7482               |
| 78.000           | .344707             | 891620.               | -12811.9519       | -.0051795          | 5891.2406                   | -255.8337               |
| 79.000           | .354232             | 879122.               | -13058.0413       | -.0050137          | 5815.9092                   | -236.3452               |
| 80.000           | .364339             | 866390.               | -13284.8567       | -.0048504          | 5739.0537                   | -217.2856               |
| 81.000           | .375026             | 853425.               | -13492.8282       | -.0046894          | 5660.7966                   | -198.6573               |
| 82.000           | .386291             | 840248.               | -13682.3879       | -.0045309          | 5581.2576                   | -180.4622               |
| 83.000           | .398134             | 826876.               | -13853.9698       | -.0043749          | 5500.5419                   | -162.7018               |
| 84.000           | .410556             | 813328.               | -14008.0095       | -.0042214          | 5418.7599                   | -145.3774               |
| 85.000           | .423557             | 799620.               | -14141.9519       | -.0040705          | 5336.0177                   | -128.4896               |
| 86.000           | .437139             | 785770.               | -14245.2072       | -.0039221          | 5252.4187                   | -112.0389               |
| 87.000           | .451292             | 771796.               | -14369.2393       | -.0037763          | 5168.0634                   | -96.0252                |
| 88.000           | .466017             | 757712.               | -14457.4761       | -.0036332          | 5083.0500                   | -80.4483                |
| 89.000           | .481314             | 743535.               | -14530.3538       | -.0034927          | 4997.4740                   | -65.3072                |
| 90.000           | .497183             | 729280.               | -14588.3080       | -.0033549          | 4911.4282                   | -50.6011                |
| 91.000           | .513624             | 714962.               | -14631.7128       | -.0032197          | 4825.0627                   | -36.3285                |
| 92.000           | .530637             | 700592.               | -14661.1810       | -.0030875          | 4738.2853                   | -22.4878                |
| 93.000           | .548222             | 686195.               | -14676.9633       | -.0029579          | 4651.3609                   | -9.0769                 |
| 94.000           | .566389             | 671774.               | -14679.5485       | -.0028304          | 4564.3120                   | 3.9065                  |
| 95.000           | .585135             | 657346.               | -14669.3628       | -.0027060          | 4477.2183                   | 16.4650                 |

|         |           |            |             |             |           |          |
|---------|-----------|------------|-------------|-------------|-----------|----------|
| 96.000  | -0.06279  | 642922.    | -14646.8295 | -0.0025843  | 4390.1572 | 28.4014  |
| 97.000  | -0.00803  | 628517.    | -14612.3683 | -0.0024653  | 4303.2033 | 40.3190  |
| 98.000  | -0.011210 | 614141.    | -14566.3993 | -0.0023490  | 4216.4289 | 51.6210  |
| 99.000  | -0.013501 | 599807.    | -14509.3333 | -0.0022354  | 4129.9037 | 62.5111  |
| 100.000 | -0.015681 | 585523.    | -14441.5812 | -0.0021245  | 4043.6948 | 72.9932  |
| 101.000 | -0.017750 | 571306.    | -14363.5489 | -0.0020182  | 3957.8659 | 83.0713  |
| 102.000 | -0.019713 | 557161.    | -14275.6383 | -0.0019106  | 3872.4824 | 92.7499  |
| 103.000 | -0.021572 | 543059.    | -14178.2467 | -0.0018077  | 3787.6011 | 102.0333 |
| 104.000 | -0.023328 | 529130.    | -14071.7469 | -0.0017073  | 3703.2805 | 110.8263 |
| 105.000 | -0.024986 | 515263.    | -13956.5869 | -0.0016096  | 3619.5757 | 119.4337 |
| 106.000 | -0.026547 | 501506.    | -13833.0897 | -0.0015144  | 3536.5394 | 127.5606 |
| 107.000 | -0.028015 | 487869.    | -13701.6533 | -0.0014218  | 3454.2220 | 135.3123 |
| 108.000 | -0.029391 | 474359.    | -13562.6502 | -0.0013318  | 3372.6719 | 142.6939 |
| 109.000 | -0.030679 | 460984.    | -13416.4477 | -0.0012442  | 3291.9348 | 149.7111 |
| 110.000 | -0.031880 | 447750.    | -13263.4074 | -0.0011592  | 3212.0546 | 156.3694 |
| 111.000 | -0.032997 | 434663.    | -13103.8854 | -0.0010766  | 3133.0727 | 162.6747 |
| 112.000 | -0.034033 | 421736.    | -12938.2317 | -0.0009965  | 3055.0205 | 168.6327 |
| 113.000 | -0.034990 | 408968.    | -12766.7907 | -0.0009187  | 2977.9594 | 174.2493 |
| 114.000 | -0.035870 | 396368.    | -12589.9006 | -0.0008434  | 2901.9005 | 179.5308 |
| 115.000 | -0.036677 | 383940.    | -12407.8337 | -0.0007703  | 2826.8850 | 184.4830 |
| 116.000 | -0.037411 | 371691.    | -12221.0960 | -0.0006996  | 2752.9440 | 189.1124 |
| 117.000 | -0.038076 | 359624.    | -12029.8274 | -0.0006312  | 2680.1068 | 193.4250 |
| 118.000 | -0.038673 | 347745.    | -11834.4013 | -0.0005650  | 2608.4005 | 197.4272 |
| 119.000 | -0.039206 | 336057.    | -11635.1249 | -0.0005010  | 2537.8506 | 201.1255 |
| 120.000 | -0.039675 | 324565.    | -11432.2991 | -0.0004392  | 2468.4805 | 204.5261 |
| 121.000 | -0.040084 | 313271.    | -11226.2184 | -0.0003795  | 2400.3121 | 207.6355 |
| 122.000 | -0.040434 | 302181.    | -11017.1705 | -0.0003219  | 2333.3651 | 210.4601 |
| 123.000 | -0.040728 | 291285.    | -10805.4372 | -0.0002663  | 2267.6577 | 213.0065 |
| 124.000 | -0.040967 | 280618.    | -10591.2935 | -0.0002120  | 2203.2065 | 215.2810 |
| 125.000 | -0.041153 | 270151.    | -10375.0079 | -0.0001613  | 2140.0242 | 217.2902 |
| 126.000 | -0.041289 | 259897.    | -10156.8426 | -0.0001117  | 2078.1301 | 219.0404 |
| 127.000 | -0.041377 | 249857.    | -9937.0533  | -6.3958E-05 | 2017.5297 | 220.5382 |
| 128.000 | -0.041417 | 239834.    | -9715.8893  | -1.8112E-05 | 1958.2352 | 221.7899 |
| 129.000 | -0.041413 | 230429.    | -9492.8334  | 2.5916E-05  | 1900.2550 | 222.8019 |
| 130.000 | -0.041366 | 221042.    | -9270.4022  | 6.8167E-05  | 1843.5962 | 223.5806 |
| 131.000 | -0.041277 | 211876.    | -9046.5458  | .0001087    | 1788.2646 | 224.1322 |
| 132.000 | -0.041148 | 202929.    | -8822.2481  | .0001475    | 1734.2643 | 224.4631 |
| 133.000 | -0.040982 | 194204.    | -8597.7268  | .0001847    | 1681.5983 | 224.5795 |
| 134.000 | -0.040779 | 185701.    | -8372.1934  | .0002202    | 1630.2682 | 224.4874 |
| 135.000 | -0.040541 | 177418.    | -8148.8532  | .0002542    | 1580.2742 | 224.1929 |
| 136.000 | -0.040270 | 169357.    | -7924.9057  | .0002867    | 1531.6155 | 223.7021 |
| 137.000 | -0.039968 | 161517.    | -7701.5442  | .0003176    | 1484.2898 | 223.0209 |
| 138.000 | -0.039635 | 153897.    | -7478.9562  | .0003471    | 1438.2940 | 222.1551 |
| 139.000 | -0.039274 | 146497.    | -7257.3234  | .0003753    | 1393.6235 | 221.1105 |
| 140.000 | -0.038885 | 139315.    | -7036.8217  | .0004020    | 1350.2727 | 219.8928 |
| 141.000 | -0.038470 | 132351.    | -6817.6216  | .0004274    | 1308.2351 | 218.5075 |
| 142.000 | -0.038030 | 125603.    | -6599.8878  | .0004516    | 1267.5030 | 216.9601 |
| 143.000 | -0.037567 | 119070.    | -6383.7797  | .0004745    | 1228.0678 | 215.2561 |
| 144.000 | -0.037081 | 112750.    | -6169.4513  | .0004962    | 1189.9197 | 213.4006 |
| 145.000 | -0.036574 | 106641.    | -5957.0516  | .0005167    | 1153.0484 | 211.3989 |
| 146.000 | -0.036048 | 100743.    | -5746.7242  | .0005361    | 1117.4422 | 209.2559 |
| 147.000 | -0.035502 | 95051.4329 | -5538.6079  | .0005544    | 1083.0890 | 206.9767 |
| 148.000 | -0.034939 | 89565.6152 | -5332.8365  | .0005717    | 1049.9754 | 204.5661 |
| 149.000 | -0.034359 | 84282.8549 | -5129.5391  | .0005880    | 1018.0875 | 202.0287 |
| 150.000 | -0.033763 | 79200.7034 | -4928.8402  | .0006033    | 987.4105  | 199.3691 |
| 151.000 | -0.033152 | 74316.5869 | -4730.8597  | .0006176    | 957.8289  | 196.5919 |
| 152.000 | -0.032526 | 69627.8305 | -4535.7131  | .0006311    | 929.6265  | 193.7013 |
| 153.000 | -0.031880 | 65131.5624 | -4343.5117  | .0006437    | 902.4861  | 190.7015 |
| 154.000 | -0.031240 | 60824.9187 | -4154.3626  | .0006555    | 876.4903  | 187.5967 |
| 155.000 | -0.030579 | 56704.8471 | -3968.3689  | .0006665    | 851.6206  | 184.3907 |
| 156.000 | -0.029907 | 52768.2109 | -3785.6299  | .0006767    | 827.8582  | 181.0874 |
| 157.000 | -0.029225 | 49011.7732 | -3606.2410  | .0006863    | 805.1836  | 177.6904 |
| 158.000 | -0.028535 | 45432.2003 | -3430.2941  | .0006951    | 783.5765  | 174.2034 |
| 159.000 | -0.027835 | 42026.0654 | -3257.8776  | .0007033    | 763.0163  | 170.6296 |
| 160.000 | -0.027128 | 38789.8522 | -3089.0765  | .0007109    | 743.4818  | 166.9725 |
| 161.000 | -0.026413 | 35719.9582 | -2923.9727  | .0007178    | 724.9513  | 163.2552 |
| 162.000 | -0.025699 | 32812.6974 | -2762.6447  | .0007242    | 707.4024  | 159.4207 |
| 163.000 | -0.024985 | 30064.3050 | -2605.1585  | .0007301    | 690.8125  | 155.5219 |
| 164.000 | -0.024232 | 27470.9377 | -2451.6169  | .0007355    | 675.1584  | 151.5714 |
| 165.000 | -0.023494 | 25028.6791 | -2302.0601  | .0007404    | 660.4164  | 147.5420 |
| 166.000 | -0.022751 | 22733.5409 | -2156.5660  | .0007449    | 646.5625  | 143.4462 |
| 167.000 | -0.022004 | 20581.4660 | -2015.1997  | .0007489    | 633.5721  | 139.2864 |
| 168.000 | -0.021253 | 18568.3308 | -1878.0242  | .0007526    | 621.4203  | 135.0647 |
| 169.000 | -0.020499 | 16689.9474 | -1745.1002  | .0007559    | 610.0820  | 130.7832 |
| 170.000 | -0.019741 | 14942.0662 | -1616.4866  | .0007589    | 599.5314  | 126.4441 |
| 171.000 | -0.018981 | 13320.3773 | -1492.2400  | .0007615    | 589.7426  | 122.0431 |
| 172.000 | -0.018218 | 11820.5131 | -1372.4154  | .0007639    | 580.6890  | 117.6000 |
| 173.000 | -0.017453 | 10438.0498 | -1257.0662  | .0007660    | 572.3442  | 113.0984 |
| 174.000 | -0.016687 | 9168.5091  | -1146.2441  | .0007678    | 564.6810  | 108.5459 |
| 175.000 | -0.015918 | 8007.3598  | -1039.9993  | .0007694    | 557.6720  | 103.9438 |
| 176.000 | -0.015148 | 6950.0193  | -938.3807   | .0007708    | 551.2897  | 99.2934  |
| 177.000 | -0.014376 | 5981.8552  | -841.4360   | .0007720    | 545.5060  | 94.5960  |
| 178.000 | -0.013604 | 5128.1862  | -749.2117   | .0007730    | 540.2927  | 89.8526  |
| 179.000 | -0.012830 | 4354.2834  | -661.7533   | .0007739    | 535.6213  | 85.0642  |
| 180.000 | -0.012056 | 3665.3714  | -579.1054   | .0007747    | 531.4628  | 80.2317  |
| 181.000 | -0.011281 | 3056.6294  | -501.3115   | .0007753    | 527.7883  | 75.3559  |
| 182.000 | -0.010505 | 2523.1918  | -428.4148   | .0007758    | 524.5684  | 70.4376  |
| 183.000 | -0.009729 | 2060.1493  | -360.4574   | .0007763    | 521.7734  | 65.4772  |
| 184.000 | -0.008953 | 1662.5493  | -297.4811   | .0007766    | 519.3734  | 60.4755  |
| 185.000 | -0.008176 | 1325.3968  | -239.5269   | .0007769    | 517.3382  | 55.4320  |
| 186.000 | -0.007399 | 1043.6548  | -186.6357   | .0007771    | 515.6376  | 50.3496  |
| 187.000 | -0.006622 | 812.2447   | -138.8478   | .0007773    | 514.2407  | 45.2262  |
| 188.000 | -0.005844 | 626.0472   | -96.2033    | .0007774    | 513.1168  | 40.0629  |
| 189.000 | -0.005067 | 479.9020   | -58.7418    | .0007775    | 512.2347  | 34.0600  |
| 190.000 | -0.004289 | 368.6008   | -26.5031    | .0007776    | 511.5629  | 28.6175  |
| 191.000 | -0.003512 | 286.9268   | -4.734752   | .0007777    | 511.0698  | 24.3357  |
| 192.000 | -0.002734 | 229.5756   | 22.1486     | .0007777    | 510.7236  | 19.0146  |
| 193.000 | -0.001956 | 191.2352   | 38.4831     | .0007778    | 510.4922  | 13.6543  |
| 194.000 | -0.001178 | 166.5459   | 49.4377     | .0007778    | 510.3432  | 8.2550   |
| 195.000 | -0.000401 | 150.1088   | 54.9734     | .0007778    | 510.2439  | 2.8165   |
| 196.000 | 0.000377  | 136.9545   | 55.0511     | .0007778    | 510.1617  | -2.6611  |
| 197.000 | 0.001155  | 120.1989   | 49.6316     | .0007779    | 510.0634  | -6.1778  |
| 198.000 | 0.001933  | 95.7324    | 38.6760     | .0007779    | 509.9157  | -13.7335 |
| 199.000 | 0.002711  | 57.5300    | 22.1451     | .0007779    | 509.6451  | -19.3283 |
| 200.000 | 0.003489  | 0.0000     | 0.0000      | .0007779    | 509.3379  | -24.9620 |

Output Verification:

Computed forces and moments are within specified convergence limits.

Output Summary for Load Case No. 1:

File-head deflection = 1.00353811 in  
 Computed slope at pile head = -.01682786

Maximum bending moment = 1061686. lbs-in  
 Maximum shear force = 36000.00000 lbs  
 Depth of maximum bending moment = 54.00000000 in  
 Depth of maximum shear force = 0.00000 in  
 Number of iterations = 17  
 Number of zero deflection points = 2

-----  
 Summary of Pile-Head Response(s)  
 -----

Definition of Symbols for Pile-Head Loading Conditions:

Type 1 = Shear and Moment, y = pile-head displacement in  
 Type 2 = Shear and Slope, M = pile-head moment lbs-in  
 Type 3 = Shear and Rot. Stiffness, V = pile-head shear force lbs  
 Type 4 = Deflection and Moment, S = pile-head slope, radians  
 Type 5 = Deflection and Slope, R = rotational stiffness of pile-head in-lbs/rad

| Load Type | Boundary Condition 1 | Boundary Condition 2 | Axial Load lbs | Pile-Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|-----------|----------------------|----------------------|----------------|-------------------------|-----------------------|-------------------|
| 1         | V=                   | M=                   | 90000.0000     | 1.0035                  | 1061686.              | 36000.0000        |

-----  
 File-head Deflection vs. File Length  
 -----

Boundary Condition Type 1, Shear and Moment

Shear = 36000. lbs  
 Moment = 0. in-lbs  
 Axial Load = 90000. lbs

| File Length in | File Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|----------------|-------------------------|-----------------------|-------------------|
| 200.000        | 1.00353811              | 1061686.              | 36000.00000       |
| 190.000        | 1.00340195              | 1061614.              | 36000.00000       |
| 180.000        | 1.00424916              | 1061354.              | 36000.00000       |
| 170.000        | 1.00745220              | 1060347.              | 36008.80000       |
| 160.000        | 1.01674684              | 1057994.              | 36000.00000       |
| 150.000        | 1.03874496              | 1055740.              | 36000.00000       |
| 140.000        | 1.08583995              | 1047774.              | 36000.00000       |
| 130.000        | 1.18347268              | 1042559.              | 36000.00000       |
| 120.000        | 1.39857761              | 1046457.              | 36000.00000       |
| 110.000        | 2.04240645              | 1081494.              | 36000.00000       |

The analysis ended normally.



LPFILE Plus for Windows, Version 5.0 (5.0.11)  
 Analysis of Individual Piles and Drilled Shafts  
 Subjected to Lateral Loading Using the p-y Method  
 (c) Copyright ENSOFT, Inc., 1985-2005  
 All Rights Reserved

This program is licensed to:

Yunwei Zhou  
 Kleinfelder

Path to file locations: U:\Yzhou\Projects\75010\Analysis\LPFILE\B4\  
 Name of input data file: B4p25mm.lpd  
 Name of output file: B4p25mm.lpo  
 Name of plot output file: B4p25mm.lpp  
 Name of runtime file: B4p25mm.lpr

Time and Date of Analysis

Date: May 30, 2007 Time: 12: 4:26

Problem Title

B4, pinned head, 1.0 inch

Program Options

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
 - Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:  
 - Only internally-generated p-y curves used in analysis  
 - Analysis does not use p-y multipliers (individual pile or shaft action only)  
 - Analysis assumes no shear resistance at pile tip  
 - Analysis includes automatic computation of pile-top deflection vs. pile embedment length  
 - No computation of foundation stiffness matrix elements  
 - Output pile response for full length of pile  
 - Analysis assumes no soil movements acting on pile  
 - No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:  
 - Number of pile increments = 200  
 - Maximum number of iterations allowed = 200  
 - Deflection tolerance for convergence = 1.0000E-05 in  
 - Maximum allowable deflection = 1.0000E+01 in

Printing Options:  
 - Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile.  
 - Printing increment (spacing of output points) = 1

Pile Structural Properties and Geometry

Pile Length = 345.00 in  
 Depth of ground surface below top of pile = -99.00 in  
 Slope angle of ground surface = .00 deg.

Structural properties of pile defined using 2 points

| Point | Depth X in | Pile Diameter in | Moment of Inertia in <sup>4</sup> | Pile Area Sq. in | Modulus of Elasticity lbs/Sq. in |
|-------|------------|------------------|-----------------------------------|------------------|----------------------------------|
| 1     | 0.0000     | 15.00000000      | 1242.5000                         | 176.7000         | 4300000.                         |
| 2     | 300.0000   | 15.00000000      | 1242.5000                         | 176.7000         | 4300000.                         |

Soil and Rock Layering Information

The soil profile is modelled using 6 layers

Layer 1 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = -99.000 in  
 Distance from top of pile to bottom of layer = 1.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>\*\*3</sup>  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>\*\*3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 2 is stiff clay without free water  
 Distance from top of pile to top of layer = 1.000 in  
 Distance from top of pile to bottom of layer = 129.000 in

Layer 3 is stiff clay with water-induced erosion  
 Distance from top of pile to top of layer = 129.000 in  
 Distance from top of pile to bottom of layer = 153.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>\*\*3</sup>  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>\*\*3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = 153.000 in  
 Distance from top of pile to bottom of layer = 213.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 213.000 in  
 Distance from top of pile to bottom of layer = 273.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 6 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 273.000 in  
 Distance from top of pile to bottom of layer = 450.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends 105.00 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth is defined using 12 points

| Point No. | Depth X in | EFF. Unit Weight lbs/in**3 |
|-----------|------------|----------------------------|
| 1         | -99.00     | .07234                     |
| 2         | 1.00       | .07234                     |
| 3         | 1.00       | .07234                     |
| 4         | 129.00     | .07234                     |
| 5         | 129.00     | .03623                     |
| 6         | 153.00     | .03623                     |
| 7         | 153.00     | .03623                     |
| 8         | 213.00     | .03623                     |
| 9         | 213.00     | .03333                     |
| 10        | 273.00     | .03333                     |
| 11        | 273.00     | .03623                     |
| 12        | 450.00     | .03623                     |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth defined using 12 points

| Point No. | Depth X in | Cohesion c lbs/in**2 | Angle of Friction Deg. | E50 or k <sub>vm</sub> | RQD % |
|-----------|------------|----------------------|------------------------|------------------------|-------|
| 1         | -99.000    | .00000               | 30.00                  | -----                  | ----- |
| 2         | 1.000      | .00000               | 30.00                  | -----                  | ----- |
| 3         | 1.000      | 6.25000              | .00                    | -----                  | ----- |
| 4         | 129.000    | 6.25000              | .00                    | -----                  | ----- |
| 5         | 129.000    | 6.25000              | .00                    | -----                  | ----- |
| 6         | 153.000    | 6.25000              | .00                    | -----                  | ----- |
| 7         | 153.000    | .00000               | 30.00                  | -----                  | ----- |
| 8         | 213.000    | .00000               | 30.00                  | -----                  | ----- |
| 9         | 213.000    | 5.56000              | 25.00                  | -----                  | ----- |
| 10        | 273.000    | 5.56000              | 25.00                  | -----                  | ----- |
| 11        | 273.000    | 3.47000              | 32.00                  | -----                  | ----- |
| 12        | 450.000    | 3.47000              | 32.00                  | -----                  | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k<sub>vm</sub> are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 File-head Loading and File-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number 1

File-head boundary conditions are Displacement and Moment (BC Type 4)  
 Deflection at pile head = 1.000 in  
 Bending moment at pile head = .000 in-lbs  
 Axial load at pile head = 90000.000 lbr





Number of iterations = 17  
 Number of zero deflection points = 3

-----  
 Summary of File-Head Response(s)  
 -----

Definition of Symbols for File-Head Loading Conditions:

Type 1 = Shear and Moment, y = pile-head displacement in  
 Type 2 = Shear and Slope, M = pile-head moment lbs-in  
 Type 3 = Shear and Rot. Stiffness, V = pile-head shear force lbs  
 Type 4 = Deflection and Moment, S = pile-head slope, radians  
 Type 5 = Deflection and Slope, R = rotational stiffness of pile-head in-lbs/rad

| Load Type | Boundary Condition | Boundary Condition | Axial Load lbs | File-Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|-----------|--------------------|--------------------|----------------|-------------------------|-----------------------|-------------------|
|           | 1                  | 2                  |                |                         |                       |                   |
| 4         | y = 1.000000       | M = 0.000          | 90000.0000     | 1.0000000               | 844828.               | 28133.4062        |

-----  
 File-head Deflection vs. File Length  
 -----

Boundary Condition Type 4, Deflection and Moment

Deflection = 1.00000 in  
 Moment = 0. in-lbs  
 Axial Load = 90000. lbs

| File Length in | File Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|----------------|-------------------------|-----------------------|-------------------|
| 345.000        | 1.00000000              | 844828.18392          | 28133.40424       |
| 327.750        | 1.00000000              | 844717.53429          | 28092.44897       |
| 310.500        | 1.00000000              | 844793.31842          | 28053.24620       |
| 293.250        | 1.00000000              | 844686.85328          | 28012.88657       |
| 276.000        | 1.00000000              | 844445.37175          | 27967.89215       |
| 258.750        | 1.00000000              | 844623.39866          | 27930.05674       |
| 241.500        | 1.00000000              | 843558.96760          | 27874.42019       |
| 224.250        | 1.00000000              | 842464.77423          | 27817.21962       |
| 207.000        | 1.00000000              | 842251.10934          | 27772.73552       |
| 189.750        | 1.00000000              | 839280.06162          | 28580.63292       |

The analysis ended normally.

LPILE Plus for Windows, Version 5.0 (5.0.11)  
 Analysis of Individual Piles and Drilled Shafts  
 Subjected to Lateral Loading Using the p-y Method  
 (c) Copyright ENSOFT, Inc., 1985-2005  
 All Rights Reserved

This program is licensed to:

Yousui Zhou  
 Kleinfelder

Path to file locations: U:\Yzhou\Projects\75010\Analysis\LPILE\04\  
 Name of input data file: B4p6mm.lpd  
 Name of output file: B4p6mm.lpo  
 Name of plot output file: B4p6mm.lpp  
 Name of runtime file: B4p6mm.lpr

-----  
 Time and Date of Analysis  
 -----

Date: May 17, 2007 Time: 7:26:27

-----  
 Problem Title  
 -----

B4, pinned head, 0.25 inch

-----  
 Program Options  
 -----

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
 - Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:

- Only internally-generated p-y curves used in analysis
- Analysis does not use p-y multipliers (individual pile or shaft action only)
- Analysis assumes no shear resistance at pile tip
- Analysis includes automatic computation of pile-top deflection vs. pile embedment length
- No computation of foundation stiffness matrix elements
- Output pile response for full length of pile
- Analysis assumes no soil movements acting on pile
- No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:

- Number of pile increments = 200
- Maximum number of iterations allowed = 200
- Deflection tolerance for convergence = 1.0000E-05 in
- Maximum allowable deflection = 1.0000E+01 in

Printing Options:

- Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile.
- Printing increment (spacing of output points) = 1

-----  
 File Structural Properties and Geometry  
 -----

File length = 345.00 in  
 Depth of ground surface below top of pile = -99.00 in  
 Slope angle of ground surface = .00 deg.

Structural properties of pile defined using 2 points

| Point | Depth<br>X<br>in | Pile<br>Diameter<br>in | Moment of<br>Inertia<br>in**4 | Pile<br>Area<br>Sq.in | Modulus of<br>Elasticity<br>lbs/Sq.in |
|-------|------------------|------------------------|-------------------------------|-----------------------|---------------------------------------|
| 1     | 0.0000           | 15.00000000            | 2485.0000                     | 176.7000              | 4300000.                              |
| 2     | 500.0000         | 15.00000000            | 2485.0000                     | 176.7000              | 4300000.                              |

-----  
 Soil and Rock Layering Information  
 -----

The soil profile is modelled using 6 layers

Layer 1 is sand, p-y criteria by Reese et al., 1974

Distance from top of pile to top of layer = -99.000 in  
 Distance from top of pile to bottom of layer = 81.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 2 is stiff clay without free water

Distance from top of pile to top of layer = 81.000 in  
 Distance from top of pile to bottom of layer = 129.000 in

Layer 3 is stiff clay with water-induced erosion

Distance from top of pile to top of layer = 129.000 in  
 Distance from top of pile to bottom of layer = 153.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = 151.000 in  
 Distance from top of pile to bottom of layer = 213.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 213.000 in  
 Distance from top of pile to bottom of layer = 273.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 6 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 273.000 in  
 Distance from top of pile to bottom of layer = 450.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends 105.00 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth is defined using 12 points

| Point No. | Depth X in | Eff. Unit Weight lbs/in**3 |
|-----------|------------|----------------------------|
| 1         | -99.00     | .07234                     |
| 2         | 81.00      | .07234                     |
| 3         | 81.00      | .07234                     |
| 4         | 129.00     | .07234                     |
| 5         | 129.00     | .03623                     |
| 6         | 153.00     | .03623                     |
| 7         | 153.00     | .03623                     |
| 8         | 213.00     | .03623                     |
| 9         | 213.00     | .03333                     |
| 10        | 273.00     | .03333                     |
| 11        | 273.00     | .03623                     |
| 12        | 450.00     | .03623                     |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth defined using 12 points

| Point No. | Depth X in | Cohesion c lbs/in**2 | Angle of Friction Deg. | E50 or k <sub>sm</sub> | RQD % |
|-----------|------------|----------------------|------------------------|------------------------|-------|
| 1         | -99.000    | .00000               | 30.00                  | -----                  | ----- |
| 2         | 81.000     | .00000               | 30.00                  | -----                  | ----- |
| 3         | 81.000     | 6.25000              | .00                    | -----                  | ----- |
| 4         | 129.000    | 6.25000              | .00                    | -----                  | ----- |
| 5         | 129.000    | 6.25000              | .00                    | -----                  | ----- |
| 6         | 153.000    | 6.25000              | .00                    | -----                  | ----- |
| 7         | 153.000    | .00000               | 30.00                  | -----                  | ----- |
| 8         | 213.000    | .00000               | 30.00                  | -----                  | ----- |
| 9         | 213.000    | 1.56000              | 25.00                  | -----                  | ----- |
| 10        | 273.000    | 1.56000              | 25.00                  | -----                  | ----- |
| 11        | 273.000    | 3.47000              | 32.00                  | -----                  | ----- |
| 12        | 450.000    | 3.47000              | 32.00                  | -----                  | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k<sub>sm</sub> are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 File-head Loading and File-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number 1

File-head boundary conditions are Displacement and Moment (BC Type 4)  
 Deflection at pile head = .250 in  
 Bending moment at pile head = .000 in-lbs  
 Axial load at pile head = 90000.000 lbs







Number of iterations = 13  
 Number of zero deflection points = 3

-----  
 Summary of File-Head Response(s)  
 -----

Definition of Symbols for File-Head Loading Conditions:

Type 1 = Shear and Moment, y = pile-head diaplement in  
 Type 2 = Shear and Slope, M = pile-head moment lbs-in  
 Type 3 = Shear and Rot. Stiffness, V = pile-head shear force lbs  
 Type 4 = Deflection and Moment, S = pile-head slope, radians  
 Type 5 = Deflection and Slope, R = rotational stiffness of pile-head-in-lbs/rad

| Load Type | Boundary Condition 1 | Boundary Condition 2 | Axial Load lbs | Pile-Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|-----------|----------------------|----------------------|----------------|-------------------------|-----------------------|-------------------|
| 4         | y = .250000          | M = 0.000            | 90000.0000     | .2500000                | 506157.               | 22781.1370        |

-----  
 File-head Deflection vs. File Length  
 -----

Boundary Condition Type 4, Deflection and Moment

Deflection = .25000 in  
 Moment = 0 in-lbs  
 Axial Load = 90000. lbs

| File Length in | File Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|----------------|-------------------------|-----------------------|-------------------|
| 345.000        | .25000000               | 506156.50279          | 22781.13698       |
| 327.750        | .25000000               | 505711.03572          | 22776.28861       |
| 310.500        | .25000000               | 50522.48603           | 22774.02121       |
| 293.250        | .25000000               | 50550.42774           | 22773.08545       |
| 276.000        | .25000000               | 505940.29583          | 22776.99170       |
| 258.750        | .25000000               | 505773.13452          | 22775.76194       |
| 241.500        | .25000000               | 504926.69830          | 22762.39176       |
| 224.250        | .25000000               | 504822.45315          | 22759.35624       |
| 207.000        | .25000000               | 504661.32033          | 22755.94780       |
| 189.750        | .25000000               | 504140.55078          | 22748.63390       |

The analysis ended normally.

LPFILE Plus for Windows, Version 5.0 (5.0.11)

Analysis of Individual Piles and Drilled Shafts  
Subjected to Lateral Loading Using the p-y Method

(c) Copyright EMSOFT, Inc., 1985-2005  
All Rights Reserved

This program is licensed to:

Youwei Zhou  
Kleifelder

Path to file locations: U:\YZhou\Projects\75010\Analysis\LPFILEB4\  
Name of input data file: B4f25mm.lpd  
Name of output file: B4f25mm.lpo  
Name of plot output file: B4f25mm.lpp  
Name of runtime file: B4f25mm.lpr

Time and Date of Analysis

Date: May 30, 2007 Time: 13: 8:31

Problem Title

B4, fixed head, 1.0 inch

Program Options

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
- Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:

- Only internally-generated p-y curves used in analysis
- Analysis does not use p-y multipliers (individual pile or shaft action only)
- Analysis assumes no shear resistance at pile tip
- Analysis includes automatic computation of pile-top deflection vs. pile embedment length
- No computation of foundation stiffness matrix elements
- Output pile response for full length of pile
- Analysis assumes no soil movements acting on pile
- No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:

- Number of pile increments = 200
- Maximum number of iterations allowed = 200
- Deflection tolerance for convergence = 1.0000E-05 in
- Maximum allowable deflection = 1.0000E+01 in

Printing Options:

- Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile.
- Printing Increment (spacing of output points) = 1

Pile Structural Properties and Geometry

File Length = 345.00 in  
Depth of ground surface below top of pile = -99.00 in  
Slope angle of ground surface = .00 deg.

Structural properties of pile defined using 2 points

| Point | Depth<br>X<br>in | Pile<br>Diameter<br>in | Moment of<br>Inertia<br>in**4 | Pile<br>Area<br>Sq.in | Modulus of<br>Elasticity<br>lbs/Sq.in |
|-------|------------------|------------------------|-------------------------------|-----------------------|---------------------------------------|
| 1     | 0.0000           | 15.00000000            | 1242.5000                     | 176.7000              | 4300000.                              |
| 2     | 500.0000         | 15.00000000            | 1242.5000                     | 176.7000              | 4300000.                              |

Soil and Rock Layering Information

The soil profile is modelled using 6 layers

Layer 1 is sand, p-y criteria by Reese et al., 1974

Distance from top of pile to top of layer = -99.000 in  
Distance from top of pile to bottom of layer = .100 in  
p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 2 is stiff clay without free water

Distance from top of pile to top of layer = .100 in  
Distance from top of pile to bottom of layer = 129.000 in

Layer 3 is stiff clay with water-induced erosion

Distance from top of pile to top of layer = 129.000 in  
Distance from top of pile to bottom of layer = 153.000 in  
p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = 153.000 in  
 Distance from top of pile to bottom of layer = 213.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 213.000 in  
 Distance from top of pile to bottom of layer = 273.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 6 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 273.000 in  
 Distance from top of pile to bottom of layer = 450.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends, 105.00 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth is defined using 12 points

| Point No. | Depth X in | Eff. Unit Weight lbs/in**3 |
|-----------|------------|----------------------------|
| 1         | -99.00     | .07234                     |
| 2         | .10        | .07234                     |
| 3         | .10        | .07234                     |
| 4         | 129.00     | .07234                     |
| 5         | 129.00     | .03623                     |
| 6         | 153.00     | .03623                     |
| 7         | 153.00     | .03623                     |
| 8         | 213.00     | .03623                     |
| 9         | 213.00     | .03333                     |
| 10        | 273.00     | .03333                     |
| 11        | 273.00     | .03623                     |
| 12        | 450.00     | .03623                     |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth defined using 12 points

| Point No. | Depth X in | Cohesion c lbs/in**2 | Angle of Friction Deg. | E50 or k <sub>sm</sub> | RQD % |
|-----------|------------|----------------------|------------------------|------------------------|-------|
| 1         | -99.000    | .00000               | 30.00                  | -----                  | ----- |
| 2         | .100       | .00000               | 30.00                  | -----                  | ----- |
| 3         | .100       | 6.25000              | .00                    | -----                  | ----- |
| 4         | 129.000    | 6.25000              | .00                    | -----                  | ----- |
| 5         | 129.000    | 6.25000              | .00                    | -----                  | ----- |
| 6         | 153.000    | 6.25000              | .00                    | -----                  | ----- |
| 7         | 153.000    | .00000               | 30.00                  | -----                  | ----- |
| 8         | 213.000    | .00000               | 30.00                  | -----                  | ----- |
| 9         | 213.000    | 5.56000              | 25.00                  | -----                  | ----- |
| 10        | 273.000    | 5.56000              | 25.00                  | -----                  | ----- |
| 11        | 273.000    | 3.47000              | 32.00                  | -----                  | ----- |
| 12        | 450.000    | 3.47000              | 32.00                  | -----                  | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k<sub>sm</sub> are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 File-head Loading and File-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number 1

File-head boundary conditions are Displacement and Slope (BC Type 5)  
 Deflection at pile head = 1.000 in  
 Slope at pile head = .000 in/in  
 Axial load at pile head = 90000.000 lbs





Number of iterations = 16  
 Number of zero deflection points = 3

-----  
 Summary of Pile-Head Response(s)  
 -----

Definition of Symbols for Pile-Head Loading Conditions:

Type 1 = Shear and Moment,      y = pile-head displacement in  
 Type 2 = Shear and Slope,      M = pile-head moment lbs-in  
 Type 3 = Shear and Rot. Stiffness, V = pile-head shear force lbs  
 Type 4 = Deflection and Moment,      S = pile-head slope, radians  
 Type 5 = Deflection and Slope,      R = rotational stiffness of pile-head-in-lbs/rad

| Load Type | Boundary Condition | Boundary Condition | Axial Load | Pile-Head Deflection | Maximum Moment | Maximum Shear |
|-----------|--------------------|--------------------|------------|----------------------|----------------|---------------|
|           | 1                  | 2                  | lbs        | in                   | in-lbs         | lbs           |
| 5         | y = 1.000000       | S = 0.000          | 90000.0000 | 1.0000000            | -2126970.      | 51146.4631    |

-----  
 Pile-head Deflection vs. Pile Length  
 -----

Boundary Condition Type 5, Deflection and Slope

Deflection = 1.00000 in  
 Slope = .00000  
 Axial Load = 90000. lbs

| File Length | Pile Head Deflection | Maximum Moment | Maximum Shear |
|-------------|----------------------|----------------|---------------|
| in          | in                   | in-lbs         | lbs           |
| 343.000     | 1.00000000           | -2126970.      | 51146.46310   |
| 327.750     | 1.00000000           | -2127039.      | 51148.55496   |
| 310.500     | 1.00000000           | -2126453.      | 51136.30897   |
| 293.250     | 1.00000000           | -2127187.      | 51148.33779   |
| 276.000     | 1.00000000           | -2126763.      | 51140.74419   |
| 258.750     | 1.00000000           | -2126701.      | 51135.49792   |
| 241.500     | 1.00000000           | -2126923.      | 51125.12334   |
| 224.250     | 1.00000000           | -2127021.      | 51121.61796   |
| 207.000     | 1.00000000           | -2097769.      | 50568.47469   |
| 189.750     | 1.00000000           | -2053189.      | 49669.05261   |

The analysis ended normally.

LPFILE Plus for Windows, Version 5.0 (5.0.11)  
 Analysis of Individual Piles and Drilled Shafts  
 Subjected to Lateral Loading Using the p-y Method  
 (c) Copyright ENSOFF, Inc., 1985-2005  
 All Rights Reserved

This program is licensed to:

Yeuwei Zhou  
 Kleinfelder

Path to file locations: U:\Yzhou\Projects\75010\Analysis\LPFILE\B4\  
 Name of input data file: B4f6mm.lpd  
 Name of output file: B4f6mm.lpo  
 Name of plot output file: B4f6mm.lpp  
 Name of runtime file: B4f6mm.lpr

-----  
 Time and Date of Analysis  
 -----

Date: May 30, 2007 Time: 13: 7:19

-----  
 Problem Title  
 -----

B4, fixed head, 0.25 inch

-----  
 Program Options  
 -----

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
 - Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:

- Only internally-generated p-y curves used in analysis
- Analysis does not use p-y multipliers (individual pile or shaft action only)
- Analysis assumes no shear resistance at pile tip
- Analysis includes automatic computation of pile-top deflection vs. pile embedment length
- No computation of foundation stiffness matrix elements
- Output pile response for full length of pile
- Analysis assumes no soil movements acting on pile
- No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:

- Number of pile increments = 200
- Maximum number of iterations allowed = 200
- Deflection tolerance for convergence = 1.0000E-05 in
- Maximum allowable deflection = 1.0000E+01 in

Printing Options:

- Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile.
- Printing increment (spacing of output points) = 1

-----  
 Pile Structural Properties and Geometry  
 -----

Pile Length = 345.00 in  
 Depth of ground surface below top of pile = -99.00 in  
 Slope angle of ground surface = .00 deg.

Structural properties of pile defined using 2 points

| Point | Depth<br>X<br>in | Pile<br>Diameter<br>in | Moment of<br>Inertia<br>in <sup>4</sup> | Pile<br>Area<br>Sq.in | Modulus of<br>Elasticity<br>lbs/Sq.in |
|-------|------------------|------------------------|---|-----------------------|---------------------------------------|
| 1     | 0.0000           | 15.00000000            | 2485.0000                               | 176.7000              | 4300000.                              |
| 2     | 500.0000         | 15.00000000            | 2485.0000                               | 176.7000              | 4300000.                              |

-----  
 Soil and Rock Layering Information  
 -----

The soil profile is modelled using 6 layers

Layer 1 is sand, p-y criteria by Reese et al., 1974

Distance from top of pile to top of layer = -99.000 in  
 Distance from top of pile to bottom of layer = 81.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 2 is stiff clay without free water

Distance from top of pile to top of layer = 81.000 in  
 Distance from top of pile to bottom of layer = 129.000 in

Layer 3 is stiff clay with water-induced expansion

Distance from top of pile to top of layer = 129.000 in  
 Distance from top of pile to bottom of layer = 153.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3



NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = 153.000 in  
 Distance from top of pile to bottom of layer = 213.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 213.000 in  
 Distance from top of pile to bottom of layer = 273.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 6 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 273.000 in  
 Distance from top of pile to bottom of layer = 450.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends 105.00 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth is defined using 12 points

| Point No. | Depth X in | Eff. Unit Weight lbs/in**3 |
|-----------|------------|----------------------------|
| 1         | -99.00     | .07234                     |
| 2         | 81.00      | .07234                     |
| 3         | 81.00      | .07234                     |
| 4         | 129.00     | .07234                     |
| 5         | 129.00     | .03623                     |
| 6         | 153.00     | .03623                     |
| 7         | 153.00     | .03623                     |
| 8         | 213.00     | .03623                     |
| 9         | 213.00     | .03323                     |
| 10        | 273.00     | .03323                     |
| 11        | 273.00     | .03623                     |
| 12        | 450.00     | .03623                     |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth defined using 12 points

| Point No. | Depth X in | Cohesion c lbs/in**2 | Angle of Friction Deg. | E50 or k <sub>zm</sub> | RQD t |
|-----------|------------|----------------------|------------------------|------------------------|-------|
| 1         | -99.000    | .00000               | 30.00                  | -----                  | ----- |
| 2         | 81.000     | .00000               | 30.00                  | -----                  | ----- |
| 3         | 81.000     | 6.25000              | .00                    | -----                  | ----- |
| 4         | 129.000    | 6.25000              | .00                    | -----                  | ----- |
| 5         | 129.000    | 6.25000              | .00                    | -----                  | ----- |
| 6         | 153.000    | 6.25000              | .00                    | -----                  | ----- |
| 7         | 153.000    | .00000               | 30.00                  | -----                  | ----- |
| 8         | 213.000    | .00000               | 30.00                  | -----                  | ----- |
| 9         | 213.000    | 3.56000              | 25.00                  | -----                  | ----- |
| 10        | 273.000    | 5.56000              | 25.00                  | -----                  | ----- |
| 11        | 273.000    | 3.47000              | 32.00                  | -----                  | ----- |
| 12        | 450.000    | 3.47000              | 32.00                  | -----                  | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k<sub>zm</sub> are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 Pile-head Loading and Pile-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number 1

Pile-head boundary conditions are Displacement and Slope (BC Type 5)  
 Deflection at pile head = .250 in  
 Slope at pile head = .000 in/in  
 Axial load at pile head = 30000.000 lbs



Table with 7 columns of numerical data representing structural analysis results for various load cases and components.

Output Verification:

Computed forces and moments are within specified convergence limits.

Output Summary for Load Case No. 1:

Summary table with 2 columns: Description and Value. Includes metrics like File-head deflection, Computed slope at pile head, Maximum bending moment, etc.

Number of iterations = 13  
 Number of zero deflection points = 3

-----  
 Summary of Pile-Head Response(s)  
 -----

Definition of Symbols for Pile-Head Loading Conditions:

Type 1 = Shear and Moment, y = pile-head displacement in  
 Type 2 = Shear and Slope, M = pile-head moment lbs-in  
 Type 3 = Shear and Rot. Stiffness, V = pile-head shear force lbs  
 Type 4 = Deflection and Moment, s = pile-head slope, radians  
 Type 5 = Deflection and Slope, R = rotational stiffness of pile-head-in-lbs/rad

| Load Type | Boundary Condition 1 | Boundary Condition 2 | Axial Load lbs | Pile-Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|-----------|----------------------|----------------------|----------------|-------------------------|-----------------------|-------------------|
| 5         | y = .250000          | s = 0.000            | 90000.0000     | .2500000                | -1560228.             | 48517.7454        |

-----  
 File-head Deflection vs. Pile Length  
 -----

Boundary Condition Type 5, Deflection and Slope

Deflection = .25000 in  
 Slope = .00000  
 Axial Load = 90000. lbs

| Pile Length in | Pile Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|----------------|-------------------------|-----------------------|-------------------|
| 345.000        | .25000000               | -1560228.             | 48517.74525       |
| 327.750        | .25000000               | -1560709.             | 48599.03100       |
| 310.500        | .25000000               | -1561022.             | 48530.89410       |
| 293.250        | .25000000               | -1560720.             | 48528.40979       |
| 276.000        | .25000000               | -1560758.             | 48523.33820       |
| 258.750        | .25000000               | -1560541.             | 48518.65467       |
| 241.500        | .25000000               | -1560608.             | 48508.59658       |
| 224.250        | .25000000               | -1560650.             | 48502.96046       |
| 207.000        | .25000000               | -1544713.             | 48395.47270       |
| 189.750        | .25000000               | -1544865.             | 48187.94625       |

The analysis ended normally.

LPILE Plus for Windows, Version 5.0 (5.0.11)

Analysis of Individual Piles and Drilled Shafts  
Subjected to Lateral Loading Using the p-y Method

(c) Copyright ENSOFT, Inc., 1985-2005  
All Rights Reserved

This program is licensed to:

Youwei Zhou  
Kieifelder

Path to file locations: U:\Yzhou\Projects\75010\Analysis\LPILE\B4\  
Name of input data file: B4stability.lpd  
Name of output file: B4stability.lpo  
Name of plot output file: B4stability.lpp  
Name of runtime file: B4stability.lpr

Time and Date of Analysis

Date: May 30, 2007 Time: 13: 6:10

Problem Title

B4 Stability

Program Options

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
- Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:  
- Only internally-generated p-y curves used in analysis  
- Analysis does not use p-y multipliers (individual pile or shaft section only)  
- Analysis assumes no shear resistance at pile tip  
- Analysis includes automatic computation of pile-top deflection vs. pile embedment length  
- No computation of foundation stiffness matrix elements  
- Output pile response for full length of pile  
- Analysis assumes no soil movements acting on pile  
- No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:  
- Number of pile increments = 200  
- Maximum number of iterations allowed = 200  
- Deflection tolerance for convergence = 1.0000E-05 in  
- Maximum allowable deflection = 1.0000E+01 in

Printing Options:  
- Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile.  
- Printing increment (spacing of output points) = 1

Pile Structural Properties and Geometry

Pile length = 210.00 in  
Depth of ground surface below top of pile = -99.00 in  
Slope angle of ground surface = .00 deg.

Structural properties of pile defined using 2 points

| Point | Depth X in | Pile Diameter in | Moment of Inertia in <sup>4</sup> | Pile Area Sq.in | Modulus of Elasticity lbs/Sq.in |
|-------|------------|------------------|-----------------------------------|-----------------|---------------------------------|
| 1     | 0.0000     | 15.00000000      | 1242.5000                         | 176.7000        | 4300000.                        |
| 2     | 500.0000   | 15.00000000      | 1242.5000                         | 176.7000        | 4300000.                        |

Soil and Rock Layering Information

The soil profile is modelled using 6 layers

Layer 1 is sand, p-y criteria by Reese et al., 1974  
Distance from top of pile to top of layer = -99.000 in  
Distance from top of pile to bottom of layer = 81.000 in  
p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 2 is stiff clay without free water  
Distance from top of pile to top of layer = 81.000 in  
Distance from top of pile to bottom of layer = 129.000 in

Layer 3 is stiff clay with water-induced erosion  
Distance from top of pile to top of layer = 129.000 in  
Distance from top of pile to bottom of layer = 153.000 in  
p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = 153.000 in  
 Distance from top of pile to bottom of layer = 213.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 213.000 in  
 Distance from top of pile to bottom of layer = 273.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 6 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 273.000 in  
 Distance from top of pile to bottom of layer = 450.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends 240.00 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth is defined using 12 points

| Point No. | Depth X in | Eff. Unit Weight lbs/in**3 |
|-----------|------------|----------------------------|
| 1         | -99.00     | .07234                     |
| 2         | 81.00      | .07234                     |
| 3         | 81.00      | .07234                     |
| 4         | 129.00     | .07234                     |
| 5         | 129.00     | .03623                     |
| 6         | 153.00     | .03623                     |
| 7         | 153.00     | .03623                     |
| 8         | 213.00     | .03623                     |
| 9         | 213.00     | .03333                     |
| 10        | 273.00     | .03333                     |
| 11        | 273.00     | .03623                     |
| 12        | 450.00     | .03623                     |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth defined using 12 points

| Point No. | Depth X in | Cohesion c lbs/in**2 | Angle of Friction Deg. | E50 or k <sub>em</sub> | RQD % |
|-----------|------------|----------------------|------------------------|------------------------|-------|
| 1         | -99.000    | .00000               | 30.00                  | -----                  | ----- |
| 2         | 81.000     | .00000               | 30.00                  | -----                  | ----- |
| 3         | 81.000     | 6.25000              | .00                    | -----                  | ----- |
| 4         | 129.000    | 6.25000              | .00                    | -----                  | ----- |
| 5         | 129.000    | 6.25000              | .00                    | -----                  | ----- |
| 6         | 153.000    | 6.25000              | .90                    | -----                  | ----- |
| 7         | 153.000    | .00000               | 30.00                  | -----                  | ----- |
| 8         | 213.000    | .00000               | 30.00                  | -----                  | ----- |
| 9         | 213.000    | 5.56000              | 25.00                  | -----                  | ----- |
| 10        | 273.000    | 5.56000              | 25.00                  | -----                  | ----- |
| 11        | 273.000    | 3.47000              | 32.00                  | -----                  | ----- |
| 12        | 450.000    | 3.47000              | 32.00                  | -----                  | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k<sub>em</sub> are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 File-head Loading and File-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number 1

File-head boundary conditions are Shear and Moment (BC Type 1)  
 Shear force at pile head = 65700.000 lbs  
 Bending moment at pile head = .000 in-lbs  
 Axial load at pile head = 90000.000 lbs

(Zero moment at pile head for this load indicates a free-head condition)







File: U:\Yzhou\Projects\75010\Analysis\Appendix C\16 Bstability.lpo

Maximum bending moment = 1353946. lbs-in  
 Maximum shear force = 65700.00000 lbs  
 Depth of maximum bending moment = 42.00000000 in  
 Depth of maximum shear force = 0.00000 in  
 Number of iterations = 17  
 Number of zero deflection points = 2

-----  
 Summary of File-Head Response(s)  
 -----

Definition of Symbols for File-Head Loading Conditions:

Type 1 = Shear and Moment, y = pile-head displacement in  
 Type 2 = Shear and Slope, M = pile-head moment lbs-in  
 Type 3 = Shear and Rot. Stiffness, V = pile-head shear force lbs  
 Type 4 = Deflection and Moment, S = pile-head slope, radians  
 Type 5 = Deflection and Slope, R = rotational stiffness of pile-head-in-lbs/rad

| Load Type | Boundary Condition | Boundary Condition | Axial Load lbs | Pile-Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs   |
|-----------|--------------------|--------------------|----------------|-------------------------|-----------------------|---------------------|
|           | 1                  | 2                  |                |                         |                       |                     |
| 1         | V=                 | M=                 | 0.000          | 90000.0000              | 1.0015                | 1353946. 65700.0000 |

-----  
 File-head Deflection vs. File Length  
 -----

Boundary Condition Type 1, Shear and Moment

Shear = 65700. lbs  
 Moment = 0. in-lbs  
 Axial Load = 90000. lbs

| File Length in | File Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|----------------|-------------------------|-----------------------|-------------------|
| 210.000        | 1.00150054              | 1353946.              | 65700.00000       |
| 199.500        | 1.00179991              | 1353958.              | 65700.00000       |
| 189.000        | 1.00186123              | 1354030.              | 65700.00000       |
| 178.500        | 1.00181363              | 1353976.              | 65700.00000       |
| 168.000        | 1.00257669              | 1353228.              | 65700.00000       |
| 157.500        | 1.00760165              | 1350315.              | 65700.00000       |
| 147.000        | 1.03259069              | 1339066.              | 65700.00000       |
| 136.500        | 1.14502336              | 1311230.              | 65700.00000       |
| 126.000        | 1.40282097              | 1295321.              | 65700.00000       |
| 115.500        | 1.77128828              | 1308083.              | 65700.00000       |

The analysis ended normally.

LPFILE Plus for Windows, Version 5.0 (5.0.11)  
 Analysis of Individual Piles and Drilled Shafts  
 Subjected to Lateral Loading Using the p-y Method

(c) Copyright ENSOFT, Inc., 1985-2005  
 All Rights Reserved

This program is licensed to:

Youwei Zhou  
 Kleinfelder

Path to file locations: U:\Yzhou\Projects\75010\Analysis\LPFILE\B2B3\  
 Name of input data file: B2p25mm.lpd  
 Name of output file: B2p25mm.lpo  
 Name of plot output file: B2p25mm.lpp  
 Name of runtime file: B2p25mm.lpr

Time and Date of Analysis

Date: May 30, 2007 Time: 13:22:55

Problem Title

B2-B3, pinned head, 1 in

Program Options

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
 - Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:  
 - Only internally-generated p-y curves used in analysis  
 - Analysis does not use p-y multipliers (individual pile or shaft action only)  
 - Analysis assumes no shear resistance at pile tip  
 - Analysis includes automatic computation of pile-top deflection wr.  
 pile embedment length  
 - No computation of foundation stiffness matrix elements  
 - Output pile response for full length of pile  
 - Analysis assumes no soil movements acting on pile  
 - No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:  
 - Number of pile increments = 200  
 - Maximum number of iterations allowed = 200  
 - Deflection tolerance for convergence = 1.0000E-05 in  
 - Maximum allowable deflection = 1.0000E+01 in

Printing Options:  
 - Values of pile-head deflection, bending moment, shear force, and  
 soil reaction are printed for full length of pile  
 - Printing increment (spacing of output points) = 1

Pile Structural Properties and Geometry

Pile Length = 345.00 in  
 Depth of ground surface below top of pile = -99.00 in  
 Slope angle of ground surface = .00 deg.

Structural properties of pile defined using 2 points

| Point | Depth<br>X<br>in | Pile<br>Diameter<br>in | Moment of<br>Inertia<br>in <sup>4</sup> | Pile<br>Area<br>Sq.in | Modulus of<br>Elasticity<br>lbs/Sq.in |
|-------|------------------|------------------------|---|-----------------------|---------------------------------------|
| 1     | 0.0000           | 15.00000000            | 1242.5000                               | 176.7000              | 4300000.                              |
| 2     | 300.0000         | 15.00000000            | 1242.5000                               | 176.7000              | 4300000.                              |

Soil and Rock Layering Information

The soil profile is modelled using 5 layers

Layer 1 is stiff clay without free water  
 Distance from top of pile to top of layer = -99.000 in  
 Distance from top of pile to bottom of layer = 129.000 in

Layer 2 is stiff clay with water-induced erosion  
 Distance from top of pile to top of layer = 129.000 in  
 Distance from top of pile to bottom of layer = 153.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 3 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = 153.000 in  
 Distance from top of pile to bottom of layer = 213.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 213.000 in  
 Distance from top of pile to bottom of layer = 273.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 273.000 in  
 Distance from top of pile to bottom of layer = 450.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends 105.00 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth is defined using 10 points

| Point No. | Depth X in | Eff. Unit Weight lbs/in**3 |
|-----------|------------|----------------------------|
| 1         | -99.00     | .07234                     |
| 2         | 129.00     | .07234                     |
| 3         | 129.00     | .03623                     |
| 4         | 153.00     | .03623                     |
| 5         | 153.00     | .03623                     |
| 6         | 213.00     | .03623                     |
| 7         | 213.00     | .03333                     |
| 8         | 273.00     | .03333                     |
| 9         | 273.00     | .03622                     |
| 10        | 450.00     | .03622                     |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth defined using 10 points

| Point No. | Depth X in | Cohesion c lbs/in**2 | Angle of Friction Deg. | E50 or k <sub>rm</sub> | RQD % |
|-----------|------------|----------------------|------------------------|------------------------|-------|
| 1         | -99.000    | 6.25000              | .00                    | -----                  | ----- |
| 2         | 129.000    | 6.25000              | .00                    | -----                  | ----- |
| 3         | 129.000    | 6.25000              | .00                    | -----                  | ----- |
| 4         | 153.000    | 6.25000              | .00                    | -----                  | ----- |
| 5         | 153.000    | .00000               | 30.00                  | -----                  | ----- |
| 6         | 213.000    | .00000               | 30.00                  | -----                  | ----- |
| 7         | 213.000    | 5.56000              | 25.00                  | -----                  | ----- |
| 8         | 273.000    | 5.56000              | 25.00                  | -----                  | ----- |
| 9         | 273.000    | 3.47000              | 32.00                  | -----                  | ----- |
| 10        | 450.000    | 3.47000              | 32.00                  | -----                  | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k<sub>rm</sub> are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 Pile-head Loading and Pile-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number 1

Pile-head boundary conditions are Displacement and Moment (BC Type 4)  
 Deflection at pile head = 1.000 in  
 Bending moment at pile head = .000 in-lbs  
 Axial load at pile head = 90000.000 lbs

-----  
 Computed Values of Load Distribution and Deflection for Lateral Loading for Load Case Number 1  
 -----

Pile-head boundary conditions are Displacement and Moment (BC Type 4)  
 Specified deflection at pile head = 1.000000 in  
 Specified moment at pile head = .000 in-lbs  
 Specified axial load at pile head = 90000.000 lbs

| Depth X | Deflect. y | Moment M | Shear V | Slope S | Total Stress | Soil Res p |
|---------|------------|----------|---------|---------|--------------|------------|
|---------|------------|----------|---------|---------|--------------|------------|



|         |           |             |            |          |          |          |
|---------|-----------|-------------|------------|----------|----------|----------|
| 194.925 | -0.10409  | -26331.9008 | -1530.6085 | .0004066 | 668.2829 | 47.0528  |
| 196.650 | -0.09715  | -28964.6654 | -1451.7875 | .0003977 | 684.1749 | 44.3339  |
| 198.375 | -0.09037  | -31464.0569 | -1377.6440 | .0003880 | 699.2617 | 41.6298  |
| 200.100 | -0.08376  | -33837.9973 | -1208.2457 | .0003774 | 713.5914 | 38.9482  |
| 201.825 | -0.07735  | -36094.3463 | -1243.2455 | .0003661 | 727.2112 | 36.2983  |
| 203.550 | -0.07113  | -38240.8758 | -1182.8821 | .0003541 | 740.1681 | 33.6883  |
| 205.275 | -0.06513  | -40285.2448 | -1126.9793 | .0003414 | 752.5084 | 31.1265  |
| 207.000 | -0.05935  | -42234.9737 | -1075.4470 | .0003281 | 764.2773 | 28.6211  |
| 208.725 | -0.05381  | -44097.4200 | -1028.1808 | .0003142 | 775.5195 | 26.1603  |
| 210.450 | -0.04851  | -45879.7531 | -985.0623  | .0002997 | 786.2780 | 23.8123  |
| 212.175 | -0.04347  | -47588.9302 | -945.9588  | .0002846 | 796.5950 | 21.5251  |
| 213.900 | -0.03869  | -49231.6713 | -909.9566  | .0002689 | 806.5109 | 19.2980  |
| 215.625 | -0.03419  | -50120.5458 | -874.9566  | .0002529 | 811.0764 | 17.0296  |
| 217.350 | -0.02997  | -50465.0479 | -840.9602  | .0002367 | 813.9559 | 15.0000  |
| 219.075 | -0.02603  | -50327.8572 | -808.9687  | .0002204 | 813.1277 | 14.0000  |
| 220.800 | -0.02236  | -49768.3360 | -778.9830  | .0002042 | 809.7504 | 13.0000  |
| 222.525 | -0.01898  | -48842.4135 | -750.0000  | .0001883 | 804.1613 | 12.0000  |
| 224.250 | -0.01587  | -47602.5460 | -722.0176  | .0001727 | 796.6732 | 11.0000  |
| 225.975 | -0.01302  | -46097.6219 | -695.0353  | .0001576 | 787.5921 | 10.0000  |
| 227.700 | -0.01043  | -44373.0191 | -668.0529  | .0001430 | 777.1830 | 9.0000   |
| 229.425 | -0.00809  | -42470.6023 | -642.0705  | .0001290 | 765.6996 | 8.0000   |
| 231.150 | -0.00598  | -40428.7806 | -617.0881  | .0001156 | 753.3748 | 7.0000   |
| 232.875 | -0.00410  | -38282.5824 | -593.1057  | .0001029 | 740.4398 | 6.0000   |
| 234.600 | -0.00243  | -36031.7500 | -569.1233  | .0000905 | 727.0265 | 5.0000   |
| 236.325 | -9.61E-05 | -33800.8504 | -545.1408  | .0000782 | 713.3671 | 4.0000   |
| 238.050 | 3.19E-05  | -31519.4010 | -521.1584  | .0000660 | 699.5958 | -1.0000  |
| 239.775 | .000142   | -29242.0047 | -497.1759  | .0000548 | 685.8490 | -2.0000  |
| 241.500 | .000236   | -26988.4971 | -473.1934  | .0000446 | 672.2463 | -3.0000  |
| 243.225 | .000315   | -24776.0980 | -449.2109  | .0000354 | 658.8918 | -4.0000  |
| 244.950 | .000381   | -22619.5695 | -425.2284  | .0000272 | 645.8745 | -5.0000  |
| 246.675 | .000441   | -20511.3758 | -401.2459  | .0000190 | 633.2697 | -6.0000  |
| 248.400 | .000475   | -18521.8459 | -377.2634  | .0000108 | 621.1397 | -7.0000  |
| 250.125 | .000506   | -16589.3340 | -353.2809  | .0000026 | 609.5350 | -8.0000  |
| 251.850 | .000527   | -14770.3807 | -329.2984  | .0000000 | 598.4951 | -9.0000  |
| 253.575 | .000541   | -13039.8700 | -305.3159  | .0000000 | 588.0493 | -10.0000 |
| 255.300 | .000547   | -11411.1829 | -281.3334  | .0000000 | 578.2187 | -11.0000 |
| 257.025 | .000547   | -9882.3467  | -257.3509  | .0000000 | 569.0140 | -12.0000 |
| 258.750 | .000541   | -8466.1783  | -233.3684  | .0000000 | 560.4416 | -13.0000 |
| 260.475 | .000531   | -7150.4221  | -209.3859  | .0000000 | 552.4994 | -14.0000 |
| 262.200 | .000516   | -5937.8807  | -185.4034  | .0000000 | 545.1802 | -15.0000 |
| 263.925 | .000499   | -4826.5396  | -161.4209  | .0000000 | 538.4719 | -16.0000 |
| 265.650 | .000478   | -3813.6830  | -137.4384  | .0000000 | 532.3581 | -17.0000 |
| 267.375 | .000456   | -2896.0071  | -113.4559  | .0000000 | 526.8188 | -18.0000 |
| 269.100 | .000432   | -2069.7149  | -89.4734   | .0000000 | 521.8311 | -19.0000 |
| 270.825 | .000406   | -1330.6181  | -65.4909   | .0000000 | 517.3698 | -20.0000 |
| 272.550 | .000380   | -674.2204   | -41.5084   | .0000000 | 513.4076 | -21.0000 |
| 274.275 | .000354   | -95.7984    | -17.5259   | .0000000 | 509.9161 | -22.0000 |
| 276.000 | .000328   | 418.0000    | 6.4566     | .0000000 | 511.8610 | -23.0000 |
| 277.725 | .000301   | 857.2645    | 20.4741    | .0000000 | 514.5125 | -24.0000 |
| 279.450 | .000276   | 1227.4032   | 34.4916    | .0000000 | 516.7467 | -25.0000 |
| 281.175 | .000251   | 1533.8089   | 48.5091    | .0000000 | 518.5963 | -26.0000 |
| 282.900 | .000227   | 1781.8082   | 62.5266    | .0000000 | 520.0932 | -27.0000 |
| 284.625 | .000203   | 1976.6178   | 76.5441    | .0000000 | 521.2692 | -28.0000 |
| 286.350 | .000181   | 2123.3070   | 90.5616    | .0000000 | 522.1546 | -29.0000 |
| 288.075 | .000160   | 2226.7667   | 104.5791   | .0000000 | 522.7791 | -30.0000 |
| 289.800 | .000141   | 2291.6835   | 118.5966   | .0000000 | 523.1710 | -31.0000 |
| 291.525 | .000122   | 2322.5194   | 132.6141   | .0000000 | 523.3571 | -32.0000 |
| 293.250 | .000105   | 2323.4867   | 146.6316   | .0000000 | 523.3630 | -33.0000 |
| 294.975 | 8.94E-05  | 2298.5862   | 160.6491   | .0000000 | 523.2126 | -34.0000 |
| 296.700 | 7.49E-05  | 2251.5010   | 174.6666   | .0000000 | 522.9284 | -35.0000 |
| 298.425 | 6.17E-05  | 2185.6919   | 188.6841   | .0000000 | 522.5312 | -36.0000 |
| 300.150 | 4.96E-05  | 2104.3481   | 202.7016   | .0000000 | 522.0402 | -37.0000 |
| 301.875 | 3.88E-05  | 2010.3990   | 216.7191   | .0000000 | 521.4733 | -38.0000 |
| 303.600 | 2.90E-05  | 1906.5196   | 230.7366   | .0000000 | 520.8460 | -39.0000 |
| 305.325 | 2.03E-05  | 1795.1375   | 244.7541   | .0000000 | 520.1737 | -40.0000 |
| 307.050 | 1.26E-05  | 1678.4409   | 258.7716   | .0000000 | 519.4693 | -41.0000 |
| 308.775 | 5.88E-06  | 1558.3913   | 272.7891   | .0000000 | 518.7446 | -42.0000 |
| 310.500 | -1.06E-06 | 1436.7324   | 286.8066   | .0000000 | 518.0103 | -43.0000 |
| 312.225 | -5.10E-06 | 1315.0042   | 300.8241   | .0000000 | 517.2755 | -44.0000 |
| 313.950 | -9.45E-06 | 1194.5561   | 314.8416   | .0000000 | 516.5485 | -45.0000 |
| 315.675 | -1.31E-05 | 1076.5603   | 328.8591   | .0000000 | 515.8262 | -46.0000 |
| 317.400 | -1.62E-05 | 962.0262    | 342.8766   | .0000000 | 515.1449 | -47.0000 |
| 319.125 | -1.88E-05 | 851.8143    | 356.8941   | .0000000 | 514.5096 | -48.0000 |
| 320.850 | -2.09E-05 | 746.6504    | 370.9116   | .0000000 | 513.8448 | -49.0000 |
| 322.575 | -2.25E-05 | 647.1398    | 384.9291   | .0000000 | 513.2441 | -50.0000 |
| 324.300 | -2.38E-05 | 553.7803    | 398.9466   | .0000000 | 512.6906 | -51.0000 |
| 326.025 | -2.48E-05 | 466.9758    | 412.9641   | .0000000 | 512.1566 | -52.0000 |
| 327.750 | -2.56E-05 | 387.0486    | 426.9816   | .0000000 | 511.6742 | -53.0000 |
| 329.475 | -2.61E-05 | 314.2513    | 440.9991   | .0000000 | 511.2347 | -54.0000 |
| 331.200 | -2.64E-05 | 248.7781    | 455.0166   | .0000000 | 510.8395 | -55.0000 |
| 332.925 | -2.66E-05 | 190.7750    | 469.0341   | .0000000 | 510.4894 | -56.0000 |
| 334.650 | -2.67E-05 | 140.3494    | 483.0516   | .0000000 | 510.1850 | -57.0000 |
| 336.375 | -2.67E-05 | 97.3786     | 497.0691   | .0000000 | 509.9269 | -58.0000 |
| 338.100 | -2.67E-05 | 62.5171     | 511.0866   | .0000000 | 509.7152 | -59.0000 |
| 339.825 | -2.66E-05 | 35.2035     | 525.1041   | .0000000 | 509.5504 | -60.0000 |
| 341.550 | -2.65E-05 | 15.6656     | 539.1216   | .0000000 | 509.4324 | -61.0000 |
| 343.275 | -2.64E-05 | 3.9251      | 553.1391   | .0000000 | 509.3616 | -62.0000 |
| 345.000 | -2.64E-05 | 0.0000      | 567.1566   | .0000000 | 509.3379 | -63.0000 |

Output Verification:

Computed forces and moments are within specified convergence limits.

Output Summary for Load Case No. 1:

- File-head deflection = 1.0000000 in
- Computed slope at pile head = -.01405743
- Maximum bending moment = 839265.90326 lbs-in
- Maximum shear force = 26050.12009 lbs
- Depth of maximum bending moment = 62.10000000 in
- Depth of maximum shear force = 0.00000 in
- Number of iterations = 20
- Number of zero deflection points = 3

Summary of Pile-Head Response(s)

Definition of Symbols for Pile-Head Loading Conditions:

Type 1 = Shear and Moment, y = pile-head displacement in  
 Type 2 = Shear and Slope, M = pile-head moment lbs-in  
 Type 3 = Shear and Rot. Stiffness, V = pile-head shear force lbs  
 Type 4 = Deflection and Moment, S = pile-head slope, radians  
 Type 5 = Deflection and Slope, R = rotational stiffness of pile-head in-lbs/rad

| Load Type | Boundary Condition 1 | Boundary Condition 2 | Axial Load lbs | File-Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|-----------|----------------------|----------------------|----------------|-------------------------|-----------------------|-------------------|
| 4         | y= 1.000000          | M= 0.000             | 90000.0000     | 1.0000000               | 839266.               | 26050.1201        |

File-head Deflection vs. File Length

Boundary Condition Type 4, Deflection and Moment

Deflection = 1.00000 in  
 Moment = 0. in-lbs  
 Axial Load = 90000. lbs

| File Length in | File Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|----------------|-------------------------|-----------------------|-------------------|
| 345.000        | 1.00000000              | 839265.86547          | 26050.11949       |
| 327.750        | 1.00000000              | 839145.06694          | 26048.59097       |
| 310.500        | 1.00000000              | 839199.66803          | 26049.17250       |
| 293.250        | 1.00000000              | 839173.32639          | 26048.56682       |
| 276.000        | 1.00000000              | 839110.95016          | 26047.86358       |
| 258.750        | 1.00000000              | 838984.29377          | 26046.12819       |
| 241.500        | 1.00000000              | 838011.82287          | 26030.01451       |
| 224.250        | 1.00000000              | 837038.82453          | 26014.81706       |
| 207.000        | 1.00000000              | 836554.01713          | 26007.85196       |
| 189.750        | 1.00000000              | 832624.97328          | 25950.74178       |

The analysis ended normally.

LPYLE Plus for Windows, Version 5.0 (5.0.11)  
 Analysis of Individual Piles and Drilled Shafts  
 Subjected to Lateral Loading Using the p-y Method  
 (c) Copyright ENSOFT, Inc., 1985-2005  
 All Rights Reserved

This program is licensed to:

Yauwei Zhou  
 Kleifolder

Path to file locations: U:\Yzhou\Projects\75010\Analysis\LPYLE\B2B3\  
 Name of input data file: B2p6mm.lpd  
 Name of output file: B2p6mm.lpo  
 Name of plot output file: B2p6mm.lpp  
 Name of runtime file: B2p6mm.lpr

Time and Date of Analysis

Date: May 30, 2007 Time: 13:21:25

Problem Title

B2-B3, pinned head, 0.25 in

Program Options

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
 - Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:  
 - Only internally-generated p-y curves used in analysis  
 - Analysis does not use p-y multipliers (individual pile or shaft action only)  
 - Analysis assumes no shear resistance at pile tip  
 - Analysis includes automatic computation of pile-top deflection vs. pile embedment length  
 - No computation of foundation stiffness matrix elements  
 - Output pile response for full length of pile  
 - Analysis assumes no soil movements acting on pile  
 - No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:  
 - Number of pile increments = 200  
 - Maximum number of iterations allowed = 200  
 - Deflection tolerance for convergence = 1.0000E-05 in  
 - Maximum allowable deflection = 1.0000E+01 in

Printing Options:  
 - Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile.  
 - Printing increment (spacing of output points) = 1

Pile Structural Properties and Geometry

Pile Length = 345.00 in  
 Depth of ground surface below top of pile = -89.00 in  
 Slope angle of ground surface = .00 deg.

Structural properties of pile defined using 2 points

| Point | Depth<br>X<br>in | Pile<br>Diameter<br>in | Moment of<br>Inertia<br>in**4 | Pile<br>Area<br>Sq.in | Modulus of<br>Elasticity<br>lbs/Sq.in |
|-------|------------------|------------------------|-------------------------------|-----------------------|---------------------------------------|
| 1     | 0.0000           | 15.00000000            | 2485.0000                     | 176.7000              | 4300000.                              |
| 2     | 500.0000         | 15.00000000            | 2485.0000                     | 176.7000              | 4300000.                              |

Soil and Rock Layering Information

The soil profile is modelled using 5 layers

Layer 1 is stiff clay without free water  
 Distance from top of pile to top of layer = -99.000 in  
 Distance from top of pile to bottom of layer = 129.000 in

Layer 2 is stiff clay with water-induced erosion  
 Distance from top of pile to top of layer = 129.000 in  
 Distance from top of pile to bottom of layer = 153.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 3 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = 153.000 in  
 Distance from top of pile to bottom of layer = 213.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 213.000 in  
 Distance from top of pile to bottom of layer = 273.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 273.000 in  
 Distance from top of pile to bottom of layer = 450.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends 105.00 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth is defined using 10 points

| Point No. | Depth X in | Eff. Unit Weight lbs/in**3 |
|-----------|------------|----------------------------|
| 1         | -99.00     | .07234                     |
| 2         | 129.00     | .07234                     |
| 3         | 129.00     | .03623                     |
| 4         | 153.00     | .03623                     |
| 5         | 153.00     | .03623                     |
| 6         | 213.00     | .03623                     |
| 7         | 213.00     | .03333                     |
| 8         | 273.00     | .03333                     |
| 9         | 273.00     | .03622                     |
| 10        | 450.00     | .03622                     |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth defined using 10 points

| Point No. | Depth X in | Cohesion c lbs/in**2 | Angle of Friction Deg. | E50 or k <sub>zm</sub> | RQD % |
|-----------|------------|----------------------|------------------------|------------------------|-------|
| 1         | -99.000    | 6.25000              | .00                    | -----                  | ----- |
| 2         | 129.000    | 6.25000              | .00                    | -----                  | ----- |
| 3         | 129.000    | 6.25000              | .00                    | -----                  | ----- |
| 4         | 153.000    | 6.25000              | .00                    | -----                  | ----- |
| 5         | 153.000    | .00000               | 30.00                  | -----                  | ----- |
| 6         | 213.000    | .00000               | 30.00                  | -----                  | ----- |
| 7         | 213.000    | 5.56000              | 25.00                  | -----                  | ----- |
| 8         | 273.000    | 5.56000              | 25.00                  | -----                  | ----- |
| 9         | 273.000    | 3.47000              | 32.00                  | -----                  | ----- |
| 10        | 450.000    | 3.47000              | 32.00                  | -----                  | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k<sub>zm</sub> are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 File-head Loading and File-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number 1

File-head boundary conditions are Displacement and Moment (BC Type 4)  
 Deflection at pile head = .250 in  
 Bending moment at pile head = .000 in-lbs  
 Axial load at pile head = 90000.000 lbs

-----  
 Computed Values of Load Distribution and Deflection for Lateral Loading for Load Case Number 1  
 -----

File-head boundary conditions are Displacement and Moment (BC Type 4)  
 Specified deflection at pile head = .250000 in  
 Specified moment at pile head = .000 in-lbs  
 Specified axial load at pile head = 90000.000 lbs

| Depth X | Deflect. y | Moment M | Shear V | Slope S | Total Stress | Soil Res p |
|---------|------------|----------|---------|---------|--------------|------------|
|---------|------------|----------|---------|---------|--------------|------------|





|         |           |             |           |             |          |           |
|---------|-----------|-------------|-----------|-------------|----------|-----------|
| 194.925 | -0.00189  | -11528.8047 | -673.2039 | .0001083    | 544.1330 | 14.4140   |
| 196.650 | -0.003003 | -12685.3022 | -648.9501 | .0001063    | 547.6235 | 13.7064   |
| 198.375 | -0.002822 | -13800.4966 | -625.9165 | .0001042    | 550.9839 | 12.9991   |
| 200.100 | -0.002644 | -14977.0646 | -604.1011 | .0001019    | 554.2385 | 12.2941   |
| 201.825 | -0.002470 | -15916.4771 | -583.4984 | 9.9388E-05  | 557.3755 | 11.5931   |
| 203.550 | -0.002301 | -16920.9940 | -564.0997 | 9.6737E-05  | 560.4073 | 10.8982   |
| 205.275 | -0.002137 | -17892.6581 | -545.8930 | 9.3927E-05  | 563.3390 | 10.2111   |
| 207.000 | -0.001977 | -10833.4892 | -528.8629 | 9.0963E-05  | 566.1794 | 9.5339    |
| 208.725 | -0.001823 | -19745.4789 | -512.9908 | 8.7849E-05  | 568.9319 | 8.8685    |
| 210.450 | -0.001674 | -20630.5844 | -498.2547 | 8.4590E-05  | 571.6032 | 8.2167    |
| 212.175 | -0.001531 | -21499.7228 | -484.6295 | 8.1190E-05  | 574.1992 | 7.5806    |
| 213.900 | -0.001394 | -22327.7657 | -399.6350 | 7.7653E-05  | 576.7255 | 69.9538   |
| 215.625 | -0.001263 | -22893.5747 | -263.1615 | 7.4003E-05  | 578.4332 | 67.2662   |
| 217.350 | -0.001139 | -23258.6509 | -152.3790 | 7.0278E-05  | 579.5350 | 61.1773   |
| 219.075 | -0.001021 | -23441.1035 | -51.8990  | 6.6508E-05  | 580.0857 | 55.3213   |
| 220.800 | -0.000909 | -23458.3533 | 38.6900   | 6.2723E-05  | 580.1377 | 49.7103   |
| 222.525 | -0.000804 | -23327.0958 | 119.8212  | 5.8946E-05  | 579.7416 | 44.3538   |
| 224.250 | -0.000706 | -23063.2729 | 191.9377  | 5.5202E-05  | 578.9453 | 39.2594   |
| 225.975 | -0.000614 | -22682.0509 | 255.4963  | 5.1509E-05  | 577.7948 | 34.4317   |
| 227.700 | -0.000528 | -22197.8044 | 310.9602  | 4.7887E-05  | 576.3322 | 29.8742   |
| 229.425 | -0.000448 | -21624.1072 | 350.7964  | 4.4350E-05  | 574.6018 | 25.5881   |
| 231.150 | -0.000375 | -20973.7275 | 399.4727  | 4.0911E-05  | 572.6380 | 21.5729   |
| 232.875 | -0.000307 | -20258.6294 | 453.4549  | 3.7583E-05  | 570.4806 | 17.8268   |
| 234.600 | -0.000245 | -19489.9778 | 511.7680  | 3.4375E-05  | 568.1607 | 14.3464   |
| 236.325 | -0.000189 | -18678.1484 | 483.1750  | 3.1294E-05  | 565.7105 | 11.1271   |
| 238.050 | -0.000137 | -17832.7408 | 499.8129  | 2.8347E-05  | 563.1590 | 8.1632    |
| 239.775 | -9.10E-05 | -16962.5957 | 511.5526  | 2.5538E-05  | 560.5328 | 5.4481    |
| 241.500 | -4.93E-05 | -16075.8141 | 518.8167  | 2.2872E-05  | 557.8564 | 2.9741    |
| 243.225 | -1.20E-05 | -15179.7798 | 522.0139  | 2.0349E-05  | 555.1521 | .7329131  |
| 244.950 | 2.09E-05  | -14281.1843 | 521.5383  | 1.7971E-05  | 552.4400 | -1.2843   |
| 246.675 | 5.00E-05  | -13489.0525 | 461.2080  | 1.5787E-05  | 549.7384 | -3.0871   |
| 248.400 | 7.52E-05  | -12499.7712 | 511.0644  | 1.3648E-05  | 547.0635 | -4.6852   |
| 250.125 | 9.70E-05  | -11627.1180 | 501.7717  | 1.1701E-05  | 544.4298 | -6.0890   |
| 251.850 | .000116   | -10772.2919 | 490.2162  | 9.8926E-06  | 541.8498 | -7.3087   |
| 253.575 | .000131   | -9930.9437  | 476.7064  | 8.2208E-06  | 539.3347 | -8.3549   |
| 255.300 | .000144   | -9130.2075  | 461.5322  | 6.6816E-06  | 536.8938 | -9.2383   |
| 257.025 | .000154   | -8340.7323  | 444.9854  | 5.2709E-06  | 534.5352 | -9.9658   |
| 258.750 | .000162   | -7589.7132  | 427.2595  | 3.9837E-06  | 532.2656 | -10.5590  |
| 260.475 | .000168   | -6875.9230  | 408.6499  | 2.8155E-06  | 530.0901 | -11.0173  |
| 262.200 | .000172   | -6187.7453  | 389.3541  | 1.7611E-06  | 528.0131 | -11.3546  |
| 263.925 | .000174   | -5533.1909  | 369.5721  | 8.1498E-07  | 526.0377 | -11.5810  |
| 265.650 | .000175   | -4912.9745  | 349.4870  | -2.8200E-08 | 524.1658 | -11.7061  |
| 267.375 | .000174   | -4327.4600  | 329.2651  | -7.7406E-07 | 522.3980 | -11.7395  |
| 269.100 | .000172   | -3776.7695  | 309.0569  | -1.4282E-06 | 520.7366 | -11.6903  |
| 270.825 | .000169   | -3260.7705  | 288.9973  | -1.8963E-06 | 519.1792 | -11.5673  |
| 272.550 | .000165   | -2779.1097  | 269.2060  | -2.4838E-06 | 517.7255 | -11.3789  |
| 274.275 | .000160   | -2331.2307  | 250.9024  | -2.8963E-06 | 516.3738 | -9.8426   |
| 276.000 | .000155   | -1912.5972  | 232.1869  | -3.2388E-06 | 515.1103 | -11.8565  |
| 277.725 | .000149   | -1529.1883  | 212.0448  | -3.5168E-06 | 513.9531 | -11.4967  |
| 279.450 | .000143   | -1179.9508  | 192.5578  | -3.7353E-06 | 512.8991 | -11.0969  |
| 281.175 | .000136   | -853.7840   | 173.7889  | -3.9003E-06 | 511.9446 | -10.6641  |
| 282.900 | .000130   | -579.1880   | 155.7896  | -4.0167E-06 | 511.0859 | -10.2046  |
| 284.625 | .000123   | -324.9827   | 138.6009  | -4.0897E-06 | 510.3187 | -9.7243   |
| 286.350 | .000115   | -89.7252    | 122.2540  | -4.1240E-06 | 509.6388 | -9.2285   |
| 208.075 | .000108   | 98.0742     | 106.7715  | -4.1241E-06 | 509.6339 | -8.7222   |
| 289.800 | .000101   | 269.9172    | 92.1678   | -4.0944E-06 | 510.1525 | -8.2097   |
| 291.525 | 9.42E-05  | 417.3244    | 78.4500   | -4.0389E-06 | 510.5974 | -7.6950   |
| 293.250 | 8.73E-05  | 541.8238    | 65.6189   | -3.9615E-06 | 510.9731 | -7.1816   |
| 294.975 | 8.05E-05  | 644.9397    | 55.5695   | -3.8657E-06 | 513.2844 | -6.6727   |
| 296.700 | 7.39E-05  | 728.1841    | 42.5920   | -3.7549E-06 | 511.5356 | -6.1708   |
| 298.425 | 6.76E-05  | 793.0481    | 32.3723   | -3.6321E-06 | 511.7314 | -5.6782   |
| 300.150 | 6.14E-05  | 840.9961    | 22.9925   | -3.5002E-06 | 511.8761 | -5.1969   |
| 301.875 | 5.55E-05  | 873.4590    | 14.4320   | -3.3618E-06 | 511.9741 | -4.7283   |
| 303.600 | 4.98E-05  | 891.8304    | 6.6679    | -3.2193E-06 | 512.0295 | -4.2736   |
| 305.325 | 4.44E-05  | 897.4629    | -32.46315 | -3.0749E-06 | 512.0465 | -3.8337   |
| 307.050 | 3.92E-05  | 891.6653    | -6.5716   | -2.9305E-06 | 512.0290 | -3.4092   |
| 308.775 | 3.43E-05  | 875.7009    | -12.0998  | -2.7878E-06 | 511.9808 | -3.0003   |
| 310.500 | 2.96E-05  | 850.7865    | -16.9364  | -2.6485E-06 | 511.9056 | -2.6072   |
| 312.225 | 2.51E-05  | 818.0927    | -21.1081  | -2.5138E-06 | 511.8070 | -2.2296   |
| 313.950 | 2.09E-05  | 778.7439    | -24.6416  | -2.3849E-06 | 511.6882 | -1.8672   |
| 315.675 | 1.69E-05  | 733.8197    | -27.5624  | -2.2628E-06 | 511.5526 | -1.5192   |
| 317.400 | 1.31E-05  | 684.3564    | -29.8949  | -2.1483E-06 | 511.4033 | -1.1851   |
| 319.125 | 9.18E-06  | 631.3495    | -31.6621  | -2.0421E-06 | 511.2433 | -.8638874 |
| 320.850 | 6.05E-06  | 575.7562    | -32.8855  | -1.9447E-06 | 511.0756 | -.5545490 |
| 322.575 | 2.77E-06  | 518.4983    | -33.5846  | -1.8564E-06 | 510.9027 | -.2559750 |
| 324.300 | -3.56E-07 | 460.4658    | -33.7789  | -1.7773E-06 | 510.7276 | .0303030  |
| 326.025 | -3.36E-06 | 402.5200    | -33.4778  | -1.7077E-06 | 510.5527 | .3137310  |
| 327.750 | -6.25E-06 | 345.4976    | -32.7006  | -1.6473E-06 | 510.3806 | .5874106  |
| 329.475 | -9.04E-06 | 290.2145    | -31.4582  | -1.5960E-06 | 510.2138 | .8553770  |
| 331.200 | -1.18E-05 | 237.4694    | -29.7533  | -1.5534E-06 | 510.0546 | 1.1189    |
| 332.925 | -1.44E-05 | 188.0479    | -27.5986  | -1.5191E-06 | 509.9054 | 1.3793    |
| 334.650 | -1.70E-05 | 142.7260    | -24.9963  | -1.4924E-06 | 509.7686 | 1.6378    |
| 336.375 | -1.95E-05 | 102.2740    | -21.9489  | -1.4726E-06 | 509.6465 | 1.8954    |
| 338.100 | -2.21E-05 | 67.4594     | -18.4569  | -1.4589E-06 | 509.5415 | 2.1533    |
| 339.825 | -2.46E-05 | 39.0505     | -14.5191  | -1.4503E-06 | 509.4557 | 2.4123    |
| 341.550 | -2.71E-05 | 17.8187     | -10.1390  | -1.4457E-06 | 509.3916 | 2.6731    |
| 343.275 | -2.96E-05 | 4.5406      | -5.2948   | -1.4439E-06 | 509.3516 | 2.9264    |
| 345.000 | -3.21E-05 | 0.0000      | 0.0000    | -1.4435E-06 | 509.3379 | 3.2025    |

Output Verification:

Computed forces and moments are within specified convergence limits.

Output Summary for Load Case No. 1:

|                                  |   |                     |
|----------------------------------|---|---------------------|
| File-head deflection             | = | .25000000 in        |
| Computed slope at pile head      | = | -.00402232          |
| Maximum bending moment           | = | 489910.93324 lbs-in |
| Maximum shear force              | = | 17108.46440 lbs     |
| Depth of maximum bending moment  | = | 56.92500000 in      |
| Depth of maximum shear force     | = | 0.00000 in          |
| Number of iterations             | = | 16                  |
| Number of zero deflection points | = | 3                   |

Summary of File-Head Response(s)

Definition of Symbols for File-Head Loading Conditions:

File: U:\Y2hou\Projects\75010\Analysis\Appendix C\14 B2p6m.lpo

Type 1 = Shear and Moment, y = pile-head displacement in  
 Type 2 = Shear and Slope, H = pile-head moment lbs-in  
 Type 3 = Shear and Rot. Stiffness, V = pile-head shear force lbs  
 Type 4 = Deflection and Moment, S = pile-head slope, radians  
 Type 5 = Deflection and Slope, R = rotational stiffness of pile-head-in-lbs/rad

| Load Type | Boundary Condition 1 | Boundary Condition 2 | Axial Load lbs | Pile-Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|-----------|----------------------|----------------------|----------------|-------------------------|-----------------------|-------------------|
| 4         | y = .250000          | M = 0.000            | 90000.0000     | .2500000                | 489911.               | 17108.4644        |

File-head Deflection vs. Pile Length

Boundary Condition Type 4, Deflection and Moment

Deflection = .25000 in  
 Moment = 0. in-lbs  
 Axial Load = 90000. lbs

| Pile Length in | Pile Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|----------------|-------------------------|-----------------------|-------------------|
| 345.000        | .25000000               | 489910.83402          | 17108.46442       |
| 327.750        | .25000000               | 490117.83090          | 17111.32141       |
| 310.500        | .25000000               | 490083.36174          | 17110.74658       |
| 293.250        | .25000000               | 490053.78008          | 17110.23077       |
| 276.000        | .25000000               | 489870.14239          | 17107.73248       |
| 258.750        | .25000000               | 489750.40342          | 17105.45026       |
| 241.500        | .25000000               | 488971.62317          | 17092.62206       |
| 224.250        | .25000000               | 488857.21836          | 17089.95159       |
| 207.000        | .25000000               | 488173.71865          | 17078.02886       |
| 189.750        | .25000000               | 486303.91708          | 17048.51397       |

The analysis ended normally.

LPILE Plus for Windows, Version 5.0 (5.0.11)  
Analysis of Individual Piles and Drilled Shafts  
Subjected to Lateral Loading Using the p-y Method  
(c) Copyright ENSOFT, Inc., 1985-2005  
All Rights Reserved

This program is licensed to:

Youwei Zhou  
Kleifelder

Path to file locations: U:\YZhou\Projects\75010\Analysis\LPILE\B2B3\  
Name of input data file: B2f25mm.lpd  
Name of output file: B2f25mm.lpo  
Name of plot output file: B2f25mm.lpp  
Name of runtime file: B2f25mm.lpr

Time and Date of Analysis

Date: May 30, 2007 Time: 13: 0:31

Problem Title

B2-B3, fixed head, 1.0 in

Program Options

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
- Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:

- Only internally-generated p-y curves used in analysis
- Analysis does not use p-y multipliers (individual pile or shaft action only)
- Analysis assumes no shear resistance at pile tip
- Analysis includes automatic computation of pile-top deflection vs. pile embedment length
- No computation of foundation stiffness matrix elements
- Output pile response for full length of pile
- Analysis assumes no soil movements acting on pile
- No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:

- Number of pile increments = 200
- Maximum number of iterations allowed = 200
- Deflection tolerance for convergence = 1.0000E-03 in
- Maximum allowable deflection = 1.0000E+01 in

Printing Options:

- Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile.
- Printing Increment (spacing of output points) = 1

Pile Structural Properties and Geometry

Pile Length = 345.00 in  
Depth of ground surface below top of pile = -99.00 in  
Slope angle of ground surface = .00 deg.

Structural properties of pile defined using 2 points

| Point | Depth X in | Pile Diameter in | Moment of Inertia in <sup>4</sup> | Pile Area Sq.in | Modulus of Elasticity lbs/Sq.in |
|-------|------------|------------------|-----------------------------------|-----------------|---------------------------------|
| 1     | 0.0000     | 15.00000000      | 1242.5000                         | 176.7000        | 4300000.                        |
| 2     | 300.0000   | 15.00000000      | 1242.5000                         | 176.7000        | 4300000.                        |

Soil and Rock Layering Information

The soil profile is modelled using 5 layers

Layer 1 is stiff clay without free water  
Distance from top of pile to top of layer = -99.000 in  
Distance from top of pile to bottom of layer = 129.000 in

Layer 2 is stiff clay with water-induced erosion  
Distance from top of pile to top of layer = 129.000 in  
Distance from top of pile to bottom of layer = 153.000 in  
p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 3 is sand, p-y criteria by Reese et al., 1974  
Distance from top of pile to top of layer = 153.000 in  
Distance from top of pile to bottom of layer = 213.000 in  
p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 213.000 in  
 Distance from top of pile to bottom of layer = 273.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 273.000 in  
 Distance from top of pile to bottom of layer = 450.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends 105.00 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth is defined using 10 points

| Point No. | Depth X in | Eff. Unit Weight lbs/in**3 |
|-----------|------------|----------------------------|
| 1         | -99.00     | .07234                     |
| 2         | 129.00     | .07234                     |
| 3         | 129.00     | .03623                     |
| 4         | 153.00     | .03623                     |
| 5         | 153.00     | .03623                     |
| 6         | 213.00     | .03623                     |
| 7         | 213.00     | .03333                     |
| 8         | 273.00     | .03333                     |
| 9         | 273.00     | .03622                     |
| 10        | 450.00     | .03622                     |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth defined using 10 points

| Point No. | Depth X in | Cohesion c lbs/in**2 | Angle of Friction Deg. | E50 or k_rm | RQD % |
|-----------|------------|----------------------|------------------------|-------------|-------|
| 1         | -99.000    | 6.25000              | .00                    | -----       | ----- |
| 2         | 129.000    | 6.25000              | .00                    | -----       | ----- |
| 3         | 129.000    | 6.25000              | .00                    | -----       | ----- |
| 4         | 153.000    | 6.25000              | .00                    | -----       | ----- |
| 5         | 153.000    | .00000               | 30.00                  | -----       | ----- |
| 6         | 213.000    | .00000               | 30.00                  | -----       | ----- |
| 7         | 213.000    | 5.56000              | 25.00                  | -----       | ----- |
| 8         | 273.000    | 5.56000              | 25.00                  | -----       | ----- |
| 9         | 273.000    | 3.47000              | 32.00                  | -----       | ----- |
| 10        | 450.000    | 3.47000              | 32.00                  | -----       | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k\_rm are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 Pile-head Loading and Pile-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number 1

Pile-head boundary conditions are Displacement and Slope (BC Type 5)  
 Deflection at pile head = 1.000 in  
 Slope at pile head = .000 in/in  
 Axial load at pile head = 90000.000 lbs

-----  
 Computed Values of Load Distribution and Deflection for Lateral Loading for Load Case Number 1  
 -----

Pile-head boundary conditions are Displacement and Slope (BC Type 5)  
 Specified deflection at pile head = 1.000000 in  
 Specified slope at pile head = 0.000E+00 in/in  
 Specified axial load at pile head = 90000.000 lbs

| Depth X | Deflect. y | Moment M | Shear V | Slope S | Total Stress | Soil Res p |
|---------|------------|----------|---------|---------|--------------|------------|
|---------|------------|----------|---------|---------|--------------|------------|



|         |           |             |            |             |           |          |
|---------|-----------|-------------|------------|-------------|-----------|----------|
| 194.925 | -0.16760  | 81344.9326  | -6510.7238 | .0003432    | 1000.3536 | 75.7649  |
| 196.650 | -0.16146  | 70371.3376  | -6381.8254 | .0003677    | 922.9073  | 73.6826  |
| 198.375 | -0.15492  | 59213.4770  | -6256.7199 | .0003885    | 866.7633  | 71.3672  |
| 200.100 | -0.14805  | 48465.0303  | -6125.7895 | .0004059    | 821.8022  | 69.8420  |
| 201.825 | -0.14091  | 37918.9623  | -6019.3752 | .0004199    | 738.2250  | 66.1310  |
| 203.550 | -0.13357  | 27567.7947  | -5907.7768 | .0004304    | 675.7431  | 63.2584  |
| 205.275 | -0.12606  | 17403.4785  | -5801.2518 | .0004377    | 614.3890  | 60.2490  |
| 207.000 | -0.11846  | 7417.5683   | -5700.0140 | .0004417    | 554.1119  | 57.1282  |
| 208.725 | -0.11082  | -2398.7216  | -5604.2335 | .0004425    | 523.8171  | 53.9217  |
| 210.450 | -0.10320  | -12054.4405 | -5524.0353 | .0004462    | 502.1011  | 50.6539  |
| 212.175 | -0.09564  | -21556.8222 | -5429.4987 | .0004348    | 639.4716  | 47.3576  |
| 213.900 | -0.08820  | -30921.2050 | -4892.2012 | .0004263    | 695.9850  | 575.5961 |
| 215.625 | -0.08093  | -38569.2798 | -4023.9831 | .0004151    | 742.1504  | 431.0336 |
| 217.350 | -0.07388  | -44932.8270 | -3309.8245 | .0004016    | 780.5622  | 396.9763 |
| 219.075 | -0.06708  | -50112.8691 | -2633.8218 | .0003862    | 811.8300  | 363.6065 |
| 220.800 | -0.06055  | -54208.4426 | -2054.6222 | .0003694    | 836.5519  | 331.1176 |
| 222.525 | -0.05433  | -57316.0172 | -1510.3637 | .0003514    | 855.3098  | 299.6749 |
| 224.250 | -0.04843  | -59528.9987 | -1019.7211 | .0003325    | 868.6678  | 269.4179 |
| 225.975 | -0.04286  | -60937.3094 | -579.9504  | .0003131    | 877.1687  | 240.4611 |
| 227.700 | -0.03763  | -61627.0436 | -188.9298  | .0002933    | 881.3321  | 212.8961 |
| 229.425 | -0.03274  | -61680.1898 | 155.8019   | .0002734    | 881.6529  | 186.7930 |
| 231.150 | -0.02819  | -61174.4184 | 456.8105   | .0002536    | 878.5999  | 162.2024 |
| 232.875 | -0.02399  | -60182.9272 | 716.7329   | .0002340    | 872.6151  | 139.1569 |
| 234.600 | -0.02012  | -58774.3405 | 928.2484   | .0002148    | 864.1126  | 117.6727 |
| 236.325 | -0.01658  | -57012.6580 | 1124.0514  | .0001961    | 853.4787  | 97.7511  |
| 238.050 | -0.01336  | -54957.2471 | 1276.8275  | .0001780    | 841.0717  | 79.3806  |
| 239.775 | -0.01044  | -52662.8744 | 1399.2321  | .0001606    | 827.2224  | 62.5377  |
| 241.500 | -0.00782  | -50179.7733 | 1493.8712  | .0001440    | 812.2339  | 47.1888  |
| 243.225 | -0.00547  | -47553.7408 | 1563.2854  | .0001283    | 796.3826  | 33.2915  |
| 244.950 | -0.00339  | -44826.2615 | 1609.9358  | .0001133    | 779.9389  | 20.7959  |
| 246.675 | -0.00165  | -42034.6545 | 1636.1918  | 9.9319E-05  | 763.0682  | 9.6458   |
| 248.400 | 3.53E-06  | -39212.2382 | 1644.3216  | 8.6203E-05  | 746.0315  | -2200424 |
| 250.125 | .000141   | -36388.5111 | 1636.4040  | 7.3998E-05  | 728.9868  | -8.8670  |
| 251.850 | .000259   | -33589.3449 | 1614.7227  | 6.2701E-05  | 712.0904  | -16.3634 |
| 253.575 | .000358   | -30837.1864 | 1580.9617  | 5.2301E-05  | 695.4778  | -22.7797 |
| 255.300 | .000439   | -28131.2662 | 1537.0023  | 4.2778E-05  | 679.2650  | -28.1877 |
| 257.025 | .000505   | -25477.8110 | 1484.5213  | 3.4109E-05  | 663.5500  | -32.6586 |
| 258.750 | .000557   | -23040.2578 | 1425.0720  | 2.6265E-05  | 648.4139  | -36.2675 |
| 260.475 | .000596   | -20639.4682 | 1360.0825  | 1.9214E-05  | 633.9222  | -39.0827 |
| 262.200 | .000623   | -18353.9394 | 1290.8599  | 1.2919E-05  | 620.1262  | -41.1754 |
| 263.925 | .000640   | -16190.0131 | 1218.5916  | 7.3427E-06  | 607.0443  | -42.6139 |
| 265.650 | .000649   | -14152.0781 | 1144.3492  | 2.4445E-06  | 594.7629  | -43.4644 |
| 267.375 | .000649   | -12212.7675 | 1069.0917  | -1.8165E-06 | 583.2379  | -43.7906 |
| 269.100 | .000642   | -10463.1477 | 993.6709   | -5.4828E-06 | 572.4957  | -43.6337 |
| 270.825 | .000630   | -8812.9006  | 918.8356   | -8.5899E-06 | 562.5344  | -43.1118 |
| 272.550 | .000613   | -7290.4963  | 845.2370   | -1.1193E-05 | 553.3449  | -42.2199 |
| 274.275 | .000591   | -5893.3572  | 777.5361   | -1.3322E-05 | 544.9114  | -36.2739 |
| 276.000 | .000567   | -4603.8603  | 708.8926   | -1.5016E-05 | 537.1278  | -43.3127 |
| 277.725 | .000540   | -3443.0150  | 635.6974   | -1.6315E-05 | 530.1206  | -41.5513 |
| 279.450 | .000510   | -2405.6383  | 565.6964   | -1.7260E-05 | 523.8588  | -39.6092 |
| 281.175 | .000480   | -1486.9032  | 499.1654   | -1.7888E-05 | 518.3077  | -37.5882 |
| 282.900 | .000449   | -677.9636   | 436.3111   | -1.8237E-05 | 513.4302  | -35.3463 |
| 284.625 | .000417   | 24.9327     | 377.2781   | -1.8343E-05 | 509.4884  | -33.0978 |
| 286.350 | .000385   | 629.3412    | 322.1549   | -1.8237E-05 | 513.1367  | -30.8132 |
| 288.075 | .000354   | 1142.0296   | 270.9002   | -1.7951E-05 | 516.2314  | -28.5198 |
| 289.800 | .000323   | 1569.7966   | 223.7489   | -1.7513E-05 | 518.8135  | -26.2412 |
| 291.525 | .000294   | 1919.4010   | 180.4174   | -1.6950E-05 | 520.9238  | -23.9982 |
| 293.250 | .000265   | 2187.4894   | 140.9094   | -1.6285E-05 | 522.6024  | -21.8082 |
| 294.975 | .000238   | 2410.5851   | 105.1208   | -1.5541E-05 | 523.8887  | -19.6859 |
| 296.700 | .000211   | 2564.9918   | 72.9241    | -1.4738E-05 | 524.8207  | -17.6435 |
| 298.425 | .000187   | 2666.7595   | 44.1735    | -1.3894E-05 | 525.4350  | -15.6906 |
| 300.150 | .000163   | 2721.7042   | 18.7083    | -1.3024E-05 | 525.7667  | -13.8343 |
| 301.875 | .000142   | 2735.3469   | -3.6628    | -1.2143E-05 | 525.8490  | -12.0800 |
| 303.600 | .000122   | 2732.9688   | -23.0585   | -1.1263E-05 | 525.7136  | -10.4310 |
| 305.325 | .000103   | 2659.2922   | -39.7219   | -1.0396E-05 | 525.3899  | -8.8888  |
| 307.050 | 8.57E-05  | 2579.0944   | -53.8172   | -9.5504E-06 | 524.9058  | -7.4536  |
| 308.775 | 6.99E-05  | 2476.5883   | -65.5279   | -8.7342E-06 | 524.2871  | -6.1240  |
| 310.500 | 5.56E-05  | 2355.7353   | -75.0339   | -7.9541E-06 | 523.5576  | -4.8975  |
| 312.225 | 4.25E-05  | 2220.1910   | -82.5102   | -7.2154E-06 | 522.7394  | -3.7706  |
| 313.950 | 3.07E-05  | 2073.3155   | -88.1246   | -6.5223E-06 | 521.8528  | -2.7389  |
| 315.675 | 2.00E-05  | 1918.1862   | -92.0369   | -5.8779E-06 | 520.9164  | -1.7971  |
| 317.400 | 1.04E-05  | 1757.6134   | -94.3971   | -5.2845E-06 | 519.9472  | -9394338 |
| 319.125 | 1.75E-06  | 1594.1571   | -95.3451   | -4.7435E-06 | 518.9605  | -1597090 |
| 320.850 | -5.99E-06 | 1430.1457   | -95.0096   | -4.2552E-06 | 517.9705  | -5487353 |
| 322.575 | -1.29E-05 | 1267.6953   | -93.5075   | -3.8197E-06 | 516.9899  | 1.1928   |
| 324.300 | -1.92E-05 | 1108.7307   | -90.9441   | -3.4361E-06 | 516.0304  | 1.7794   |
| 326.025 | -2.48E-05 | 953.0053    | -87.4121   | -3.1029E-06 | 515.1025  | 2.3156   |
| 327.750 | -2.99E-05 | 808.1223    | -82.9927   | -2.8183E-06 | 514.2159  | 2.8084   |
| 329.475 | -3.45E-05 | 669.5557    | -77.7547   | -2.5797E-06 | 513.3794  | 3.2646   |
| 331.200 | -3.88E-05 | 540.6697    | -71.7557   | -2.3844E-06 | 512.6015  | 3.6907   |
| 332.925 | -4.27E-05 | 422.7389    | -65.0422   | -2.2288E-06 | 511.8896  | 4.0930   |
| 334.650 | -4.65E-05 | 316.9663    | -57.6503   | -2.1094E-06 | 511.2511  | 4.4774   |
| 336.375 | -5.00E-05 | 224.5004    | -49.6066   | -2.0220E-06 | 510.6930  | 4.8488   |
| 338.100 | -5.34E-05 | 146.4514    | -40.9289   | -1.9621E-06 | 510.2219  | 5.2122   |
| 339.825 | -5.68E-05 | 83.9048     | -31.6278   | -1.9250E-06 | 509.8443  | 5.5717   |
| 341.550 | -6.01E-05 | 37.9333     | -21.7071   | -1.9053E-06 | 509.5668  | 5.9205   |
| 343.275 | -6.34E-05 | 9.6070      | -11.1660   | -1.8976E-06 | 509.3959  | 6.2911   |
| 345.000 | -6.66E-05 | 0.0000      | 0.0000     | -1.8961E-06 | 509.3379  | 6.6550   |

Output Verification:

Computed forces and moments are within specified convergence limits.

Output Summary for Load Case No. 1:

|                                  |   |                  |
|----------------------------------|---|------------------|
| File-head deflection             | = | 1.00000000 in    |
| Computed slope at pile head      | = | -0.0001373       |
| Maximum bending moment           | = | -2112883. lbs-in |
| Maximum shear force              | = | 49644.62898 lbs  |
| Depth of maximum bending moment  | = | 0.00000 in       |
| Depth of maximum shear force     | = | 0.00000 in       |
| Number of iterations             | = | 16               |
| Number of zero deflection points | = | 3                |

Summary of File-Head Response(s)

Definition of Symbols for File-Head Loading Conditions:

Type 1 = Shear and Moment.      y = pile-head displacement in  
 Type 2 = Shear and Slope,      M = pile-head moment lbs-in  
 Type 3 = Shear and Rot. Stiffness, V = pile-head shear force lbs  
 Type 4 = Deflection and Moment,    S = pile-head slope, radians  
 Type 5 = Deflection and Slope,    R = rotational stiffness of pile-head-in-lbs/rad

| Load Type | Boundary Condition | Boundary Condition | Axial Load lbs | File-Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|-----------|--------------------|--------------------|----------------|-------------------------|-----------------------|-------------------|
|           | 1                  | 2                  |                |                         |                       |                   |
| 5         | y = 1.000000       | S = 0.000          | 90000.0000     | 1.0000000               | -2112883.             | 49644.6290        |

File-head Deflection vs. File Length

Boundary Condition Type 5, Deflection and Slope

Deflection = 1.00000 in  
 Slope = .00000  
 Axial Load = 90000. lbs

| File Length in | File Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|----------------|-------------------------|-----------------------|-------------------|
| 345.000        | 1.00000000              | -2112883.             | 49644.62899       |
| 327.750        | 1.00000000              | -2112885.             | 49645.72730       |
| 310.500        | 1.00000000              | -2112337.             | 49633.49194       |
| 293.250        | 1.00000000              | -2112890.             | 49642.84288       |
| 276.000        | 1.00000000              | -2112666.             | 49638.14646       |
| 258.750        | 1.00000000              | -2112611.             | 49631.05662       |
| 241.500        | 1.00000000              | -2112841.             | 49621.47901       |
| 224.250        | 1.00000000              | -2112712.             | 49615.46783       |
| 207.000        | 1.00000000              | -2081330.             | 49014.45770       |
| 189.750        | 1.00000000              | -2037935.             | 48080.75300       |

The analysis ended normally.



LPILS Plus for Windows, Version 5.0 (5.0.11)  
 Analysis of Individual Piles and Drilled Shafts  
 Subjected to Lateral Loading Using the p-y Method  
 (c) Copyright ENSOFF, Inc., 1985-2005  
 All Rights Reserved

This program is licensed to:

Youniel Zhou  
 Kleinfelder

Path to file locations: U:\YZhou\Projects\75010\Analysis\LPILS\B2B3\  
 Name of input data file: B2f6mm.lpd  
 Name of output file: B2f6mm.lpo  
 Name of plot output file: B2f6mm.lpp  
 Name of runtime file: B2f6mm.lpr

Time and Date of Analysis

Date: May 30, 2007 Time: 12:59:40

Problem Title

B2-B3, fixed head, 0.25 in

Program Options

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
 - Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:

- Only internally-generated p-y curves used in analysis
- Analysis does not use p-y multipliers (individual pile or shaft action only)
- Analysis assumes no shear resistance at pile tip
- Analysis includes automatic computation of pile-top deflection vs. pile embedment length
- No computation of foundation stiffness matrix elements
- Output pile response for full length of pile
- Analysis assumes no soil movements acting on pile
- No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:

- Number of pile increments = 200
- Maximum number of iterations allowed = 200
- Deflection tolerance for convergence = 1.0000E-05 in
- Maximum allowable deflection = 1.0000E+01 in

Printing Options:

- Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile.
- Printing increment (spacing of output points) = 1

Pile Structural Properties and Geometry

File Length = 345.00 in  
 Depth of ground surface below top of pile = -99.00 in  
 Slope angle of ground surface = .00 deg.

Structural properties of pile defined using 2 points

| Point | Depth<br>X<br>in | Pile<br>Diameter<br>in | Moment of<br>Inertia<br>in <sup>4</sup> | Pile<br>Area<br>Sq.in | Modulus of<br>Elasticity<br>lbs/Sq.in |
|-------|------------------|------------------------|---|-----------------------|---------------------------------------|
| 1     | 0.0000           | 15.00000000            | 2485.0000                               | 176.7000              | 4300000.                              |
| 2     | 300.0000         | 15.00000000            | 2485.0000                               | 176.7000              | 4300000.                              |

Soil and Rock Layering Information

The soil profile is modelled using 5 layers

Layer 1 is stiff clay without free water  
 Distance from top of pile to top of layer = -99.000 in  
 Distance from top of pile to bottom of layer = 129.000 in

Layer 2 is stiff clay with water-induced erosion  
 Distance from top of pile to top of layer = 129.000 in  
 Distance from top of pile to bottom of layer = 153.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 3 is sand, p-y criteria by Reese et al., 1978  
 Distance from top of pile to top of layer = 153.000 in  
 Distance from top of pile to bottom of layer = 213.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 213.000 in  
 Distance from top of pile to bottom of layer = 273.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 273.000 in  
 Distance from top of pile to bottom of layer = 450.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends 105.00 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth is defined using 10 points

| Point No. | Depth X in | Eff. Unit Weight lbs/in**3 |
|-----------|------------|----------------------------|
| 1         | -99.00     | .07234                     |
| 2         | 129.00     | .07234                     |
| 3         | 129.00     | .03623                     |
| 4         | 153.00     | .03623                     |
| 5         | 153.00     | .03623                     |
| 6         | 213.00     | .03623                     |
| 7         | 213.00     | .03333                     |
| 8         | 273.00     | .03333                     |
| 9         | 273.00     | .03622                     |
| 10        | 450.00     | .03622                     |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth defined using 10 points

| Point No. | Depth X in | Cohesion c lbs/in**2 | Angle of Friction Deg. | E50 or k <sub>ms</sub> | RQD % |
|-----------|------------|----------------------|------------------------|------------------------|-------|
| 1         | -99.000    | 6.25000              | .00                    | -----                  | ----- |
| 2         | 129.000    | 6.25000              | .00                    | -----                  | ----- |
| 3         | 129.000    | 6.25000              | .00                    | -----                  | ----- |
| 4         | 153.000    | 6.25000              | .00                    | -----                  | ----- |
| 5         | 153.000    | .00000               | 30.00                  | -----                  | ----- |
| 6         | 213.000    | .00000               | 30.00                  | -----                  | ----- |
| 7         | 213.000    | 5.56000              | 25.00                  | -----                  | ----- |
| 8         | 273.000    | 5.56000              | 25.00                  | -----                  | ----- |
| 9         | 273.000    | 3.47000              | 32.00                  | -----                  | ----- |
| 10        | 450.000    | 3.47000              | 32.00                  | -----                  | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k<sub>ms</sub> are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 Pile-head Loading and Pile-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number 1

Pile-head boundary conditions are Displacement and Slope (BC Type 5)  
 Deflection at pile head = .250 in  
 Slope at pile head = .000 in/in  
 Axial load at pile head = 90000.000 lbs

-----  
 Computed Values of Load Distribution and Deflection for Lateral Loading for Load Case Number 1  
 -----

Pile-head boundary conditions are Displacement and Slope (BC Type 5)  
 Specified deflection at pile head = .250000 in  
 Specified slope at pile head = 0.000E+00 in/in  
 Specified axial load at pile head = 90000.000 lbs

| Depth X | Deflect. y | Moment M | Shear V | Slope S | Total Stress | Soil Res p |
|---------|------------|----------|---------|---------|--------------|------------|
|---------|------------|----------|---------|---------|--------------|------------|



|         |           |             |            |             |          |            |
|---------|-----------|-------------|------------|-------------|----------|------------|
| 194.925 | -0.06425  | 30005.8966  | -2884.1428 | 0.001407    | 599.8989 | 29.0446    |
| 196.650 | -0.06178  | 25051.7465  | -2834.7735 | 0.001451    | 581.9468 | 28.1952    |
| 198.375 | -0.05924  | 20180.8666  | -2786.9157 | 0.001488    | 570.2459 | 27.2922    |
| 200.100 | -0.05665  | 15390.6924  | -2740.4564 | 0.001516    | 555.7886 | 26.3413    |
| 201.825 | -0.05401  | 10678.5143  | -2696.0748 | 0.001538    | 541.5668 | 25.3479    |
| 203.550 | -0.05134  | 6041.4943   | -2653.2383 | 0.001551    | 527.5717 | 24.3177    |
| 205.275 | -0.04866  | 1476.6832   | -2612.2057 | 0.001557    | 513.7947 | 23.2564    |
| 207.000 | -0.04597  | -3018.9626  | -2573.0255 | 0.001556    | 501.4494 | 22.1700    |
| 208.725 | -0.04329  | -7448.5634  | -2535.7398 | 0.001547    | 531.8184 | 21.0644    |
| 210.450 | -0.04065  | -11815.2975 | -2500.3643 | 0.001532    | 544.9977 | 19.9460    |
| 212.175 | -0.03801  | -16122.3837 | -2466.9278 | 0.001509    | 557.9970 | 18.8209    |
| 213.900 | -0.03543  | -20373.0618 | -2251.2799 | 0.001480    | 570.8260 | 231.2056   |
| 215.625 | -0.03290  | -23935.2481 | -1900.7200 | 0.001444    | 581.5770 | 175.2406   |
| 217.350 | -0.03045  | -26975.3840 | -1608.4739 | 0.001403    | 590.7525 | 163.5954   |
| 219.075 | -0.02806  | -29528.0453 | -1336.1658 | 0.001357    | 598.4587 | 152.1241   |
| 220.800 | -0.02576  | -31827.3022 | -1083.4527 | 0.001308    | 604.7825 | 140.8785   |
| 222.525 | -0.02355  | -33306.5707 | -849.3111  | 0.001256    | 609.8607 | 129.8961   |
| 224.250 | -0.02143  | -34598.4815 | -635.0461  | 0.001201    | 613.7598 | 119.2224   |
| 225.975 | -0.01941  | -35534.7640 | -438.3010  | 0.001144    | 616.5856 | 108.8879   |
| 227.700 | -0.01748  | -36146.1463 | -259.0655  | 0.001086    | 618.4109 | 98.9213    |
| 229.425 | -0.01566  | -36482.2700 | -96.6846   | 0.001028    | 619.3850 | 89.3465    |
| 231.150 | -0.01394  | -36511.6183 | 49.5343    | 9.6880E-05  | 619.5339 | 80.1827    |
| 232.875 | -0.01232  | -36321.4578 | 180.3136   | 9.1001E-05  | 618.9600 | 71.4454    |
| 234.600 | -0.01080  | -35917.7923 | 296.3984   | 8.5170E-05  | 617.7417 | 63.1458    |
| 236.325 | -0.00938  | -35325.3286 | 398.5507   | 7.9420E-05  | 615.9535 | 55.2917    |
| 238.050 | -0.00806  | -34567.4521 | 487.5428   | 7.3778E-05  | 613.6662 | 47.8875    |
| 239.775 | -0.00683  | -33666.2141 | 564.1519   | 6.8271E-05  | 610.9462 | 40.9947    |
| 241.500 | -0.00570  | -32642.3261 | 629.1554   | 6.2918E-05  | 607.8859 | 34.4317    |
| 243.225 | -0.00466  | -31515.1643 | 683.3257   | 5.7740E-05  | 604.4541 | 28.3745    |
| 244.950 | -0.00371  | -30302.9220 | 727.4264   | 5.2750E-05  | 600.7948 | 22.7580    |
| 246.675 | -0.00284  | -29021.9220 | 762.2086   | 4.7962E-05  | 596.9292 | 17.5704    |
| 248.400 | -0.00206  | -27688.0530 | 788.4072   | 4.3384E-05  | 592.9034 | 12.8048    |
| 250.125 | -0.00135  | -26315.3878 | 806.7381   | 3.9025E-05  | 588.7606 | 8.4484     |
| 251.850 | -0.00072  | -24916.9238 | 817.8958   | 3.4890E-05  | 584.5398 | 4.4880     |
| 253.575 | -0.00019  | -23504.4808 | 822.5507   | 3.0981E-05  | 580.2769 | .9090891   |
| 255.300 | 3.59E-05  | -22088.7436 | 821.3480   | 2.7301E-05  | 576.0041 | -2.3036    |
| 257.025 | 7.39E-05  | -20678.7808 | 814.9053   | 2.3849E-05  | 571.7503 | -5.1662    |
| 258.750 | 0.000118  | -19284.7255 | 803.8120   | 2.0623E-05  | 567.5413 | -7.6956    |
| 260.475 | 0.000151  | -17912.5596 | 788.6280   | 1.7621E-05  | 563.3999 | -9.9090    |
| 262.200 | 0.000179  | -16569.4304 | 769.8831   | 1.4838E-05  | 559.3462 | -11.8241   |
| 263.925 | 0.000202  | -15261.0701 | 748.0767   | 1.2268E-05  | 555.3974 | -13.4587   |
| 265.650 | 0.000221  | -13992.3753 | 723.6773   | 9.9072E-06  | 551.5684 | -14.8305   |
| 267.375 | 0.000236  | -12767.4599 | 697.1227   | 7.7472E-06  | 547.8714 | -15.9574   |
| 269.100 | 0.000248  | -11589.7075 | 668.8203   | 5.7812E-06  | 544.3169 | -16.8570   |
| 270.825 | 0.000256  | -10461.8248 | 639.1471   | 4.0013E-06  | 540.9128 | -17.5467   |
| 272.550 | 0.000262  | -9385.8925  | 608.4503   | 2.3992E-06  | 537.6655 | -18.0436   |
| 274.275 | 0.000265  | -8363.4161  | 578.8844   | 9.6657E-07  | 534.5796 | -16.2357   |
| 276.000 | 0.000265  | -7389.0413  | 547.4011   | -3.0492E-07 | 531.6388 | -20.2668   |
| 277.725 | 0.000264  | -6474.7878  | 512.4093   | -1.4240E-06 | 528.8795 | -20.3024   |
| 279.450 | 0.000260  | -5620.7049  | 477.4793   | -2.4003E-06 | 526.3020 | -19.1966   |
| 281.175 | 0.000255  | -4826.7308  | 442.8405   | -3.2435E-06 | 523.9055 | -19.9643   |
| 282.900 | 0.000249  | -4091.9779  | 408.6988   | -3.9635E-06 | 521.6879 | -19.6203   |
| 284.625 | 0.000242  | -3415.4974  | 375.2347   | -4.5694E-06 | 519.6462 | -19.1786   |
| 286.350 | 0.000233  | -2795.9995  | 342.6057   | -5.0708E-06 | 517.7765 | -18.6521   |
| 288.075 | 0.000224  | -2231.9332  | 310.9474   | -5.4767E-06 | 516.0741 | -18.0531   |
| 289.800 | 0.000214  | -1721.5303  | 280.3752   | -5.7958E-06 | 514.5336 | -17.3930   |
| 291.525 | 0.000204  | -1262.8393  | 250.9853   | -6.0367E-06 | 513.1492 | -16.6822   |
| 293.250 | 0.000194  | -853.7867   | 222.8568   | -6.2075E-06 | 511.9146 | -15.9305   |
| 294.975 | 0.000183  | -492.0559   | 196.0527   | -6.3161E-06 | 510.8229 | -15.1467   |
| 296.700 | 0.000172  | -175.4138   | 170.6215   | -6.3700E-06 | 509.8673 | -14.3387   |
| 298.425 | 0.000161  | 98.5661     | 146.5987   | -6.3762E-06 | 509.0353 | -13.5138   |
| 300.150 | 0.000150  | 332.3314    | 124.0080   | -6.3414E-06 | 510.3409 | -12.6783   |
| 301.875 | 0.000139  | 528.3626    | 102.8629   | -6.2720E-06 | 510.9325 | -11.8378   |
| 303.600 | 0.000128  | 689.1539    | 83.1678    | -6.1737E-06 | 511.4178 | -10.9971   |
| 305.325 | 0.000118  | 818.1086    | 64.9195    | -6.0521E-06 | 511.8043 | -10.1604   |
| 307.050 | 0.000107  | 915.0074    | 48.1081    | -5.9122E-06 | 512.0995 | -9.3311    |
| 308.775 | 9.72E-05  | 985.0173    | 32.7184    | -5.7589E-06 | 512.3107 | -8.5120    |
| 310.500 | 8.74E-05  | 1029.6739   | 18.7309    | -5.5963E-06 | 512.4455 | -7.7053    |
| 312.225 | 7.79E-05  | 1051.3766   | 6.1230     | -5.4283E-06 | 512.5110 | -6.9126    |
| 313.950 | 6.87E-05  | 1052.4937   | -5.1304    | -5.2585E-06 | 512.5144 | -6.1348    |
| 315.675 | 5.97E-05  | 1035.3096   | -15.0559   | -5.0900E-06 | 512.4625 | -5.3728    |
| 317.400 | 5.11E-05  | 1002.2226   | -23.6793   | -4.9255E-06 | 512.3624 | -4.6280    |
| 319.125 | 4.28E-05  | 955.1452    | -31.0285   | -4.7675E-06 | 512.2206 | -3.8947    |
| 320.850 | 3.47E-05  | 896.5547    | -37.1287   | -4.6181E-06 | 512.0438 | -3.1780    |
| 322.575 | 2.69E-05  | 828.4851    | -42.0043   | -4.4788E-06 | 511.8383 | -2.4748    |
| 324.300 | 1.92E-05  | 753.0305    | -45.6775   | -4.3512E-06 | 511.6106 | -1.7839    |
| 326.025 | 1.18E-05  | 672.2489    | -48.1680   | -4.2361E-06 | 511.3668 | -1.1036    |
| 327.750 | 4.60E-06  | 588.1664    | -49.4927   | -4.1348E-06 | 511.1130 | -0.432713  |
| 329.475 | -2.45E-06 | 502.7829    | -49.6654   | -4.0463E-06 | 510.8553 | -0.2320486 |
| 331.200 | -9.36E-06 | 418.0773    | -48.6965   | -3.9720E-06 | 510.5997 | .8913090   |
| 332.925 | -1.62E-05 | 336.0134    | -46.5930   | -3.9111E-06 | 510.3520 | 1.5475     |
| 334.650 | -2.29E-05 | 258.5460    | -43.3584   | -3.8632E-06 | 510.1182 | 2.2027     |
| 336.375 | -2.95E-05 | 187.6264    | -38.9929   | -3.8271E-06 | 509.9041 | 2.8587     |
| 338.100 | -3.61E-05 | 125.2086    | -33.4935   | -3.8019E-06 | 509.7158 | 3.5175     |
| 339.825 | -4.26E-05 | 75.2544     | -26.8540   | -3.7859E-06 | 509.5590 | 4.1805     |
| 341.550 | -4.91E-05 | 33.7378     | -19.0660   | -3.7772E-06 | 509.4397 | 4.8491     |
| 343.275 | -5.56E-05 | 8.6495      | -10.1187   | -3.7738E-06 | 509.3640 | 5.5245     |
| 345.000 | -6.21E-05 | 0.0000      | 0.0000     | -3.7731E-06 | 509.3379 | 6.2073     |

Output Verification:

Computed forces and moments are within specified convergence limits.

Output Summary for Load Case No. 1:

|                                  |   |                  |
|----------------------------------|---|------------------|
| File-head deflection             | = | .25000000 in     |
| Computed slope at pile head      | = | -.00000444       |
| Maximum bending moment           | = | -1248877. lbs-in |
| Maximum shear force              | = | 32182.49778 lbs  |
| Depth of maximum bending moment  | = | 0.00000 in       |
| Depth of maximum shear force     | = | 0.00000 in       |
| Number of iterations             | = | 16               |
| Number of zero deflection points | = | 3                |

Summary of File-Head Response(s)

Definition of Symbols for File-Head Loading Conditions:

File: U:\Yzhou\projects\75010\Analysis\Appendix C\12 B2f6m.ip0

Type 1 = Shear and Moment, y = pile-head displacement in  
 Type 2 = Shear and Slope, M = pile-head moment lbs-in  
 Type 3 = Shear and Rot. Stiffness, V = pile-head shear force lbs  
 Type 4 = Deflection and Moment, S = pile-head slope, radians  
 Type 5 = Deflection and Slope, R = rotational stiffness of pile-head=lbs/rad

| Load Type | Boundary Condition 1 | Boundary Condition 2 | Axial Load lbs | Pile-Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|-----------|----------------------|----------------------|----------------|-------------------------|-----------------------|-------------------|
| 5         | y = .250000          | S = 0.000            | 90000.0000     | .2500000                | -1248877.             | 32182.4978        |

File-head Deflection vs. File Length

Boundary Condition Type 5, Deflection and Slope

Deflection = .25000 in  
 Slope = .00000  
 Axial Load = 90000. lbs

| File Length in | File Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|----------------|-------------------------|-----------------------|-------------------|
| 345.000        | .25000000               | -1248877.             | 32182.49769       |
| 327.750        | .25000000               | -1248923.             | 32184.80379       |
| 310.500        | .25000000               | -1249273.             | 32187.43227       |
| 293.250        | .25000000               | -1248720.             | 32179.03485       |
| 276.000        | .25000000               | -1249092.             | 32181.91299       |
| 258.750        | .25000000               | -1249631.             | 32189.43762       |
| 241.500        | .25000000               | -1248753.             | 32160.29011       |
| 224.250        | .25000000               | -1249087.             | 32164.53266       |
| 207.000        | .25000000               | -1232445.             | 31804.84622       |
| 189.750        | .25000000               | -1213728.             | 31355.04485       |

The analysis ended normally.

LPFILE Plus for Windows, Version 5.0 (5.0.11)  
 Analysis of Individual Piles and Drilled Shafts  
 Subjected to Lateral Loading Using the p-y Method  
 (c) Copyright ENSOFT, Inc., 1985-2005  
 All Rights Reserved

This program is licensed to:

Youwei Zhou  
 Kleinfelder

Path to file locations: U:\YZhou\Projects\75010\Analysis\LPFILE\B2B3\  
 Name of input data file: B2stability.ipd  
 Name of output file: B2stability.lpo  
 Name of plot output file: B2stability.lpp  
 Name of runtime file: B2stability.lpr

Time and Date of Analysis

Date: May 30, 2007 Time: 12:56: 7

Problem Title

B2-B3 Stability

Program Options

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
 - Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:  
 - Only internally-generated p-y curves used in analysis  
 - Analysis does not use p-y multipliers (individual pile or shaft action only)  
 - Analysis assumes no shear resistance at pile tip  
 - Analysis includes automatic computation of pile-top deflection vs. pile embedment length  
 - No computation of foundation stiffness matrix elements  
 - Output pile response for full length of pile  
 - Analysis assumes no soil movement acting on pile  
 - No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:  
 - Number of pile increments = 200  
 - Maximum number of iterations allowed = 200  
 - Deflection tolerance for convergence = 1.0000E-05 in  
 - Maximum allowable deflection = 1.0000E+01 in

Printing Options:  
 - Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile.  
 - Printing increment (spacing of output points) = 1

Pile Structural Properties and Geometry

Pile length = 210.00 in  
 Depth of ground surface below top of pile = -99.00 in  
 Slope angle of ground surface = .00 deg.

Structural properties of pile defined using 2 points

| Point | Depth X<br>in | Pile Diameter<br>in | Moment of Inertia<br>in <sup>4</sup> | Pile Area<br>Sq.in | Modulus of Elasticity<br>lbs/Sq.in |
|-------|---------------|---------------------|--------------------------------------|--------------------|------------------------------------|
| 1     | 0.0000        | 15.00000000         | 1242.5000                            | 176.7000           | 4300000.                           |
| 2     | 500.0000      | 15.00000000         | 1242.5000                            | 176.7000           | 4300000.                           |

Soil and Rock Layering Information

The soil profile is modelled using 5 layers

Layer 1 is stiff clay without free water  
 Distance from top of pile to top of layer = -99.000 in  
 Distance from top of pile to bottom of layer = 129.000 in

Layer 2 is stiff clay with water-induced erosion  
 Distance from top of pile to top of layer = 129.000 in  
 Distance from top of pile to bottom of layer = 153.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 3 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = 153.000 in  
 Distance from top of pile to bottom of layer = 213.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 213.000 in  
 Distance from top of pile to bottom of layer = 273.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 273.000 in  
 Distance from top of pile to bottom of layer = 450.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends 240.00 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth is defined using 10 points

| Point No. | Depth X in | Eff. Unit Weight lbs/in**3 |
|-----------|------------|----------------------------|
| 1         | -99.00     | .07234                     |
| 2         | 129.00     | .07234                     |
| 3         | 129.00     | .03623                     |
| 4         | 153.00     | .03623                     |
| 5         | 153.00     | .03623                     |
| 6         | 213.00     | .03623                     |
| 7         | 213.00     | .03333                     |
| 8         | 273.00     | .03333                     |
| 9         | 273.00     | .03623                     |
| 10        | 450.00     | .03623                     |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth defined using 10 points

| Point No. | Depth X in | Cohesion c lbs/in**2 | Angle of Friction Deg. | E50 or k <sub>sm</sub> | RQD % |
|-----------|------------|----------------------|------------------------|------------------------|-------|
| 1         | -99.000    | 9.68000              | .00                    | -----                  | ----- |
| 2         | 129.000    | 9.68000              | .00                    | -----                  | ----- |
| 3         | 129.000    | 6.25000              | .00                    | -----                  | ----- |
| 4         | 153.000    | 6.25000              | .00                    | -----                  | ----- |
| 5         | 153.000    | .00000               | 30.00                  | -----                  | ----- |
| 6         | 213.000    | .00000               | 30.00                  | -----                  | ----- |
| 7         | 213.000    | 5.56000              | 25.00                  | -----                  | ----- |
| 8         | 273.000    | 5.56000              | 25.00                  | -----                  | ----- |
| 9         | 273.000    | 3.47000              | 32.00                  | -----                  | ----- |
| 10        | 450.000    | 3.47000              | 32.00                  | -----                  | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k<sub>sm</sub> are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 Pile-head Loading and Pile-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number 1

Pile-head boundary conditions are Shear and Moment (BC Type 1)  
 Shear force at pile head = 38000.000 lbs  
 Bending moment at pile head = .000 in-lbs  
 Axial load at pile head = 90000.000 lbs

(Zero moment at pile head for this load indicates a free-head condition)

-----  
 Computed Values of Load Distribution and Deflection for Lateral Loading for Load Case Number 1  
 -----

Pile-head boundary conditions are Shear and Moment (BC Type 1)  
 Specified shear force at pile head = 38000.000 lbs  
 Specified moment at pile head = .000 in-lbs  
 Specified axial load at pile head = 90000.000 lbs





|         |          |            |             |             |           |          |
|---------|----------|------------|-------------|-------------|-----------|----------|
| 114.450 | -.026966 | 227261.    | -13382.9963 | -.0006751   | 2484.7558 | 369.9128 |
| 115.500 | -.027641 | 313473.    | -12993.3835 | -.0006121   | 2401.5316 | 372.2067 |
| 116.550 | -.028251 | 300090.    | -12601.4964 | -.0005518   | 2320.7492 | 374.2449 |
| 117.800 | -.028800 | 287115.    | -12207.5925 | -.0004941   | 2242.4230 | 376.0484 |
| 118.650 | -.029289 | 274548.    | -11811.9085 | -.0004389   | 2166.5688 | 377.6354 |
| 119.700 | -.029722 | 262393.    | -11414.6633 | -.0003861   | 2093.1961 | 379.0222 |
| 120.750 | -.030100 | 250650.    | -11016.0596 | -.0003357   | 2022.3264 | 380.2230 |
| 121.800 | -.030427 | 239322.    | -10616.2860 | -.0002876   | 1953.9390 | 381.2506 |
| 122.850 | -.030704 | 228410.    | -10215.5183 | -.0002416   | 1888.0719 | 382.1164 |
| 123.900 | -.030934 | 217915.    | -9813.9211  | -.0001978   | 1824.7221 | 382.8306 |
| 124.950 | -.031119 | 207838.    | -9411.6487  | -.0001559   | 1763.8957 | 383.4024 |
| 126.000 | -.031262 | 198180.    | -9008.8464  | -.0001160   | 1705.5974 | 383.8401 |
| 127.050 | -.031363 | 188942.    | -8605.6510  | -7.7994E-05 | 1649.8314 | 384.1511 |
| 128.100 | -.031425 | 180123.    | -8202.1920  | -4.1728E-05 | 1596.6007 | 384.3422 |
| 129.150 | -.031451 | 171725.    | -7882.2263  | -7.1543E-06 | 1545.9076 | 225.1164 |
| 130.200 | -.031440 | 163572.    | -7645.8732  | 2.5793E-05  | 1496.6933 | 225.0799 |
| 131.250 | -.031396 | 155664.    | -7409.6219  | 5.7163E-05  | 1448.9586 | 224.9226 |
| 132.300 | -.031320 | 148001.    | -7173.5963  | 8.7002E-05  | 1402.7033 | 224.6489 |
| 133.350 | -.031214 | 140583.    | -6937.8148  | 0.0001154   | 1357.9264 | 224.2673 |
| 134.400 | -.031078 | 133409.    | -6702.6903  | 0.0001423   | 1314.6263 | 223.7795 |
| 135.450 | -.030915 | 126480.    | -6468.0305  | 0.0001678   | 1272.8004 | 223.1914 |
| 136.500 | -.030726 | 119795.    | -6234.0388  | 0.0001920   | 1232.4457 | 222.5072 |
| 137.550 | -.030512 | 113353.    | -6000.8137  | 0.0002149   | 1193.5584 | 221.7311 |
| 138.600 | -.030274 | 107153.    | -5768.4498  | 0.0002366   | 1156.1339 | 220.8669 |
| 139.650 | -.030015 | 101194.    | -5537.0375  | 0.0002571   | 1120.1672 | 219.9184 |
| 140.700 | -.029724 | 95476.     | -5306.6637  | 0.0002764   | 1085.6528 | 218.8889 |
| 141.750 | -.029404 | 89987.8336 | -5077.4116  | 0.0002946   | 1052.5843 | 217.7817 |
| 142.800 | -.029116 | 84757.9259 | -4849.3614  | 0.0003118   | 1020.9551 | 216.5997 |
| 143.850 | -.028780 | 79755.2454 | -4622.5900  | 0.0003280   | 990.7579  | 215.3458 |
| 144.900 | -.028427 | 74988.5024 | -4397.1716  | 0.0003432   | 961.9840  | 214.0227 |
| 145.950 | -.028059 | 70456.3267 | -4173.1775  | 0.0003575   | 934.6276  | 212.6326 |
| 147.000 | -.027676 | 66157.2698 | -3950.6769  | 0.0003709   | 908.6775  | 211.1780 |
| 148.050 | -.027280 | 62098.8083 | -3729.7365  | 0.0003835   | 884.1254  | 209.6608 |
| 149.100 | -.026871 | 58252.3447 | -3510.4210  | 0.0003953   | 860.9617  | 208.0830 |
| 150.150 | -.026450 | 54643.2107 | -3292.7932  | 0.0004064   | 839.1762  | 206.4462 |
| 151.200 | -.026018 | 51260.6688 | -3076.9141  | 0.0004168   | 818.7584  | 204.7520 |
| 152.250 | -.025575 | 48102.9140 | -2862.8435  | 0.0004266   | 799.6975  | 203.0016 |
| 153.300 | -.025122 | 45160.0750 | -2702.6837  | 0.0004357   | 781.9822  | 102.0646 |
| 154.350 | -.024660 | 42344.8235 | -2596.1619  | 0.0004443   | 764.9110  | 100.8242 |
| 155.400 | -.024189 | 39632.1552 | -2490.9636  | 0.0004524   | 748.5662  | 99.5435  |
| 156.450 | -.023710 | 37028.3976 | -2387.1513  | 0.0004599   | 732.8493  | 98.1942  |
| 157.500 | -.023223 | 34532.2114 | -2284.7856  | 0.0004670   | 717.7818  | 96.7879  |
| 158.550 | -.022729 | 32142.0926 | -2183.9257  | 0.0004735   | 703.3545  | 95.3262  |
| 159.600 | -.022228 | 29856.4740 | -2084.6289  | 0.0004796   | 689.5580  | 93.8106  |
| 160.650 | -.021722 | 27673.7271 | -1986.9510  | 0.0004853   | 676.3825  | 92.2425  |
| 161.700 | -.021209 | 25592.1637 | -1890.9463  | 0.0004905   | 663.8177  | 90.6235  |
| 162.750 | -.020692 | 23610.0373 | -1796.6677  | 0.0004953   | 651.8332  | 88.9548  |
| 163.800 | -.020169 | 21725.5451 | -1704.1666  | 0.0004998   | 640.4780  | 87.2379  |
| 164.850 | -.019642 | 19936.8291 | -1613.4929  | 0.0005039   | 629.6809  | 85.4740  |
| 165.900 | -.019111 | 18241.9780 | -1524.6952  | 0.0005076   | 619.4504  | 83.6644  |
| 166.950 | -.018576 | 16639.0281 | -1437.8209  | 0.0005111   | 609.7747  | 81.8104  |
| 168.000 | -.018038 | 15125.9653 | -1352.9160  | 0.0005142   | 600.6415  | 79.9131  |
| 169.050 | -.017496 | 13700.7257 | -1270.0254  | 0.0005170   | 592.0384  | 77.9737  |
| 170.100 | -.016952 | 12361.1977 | -1189.1929  | 0.0005196   | 583.9527  | 75.9931  |
| 171.150 | -.016405 | 11105.2225 | -1110.4610  | 0.0005219   | 576.3714  | 73.9725  |
| 172.200 | -.015856 | 9930.5957  | -1033.8712  | 0.0005239   | 569.2811  | 71.9127  |
| 173.250 | -.015305 | 8835.0682  | -959.4643   | 0.0005258   | 562.6643  | 69.8148  |
| 174.300 | -.014752 | 7816.3474  | -887.2798   | 0.0005274   | 556.5190  | 67.6796  |
| 175.350 | -.014197 | 6872.0981  | -817.3564   | 0.0005289   | 550.8123  | 65.5079  |
| 176.400 | -.013641 | 5999.9437  | -749.7320   | 0.0005301   | 545.5548  | 63.3005  |
| 177.450 | -.013084 | 5197.4665  | -684.4438   | 0.0005312   | 540.7109  | 61.0581  |
| 178.500 | -.012526 | 4462.2094  | -621.5280   | 0.0005322   | 536.2727  | 58.7814  |
| 179.550 | -.011967 | 3791.6759  | -561.0204   | 0.0005330   | 532.2252  | 56.4711  |
| 180.600 | -.011407 | 3183.3315  | -502.9560   | 0.0005337   | 528.5531  | 54.1277  |
| 181.650 | -.010846 | 2634.6038  | -447.3693   | 0.0005342   | 525.2409  | 51.7518  |
| 182.700 | -.010285 | 2142.8835  | -394.2940   | 0.0005347   | 522.2728  | 49.3438  |
| 183.750 | -.009723 | 1705.5250  | -343.7637   | 0.0005351   | 519.6328  | 46.9043  |
| 184.800 | -.009161 | 1319.8469  | -295.8114   | 0.0005354   | 517.3047  | 44.4335  |
| 185.850 | -.008599 | 983.1322   | -250.4695   | 0.0005356   | 515.2723  | 41.9320  |
| 186.900 | -.008036 | 692.6292   | -207.7703   | 0.0005358   | 513.5187  | 39.3998  |
| 187.950 | -.007474 | 445.5518   | -167.7457   | 0.0005359   | 512.0273  | 36.8375  |
| 189.000 | -.006911 | 239.0793   | -130.4273   | 0.0005360   | 510.7810  | 34.2452  |
| 190.050 | -.006348 | 70.3578    | -95.8465    | 0.0005360   | 509.7626  | 31.6230  |
| 191.100 | -.005785 | -63.5007   | -64.0345    | 0.0005360   | 509.7212  | 28.9713  |
| 192.150 | -.005222 | -165.4172  | -35.0222    | 0.0005360   | 510.3364  | 26.2901  |
| 193.200 | -.004660 | -238.3457  | -8.8407     | 0.0005359   | 510.7766  | 23.5795  |
| 194.250 | -.004097 | -285.2735  | 14.4793     | 0.0005359   | 511.0598  | 20.8396  |
| 195.300 | -.003534 | -309.2204  | 34.9070     | 0.0005358   | 511.2044  | 18.0704  |
| 196.350 | -.002972 | -313.2381  | 52.4119     | 0.0005358   | 511.2286  | 15.2721  |
| 197.400 | -.002409 | -300.4139  | 66.9631     | 0.0005357   | 511.1512  | 12.4445  |
| 198.450 | -.001847 | -273.8634  | 78.5301     | 0.0005356   | 510.9910  | 9.5078   |
| 199.500 | -.001284 | -236.7372  | 87.0821     | 0.0005356   | 510.7669  | 6.7018   |
| 200.550 | -.000722 | -192.2179  | 92.5885     | 0.0005356   | 510.4981  | 3.7865   |
| 201.600 | -.000160 | -143.5204  | 95.0184     | 0.0005355   | 510.2042  | 0.819642 |
| 202.650 | 0.000403 | -93.8919   | 94.3412     | 0.0005355   | 509.9046  | -2.1320  |
| 203.700 | 0.000965 | -46.6322   | 90.3259     | 0.0005355   | 509.6192  | -5.1353  |
| 204.750 | 0.001527 | -4.8933    | 83.5415     | 0.0005355   | 509.3680  | -8.1682  |
| 205.800 | 0.002089 | 27.6202    | 73.3572     | 0.0005355   | 509.5046  | -11.2305 |
| 206.850 | 0.002652 | 47.8517    | 59.9420     | 0.0005355   | 509.6267  | -14.3224 |
| 207.900 | 0.003214 | 52.2918    | 43.2647     | 0.0005355   | 509.6535  | -17.4438 |
| 208.950 | 0.003776 | 37.4992    | 23.2944     | 0.0005355   | 509.5642  | -20.5849 |
| 210.000 | 0.004338 | 0.0000     | 0.0000      | 0.0005355   | 509.3379  | -23.7755 |

Output Verification:

Computed forces and moments are within specified convergence limits.

Output Summary for Load Case No. 1:

File-head deflection = .99683260 in  
 Computed slope at pile head = -.01680133  
 Maximum bending moment = 1079031. lbs-in  
 Maximum shear force = 38000.00000 lbs  
 Depth of maximum bending moment = 55.65000000 in  
 Depth of maximum shear force = 0.00000 in  
 Number of iterations = 32  
 Number of zero deflection points = 2

Summary of Pile-Head Response(s)

Definition of Symbols for File-Head Loading Conditions:

Type 1 = Shear and Moment,           y = pile-head displacement  
 Type 2 = Shear and Slope,           M = pile-head moment lbs-in  
 Type 3 = Shear and Rot. Stiffness,   V = pile-head shear force lbs  
 Type 4 = Deflection and Moment,     S = pile-head slope, radians  
 Type 5 = Deflection and Slope,     R = rotational stiffness of pile-head-in-lbs/rd

| Load Type | Boundary Condition 1 | Boundary Condition 2 | Axial Load lbs | File-Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|-----------|----------------------|----------------------|----------------|-------------------------|-----------------------|-------------------|
| 1         | V=                   | M=                   | 38000.0000     | .9968326                | 1079051.              | 38000.0000        |

File-head Deflection vs. File Length

Boundary Condition Type 1, Shear and Moment

Shear = 38000. lbs  
 Moment = 0. in-lbs  
 Axial Load = 90000. lbs

| File Length in | File Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|----------------|-------------------------|-----------------------|-------------------|
| 210.000        | .99683260               | 1079052.              | 38000.00000       |
| 199.500        | .99651354               | 1079098.              | 38000.00000       |
| 189.000        | .99619525               | 1079144.              | 38000.00000       |
| 178.500        | .99587706               | 1078502.              | 38000.00000       |
| 168.000        | 1.00512460              | 1076531.              | 38000.00000       |
| 157.500        | 1.02160803              | 1071296.              | 38000.00000       |
| 147.000        | 1.08156806              | 1056796.              | 38000.00000       |
| 136.500        | 1.24111123              | 1025064.              | 38000.00000       |
| 126.000        | 1.59211583              | 979363.95552          | 38000.00000       |
| 115.500        | 2.49672730              | 925243.23618          | 38000.00001       |

The analysis ended normally.

LPILE Plus for Windows, Version 5.0 (5.0.11)  
Analysis of Individual Piles and Drilled Shafts  
Subjected to Lateral Loading Using the p-y Method

(c) Copyright ENSOFT, Inc., 1985-2005  
All Rights Reserved

This program is licensed to:

Youwei Zhou  
Kleinfeldar

Path to file locations: U:\Yzhou\Projects\75010\Analysis\LPILE\A1\  
Name of input data file: Alp25mm.lpd  
Name of output file: Alp25mm.lpo  
Name of plot output file: Alp25mm.lpp  
Name of runtime file: Alp25mm.lpr

Time and Date of Analysis

Date: May 30, 2007 Time: 12:53:42

Problem Title

A1 pinned head 1.0 inch

Program Options

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
- Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:  
- Only internally-generated p-y curves used in analysis  
- Analysis does not use p-y multipliers (individual pile or shaft action only)  
- Analysis assumes no shear resistance at pile tip  
- Analysis includes automatic computation of pile-top deflection vs. pile embedment length  
- No computation of foundation stiffness matrix elements  
- Output pile response for full length of pile  
- Analysis assumes no soil movements acting on pile  
- No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:  
- Number of pile increments = 200  
- Maximum number of iterations allowed = 200  
- Deflection tolerance for convergence = 1.0000E-05 in  
- Maximum allowable deflection = 1.0000E+01 in

Printing Options:  
- Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile  
- Printing increment (spacing of output points) = 1

Pile Structural Properties and Geometry

Pile Length = 307.70 in  
Depth of ground surface below top of pile = -100.30 in  
Slope angle of ground surface = 25.00 deg.

Structural properties of pile defined using 2 points

| Point | Depth X in | Pile Diameter in | Moment of Inertia in <sup>4</sup> | Pile Area Sq.in | Modulus of Elasticity lbs/Sq.in |
|-------|------------|------------------|-----------------------------------|-----------------|---------------------------------|
| 1     | 0.0000     | 15.00000000      | 1242.5000                         | 176.7000        | 4300000.                        |
| 2     | 500.0000   | 15.00000000      | 1242.5000                         | 176.7000        | 4300000.                        |

Soil and Rock Layering Information

The soil profile is modelled using 6 layers

Layer 1 is sand, p-y criteria by Reese et al., 1974  
Distance from top of pile to top of layer = -100.300 in  
Distance from top of pile to bottom of layer = 91.700 in  
p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>\*3</sup>  
p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>\*3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 2 is stiff clay without free water  
Distance from top of pile to top of layer = 91.700 in  
Distance from top of pile to bottom of layer = 175.700 in

Layer 3 is sand, p-y criteria by Reese et al., 1974  
Distance from top of pile to top of layer = 175.700 in  
Distance from top of pile to bottom of layer = 235.700 in  
p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>\*3</sup>  
p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>\*3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 235.700 in  
 Distance from top of pile to bottom of layer = 295.700 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 295.700 in  
 Distance from top of pile to bottom of layer = 381.700 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 6 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 381.700 in  
 Distance from top of pile to bottom of layer = 450.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends 142.30 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth is defined using 12 points

| Point No. | Depth X in | Eff. Unit Weight lbs/in**3 |
|-----------|------------|----------------------------|
| 1         | -100.30    | .07234                     |
| 2         | 91.70      | .07234                     |
| 3         | 91.70      | .07234                     |
| 4         | 175.70     | .07234                     |
| 5         | 175.70     | .07234                     |
| 6         | 235.70     | .07234                     |
| 7         | 235.70     | .06940                     |
| 8         | 295.70     | .06940                     |
| 9         | 295.70     | .07234                     |
| 10        | 381.70     | .07234                     |
| 11        | 381.70     | .03623                     |
| 12        | 450.00     | .03623                     |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth defined using 12 points

| Point No. | Depth X in | Cohesion c lbs/in**2 | Angle of Friction Deg. | E50 or k <sub>rm</sub> | RQD % |
|-----------|------------|----------------------|------------------------|------------------------|-------|
| 1         | -100.300   | .00000               | 30.00                  | -----                  | ----- |
| 2         | 91.700     | .00000               | 30.00                  | -----                  | ----- |
| 3         | 91.700     | 6.25000              | .00                    | -----                  | ----- |
| 4         | 175.700    | 6.25000              | .00                    | -----                  | ----- |
| 5         | 175.700    | .00000               | 30.00                  | -----                  | ----- |
| 6         | 235.700    | .00000               | 30.00                  | -----                  | ----- |
| 7         | 235.700    | 5.56000              | 25.00                  | -----                  | ----- |
| 8         | 295.700    | 5.56000              | 25.00                  | -----                  | ----- |
| 9         | 295.700    | 3.47000              | 32.00                  | -----                  | ----- |
| 10        | 381.700    | 3.47000              | 32.00                  | -----                  | ----- |
| 11        | 381.700    | 3.47000              | 32.00                  | -----                  | ----- |
| 12        | 450.000    | 3.47000              | 32.00                  | -----                  | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k<sub>rm</sub> are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 Pile-head Loading and Pile-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number: 1

Pile-head boundary conditions are Displacement and Moment (BC Type 4)  
 Deflection at pile head = 1.000 in  
 Bending moment at pile head = .000 in-lbs  
 Axial load at pile head = 90000.000 lbs





Number of iterations = 20  
 Number of zero deflection points = 3

-----  
 Summary of File-Head Response(s)  
 -----

Definition of Symbols for File-Head Loading Conditions:

Type 1 = Shear and Moment, y = pile-head displacement in  
 Type 2 = Shear and Slope, M = pile-head moment lbs-in  
 Type 3 = Shear and Rot. Stiffness, V = pile-head shear force lbs  
 Type 4 = Deflection and Moment, S = pile-head slope, radians  
 Type 5 = Deflection and Slope, R = rotational stiffness of pile-head in-lbs/rad

| Load Type | Boundary Condition | Boundary Condition | Axial Load lbs | File-Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|-----------|--------------------|--------------------|----------------|-------------------------|-----------------------|-------------------|
| 4         | y = 1.000000       | M = 0.000          | 90000.0000     | 1.0000000               | 1149409.              | 41953.7834        |

-----  
 File-head Deflection vs. File Length  
 -----

Boundary Condition Type 4, Deflection and Moment

Deflection = 1.00000 in  
 Moment = 0. in-lbs  
 Axial Load = 90000. lbs

| File Length in | File Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|----------------|-------------------------|-----------------------|-------------------|
| 307.700        | 1.00000000              | 1149409.              | 41953.78342       |
| 292.215        | 1.00000000              | 1149412.              | 41955.13514       |
| 276.930        | 1.00000000              | 1149052.              | 41950.51319       |
| 261.545        | 1.00000000              | 1149141.              | 41951.30635       |
| 246.160        | 1.00000000              | 1148758.              | 41943.31770       |
| 230.775        | 1.00000000              | 1147827.              | 41923.65069       |
| 215.390        | 1.00000000              | 1147317.              | 41913.06536       |
| 200.005        | 1.00000000              | 1147468.              | 41912.40472       |
| 184.620        | 1.00000000              | 1146294.              | 41927.02608       |
| 169.235        | 1.00000000              | 1141277.              | 41798.45254       |

The analysis ended normally.

LPFILE Plus for Windows, Version 5.0 (5.0.11)  
 Analysis of Individual Piles and Drilled Shafts  
 Subjected to Lateral Loading Using the p-y Method  
 (c) Copyright ENSOFF, Inc., 1985-2005  
 All Rights Reserved

This program is licensed to:

Youwei Zhou  
 Kloifelder

Path to file locations: U:\Yzhou\Projects\75010\Analysis\LPFILE\A1\  
 Name of input data file: Alp6mm.lpd  
 Name of output file: Alp6mm.lpo  
 Name of plot output file: Alp6mm.lpp  
 Name of runtime file: Alp6mm.lpr

Time and Date of Analysis

Date: May 30, 2007 Time: 12:52:30

Problem Title

A1 pinned head 0.25 inch

Program Options

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
 - Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:  
 - Only internally-generated p-y curves used in analysis  
 - Analysis does not use p-y multipliers (individual pile or shaft action only)  
 - Analysis assumes no shear resistance at pile tip  
 - Analysis includes automatic computation of pile-top deflection vs. pile embedment length  
 - No computation of foundation stiffness matrix elements  
 - Output pile response for full length of pile  
 - Analysis assumes no soil movements acting on pile  
 - No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:  
 - Number of pile increments = 200  
 - Maximum number of iterations allowed = 200  
 - Deflection tolerance for convergence = 1.0000E-05 in  
 - Maximum allowable deflection = 1.0000E+01 in

Printing Options:  
 - Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile.  
 - Printing increment (spacing of output points) = 1

Pile Structural Properties and Geometry

Pile Length = 307.70 in  
 Depth of ground surface below top of pile = -100.30 in  
 Slope angle of ground surface = 25.00 deg.

Structural properties of pile defined using 2 points

| Point | Depth X<br>in | Pile Diameter<br>in | Moment of Inertia<br>in <sup>4</sup> | Pile Area<br>Sq.in | Modulus of Elasticity<br>lbs/Sq.in |
|-------|---------------|---------------------|--------------------------------------|--------------------|------------------------------------|
| 1     | 0.0000        | 15.00000000         | 2485.0000                            | 176.7000           | 4300000.                           |
| 2     | 500.0000      | 15.00000000         | 2485.0000                            | 176.7000           | 4300000.                           |

Soil and Rock Layering Information

The soil profile is modelled using 6 layers

Layer 1 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = -100.300 in  
 Distance from top of pile to bottom of layer = 91.700 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 2 is stiff clay without free water  
 Distance from top of pile to top of layer = 91.700 in  
 Distance from top of pile to bottom of layer = 175.700 in

Layer 3 is sand, p-y criteria by Reese et al., 1974  
 Distance from top of pile to top of layer = 175.700 in  
 Distance from top of pile to bottom of layer = 235.700 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>



NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 235.700 in  
 Distance from top of pile to bottom of layer = 295.700 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 295.700 in  
 Distance from top of pile to bottom of layer = 381.700 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 6 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 381.700 in  
 Distance from top of pile to bottom of layer = 450.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends 142.30 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth is defined using 12 points

| Point No. | Depth X in | Eff. Unit Weight lbs/in**3 |
|-----------|------------|----------------------------|
| 1         | -100.30    | .07234                     |
| 2         | 91.70      | .07234                     |
| 3         | 91.70      | .07234                     |
| 4         | 175.70     | .07234                     |
| 5         | 175.70     | .07234                     |
| 6         | 235.70     | .07234                     |
| 7         | 235.70     | .08940                     |
| 8         | 295.70     | .06940                     |
| 9         | 295.70     | .07234                     |
| 10        | 381.70     | .07234                     |
| 11        | 381.70     | .03623                     |
| 12        | 450.00     | .03623                     |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth defined using 12 points

| Point No. | Depth X in | Cohesion c lbs/in**2 | Angle of Friction Deg. | E50 or k <sub>zm</sub> | RQD % |
|-----------|------------|----------------------|------------------------|------------------------|-------|
| 1         | -100.300   | .00000               | 30.00                  | -----                  | ----- |
| 2         | 91.700     | .00000               | 30.00                  | -----                  | ----- |
| 3         | 91.700     | 6.25000              | .00                    | -----                  | ----- |
| 4         | 175.700    | 6.25000              | .00                    | -----                  | ----- |
| 5         | 175.700    | .00000               | 30.00                  | -----                  | ----- |
| 6         | 235.700    | .00000               | 30.00                  | -----                  | ----- |
| 7         | 235.700    | 5.56000              | 25.00                  | -----                  | ----- |
| 8         | 295.700    | 5.56000              | 25.00                  | -----                  | ----- |
| 9         | 295.700    | 3.47000              | 32.00                  | -----                  | ----- |
| 10        | 381.700    | 3.47000              | 32.00                  | -----                  | ----- |
| 11        | 381.700    | 3.47000              | 32.00                  | -----                  | ----- |
| 12        | 450.000    | 3.47000              | 32.00                  | -----                  | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k<sub>zm</sub> are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 Pile-head Loading and Pile-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number 1

Pile-head boundary conditions are Displacement and Moment (BC Type 4)  
 Deflection at pile head = .250 in  
 Bending moment at pile head = .000 in-lbs  
 Axial load at pile head = 90000.000 lbs





Number of iterations = 15  
 Number of zero deflection points = 3

-----  
 Summary of File-Head Response(s)  
 -----

Definition of Symbols for File-Head Loading Conditions:

Type 1 = Shear and Moment, y = pile-head displacment in  
 Type 2 = Shear and Slope, M = pile-head moment lbs-in  
 Type 3 = Shear and Rot. Stiffness, V = pile-head shear force lbs  
 Type 4 = Deflection and Moment, S = pile-head slope, radians  
 Type 5 = Deflection and Slope, R = rotational stiffness of pile-head-in-lbs/rad

| Load Type | Boundary Condition 1 | Boundary Condition 2 | Axial Load lbs | File-Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|-----------|----------------------|----------------------|----------------|-------------------------|-----------------------|-------------------|
| 4         | y = .250000          | M = 0.000            | 90000.0000     | .2500000                | 494372.               | 19230.6615        |

-----  
 File-head Deflection vs. File Length  
 -----

Boundary Condition Type 4, Deflection and Moment

Deflection = .25000 in  
 Moment = 0. in-lbs  
 Axial Load = 90000. lbs

| File Length in | File Head Deflection in | Maximum Moment in-lbs | Maximum Shear lbs |
|----------------|-------------------------|-----------------------|-------------------|
| 307.700        | .25000000               | 494372.36186          | 19230.66134       |
| 292.315        | .25000000               | 494403.97759          | 19231.50262       |
| 276.930        | .25000000               | 494020.10188          | 19225.71530       |
| 261.545        | .25000000               | 494109.13977          | 19227.30859       |
| 246.160        | .25000000               | 494179.59867          | 19227.49720       |
| 230.775        | .25000000               | 494140.75020          | 19225.82624       |
| 215.390        | .25000000               | 494005.53172          | 19223.77817       |
| 200.005        | .25000000               | 494200.83033          | 19223.23880       |
| 184.620        | .25000000               | 494061.64984          | 19223.29397       |
| 169.235        | .25000000               | 493173.19571          | 19208.99409       |

The analysis ended normally.

LPFILE Plus for Windows, Version 5.0 (5.0.11)  
Analysis of Individual Piles and Drilled Shafts  
Subjected to Lateral Loading Using the p-y Method  
© Copyright ENSOFT, Inc., 1985-2005  
All Rights Reserved

This program is licensed to:

Youwei Zhou  
Kleifelder

Path to file locations: U:\Zhou\Projects\75010\Analysis\LPFILE\A1\  
Name of input data file: Alf25mm.lpd  
Name of output file: Alf25mm.lpo  
Name of plot output file: Alf25mm.lpp  
Name of runtime file: Alf25mm.lpr

Time and Date of Analysis

Date: May 30, 2007 Time: 10:58:48

Problem Title

A1 fixed head 1.0 inch

Program Options

Units Used in Computations - US Customary Units, inches, pounds

Basic Program Options:

Analysis Type 1:  
- Computation of Lateral Pile Response Using User-specified Constant EI

Computation Options:

- Only internally-generated p-y curves used in analysis
- Analysis does not use p-y multipliers (individual pile or shaft action only)
- Analysis assumes no shear resistance at pile tip
- Analysis includes automatic computation of pile-top deflection vs. pile embedment length
- No computation of foundation stiffness matrix elements
- Output pile response for full length of pile
- Analysis assumes no soil movements acting on pile
- No additional p-y curves to be computed at user-specified depths

Solution Control Parameters:

- Number of pile increments = 200
- Maximum number of iterations allowed = 200
- Deflection tolerance for convergence = 1.0000E-05 in
- Maximum allowable deflection = 1.0000E+01 in

Printing Options:

- Values of pile-head deflection, bending moment, shear force, and soil reaction are printed for full length of pile.
- Printing increment (spacing of output points) = 1

Pile Structural Properties and Geometry

File length = 307.70 in  
Depth of ground surface below top of pile = -100.30 in  
Slope angle of ground surface = 25.00 deg.

Structural properties of pile defined using 2 points

| Point | Depth X in | Pile Diameter in | Moment of Inertia in <sup>4</sup> | Pile Area Sq.in | Modulus of Elasticity lbs/Sq.in |
|-------|------------|------------------|-----------------------------------|-----------------|---------------------------------|
| 1     | 0.0000     | 15.00000000      | 1242.5000                         | 176.7000        | 4300000.                        |
| 2     | 500.0000   | 15.00000000      | 1242.5000                         | 176.7000        | 4300000.                        |

Soil and Rock Layering Information

The soil profile is modelled using 6 layers

Layer 1 is sand, p-y criteria by Reese et al., 1974  
Distance from top of pile to top of layer = -100.300 in  
Distance from top of pile to bottom of layer = 91.700 in  
p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 2 is stiff clay without free water  
Distance from top of pile to top of layer = 91.700 in  
Distance from top of pile to bottom of layer = 175.700 in

Layer 3 is sand, p-y criteria by Reese et al., 1974  
Distance from top of pile to top of layer = 175.700 in  
Distance from top of pile to bottom of layer = 235.700 in  
p-y subgrade modulus k for top of soil layer = .000 lbs/in<sup>3</sup>  
p-y subgrade modulus k for bottom of layer = .000 lbs/in<sup>3</sup>

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 4 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 235.700 in  
 Distance from top of pile to bottom of layer = 295.700 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 5 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 295.700 in  
 Distance from top of pile to bottom of layer = 381.700 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

Layer 6 is silt with cohesion and friction  
 Distance from top of pile to top of layer = 381.700 in  
 Distance from top of pile to bottom of layer = 450.000 in  
 p-y subgrade modulus k for top of soil layer = .000 lbs/in\*\*3  
 p-y subgrade modulus k for bottom of layer = .000 lbs/in\*\*3

NOTE: Internal default values for p-y subgrade modulus will be computed for the above soil layer.

(Depth of lowest layer extends 142.30 in below pile tip)

-----  
 Effective Unit Weight of Soil vs. Depth  
 -----

Distribution of effective unit weight of soil with depth is defined using 12 points

| Point No. | Depth X in | Eff. Unit Weight lbs/in**3 |
|-----------|------------|----------------------------|
| 1         | -100.30    | .07234                     |
| 2         | 91.70      | .07234                     |
| 3         | 91.70      | .07234                     |
| 4         | 175.70     | .07234                     |
| 5         | 175.70     | .07234                     |
| 6         | 235.70     | .07234                     |
| 7         | 235.70     | .06940                     |
| 8         | 295.70     | .06940                     |
| 9         | 295.70     | .07234                     |
| 10        | 381.70     | .07234                     |
| 11        | 381.70     | .03623                     |
| 12        | 450.00     | .03623                     |

-----  
 Shear Strength of Soils  
 -----

Distribution of shear strength parameters with depth defined using 12 points

| Point No. | Depth X in | Cohesion c lbs/in**2 | Angle of Friction Deg. | E50 or k <sub>cm</sub> | RQD % |
|-----------|------------|----------------------|------------------------|------------------------|-------|
| 1         | -100.300   | .00000               | 30.00                  | -----                  | ----- |
| 2         | 91.700     | .00000               | 30.00                  | -----                  | ----- |
| 3         | 91.700     | 6.25000              | .00                    | -----                  | ----- |
| 4         | 175.700    | 6.25000              | .00                    | -----                  | ----- |
| 5         | 175.700    | .00000               | 30.00                  | -----                  | ----- |
| 6         | 235.700    | .00000               | 30.00                  | -----                  | ----- |
| 7         | 235.700    | 5.56000              | 25.00                  | -----                  | ----- |
| 8         | 295.700    | 5.56000              | 25.00                  | -----                  | ----- |
| 9         | 295.700    | 3.47000              | 32.00                  | -----                  | ----- |
| 10        | 381.700    | 3.47000              | 32.00                  | -----                  | ----- |
| 11        | 381.700    | 3.47000              | 32.00                  | -----                  | ----- |
| 12        | 450.000    | 3.47000              | 32.00                  | -----                  | ----- |

Notes:

- (1) Cohesion = uniaxial compressive strength for rock materials.
- (2) Values of E50 are reported for clay strata.
- (3) Default values will be generated for E50 when input values are 0.
- (4) RQD and k<sub>cm</sub> are reported only for weak rock strata.

-----  
 Loading Type  
 -----

Static loading criteria was used for computation of p-y curves

-----  
 File-head Loading and Pile-head Fixity Conditions  
 -----

Number of loads specified = 1

Load Case Number 1

File-head boundary conditions are Displacement and Slope (BC Type 5)  
 Deflection at pile head = 1.000 in  
 Slope at pile head = .000 in/in  
 Axial load at pile head = 90000.000 lbs



